



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

April 15, 1985

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Dresser Industries
Diaphragm Seal Globe
Valves [RDC 119(84)]

Dear Mr. Keppler:

This letter is being transmitted to advise you of our progress concerning the modification of Dresser Industries diaphragm seal globe valves being conducted per our Deviation Analysis Report 212.

Since January 1985, 161 valves have been modified under the corrective action program. This represents approximately 82% completion of the modifications required. Approximately 27% of the modified valves have been tested, and have met the acceptance criteria. The test results indicate our modification program corrects the design deficiency.

Further progress concerning the modification program and operability verification will be reported by June 1, 1985.


8505010601 850415
PDR ADOCK 05000440
S PDR

IE27
APR 18 1985

April 15, 1985

Please call if there are any questions.

Sincerely,



Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. J. A. Grobe
USNRC, Site Office

Mr. D. E. Keating
USNRC, Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

Mr. T. E. Meyers, President
Industrial Valve Operations Division
Dresser Industries Incorporated
P.O. Box 1430
Alexandria, LA 71301