

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

SUSHIL C. JAIN
Division Vice President
Nuclear Services
Nuclear Power Division

(412) 393-5512
Fax (412) 643-8069


August 6, 1996
NPD1VPS:0237

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, Licensee No. DPR-66
LER-96-004-02

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Duquesne Light Company (DLC), Beaver Valley Power Station, has developed a review plan in response to Generic Letter (GL) 96-01, "Testing of Safety-Related Logic Circuits". The completion dates are included in the DLC response to the Commission dated April 4, 1996.

In accordance with DLC letter NPD1VPO:00465, dated April 23, 1996, enclosed you will find Revision 2 to 50-334, LER 96-004-00, Unit 1, Incorrect Testing of Safety-Related Logic Circuits which is reportable in accordance with 10 CFR 50.73 a.2.i.B "Condition Prohibited by Technical Specifications". This revision covers reportable surveillance inadequacies of safety-related logic discovered since April 23, 1996. Further updates will be submitted upon discovery of additional surveillance deficiencies that fall under the reportability criteria of 10 CFR 50.73.


Sushil C. Jain

1/1
I e 22

JH/tab

Attachment

9608090082 960806
PDR ADOCK 05000334
S PDR



August 6, 1996
NPD1VPS:0237
Page 2

cc: Mr. H. J. Miller, Regional Administrator
United States Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia, PA 19406

Mr. D. S. Brinkman
BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, DC 20555

Mr. Larry Rossbach
BVPS Senior Resident Inspector
United States Nuclear Regulatory Commission

Mr. J. A. Hultz
Ohio Edison Company
76 S. Main Street
Akron, OH 44308

Mr. Mark Burns
Centerior Energy Corporation
6200 Oak Tree Boulevard
Independence, OH 44101-4661

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Mr. Robert Maiers
Department of Environmental Resources
P. O. Box 8469
State Office Building, 13th Floor
Harrisburg, PA 17105-8469

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P. O. Box 26666
One James River Plaza
Richmond, VA 23261