

Attachment IV to NA 92-0089
Page 1 of 2

Attachment IV
Proposed Technical Specification Changes

9211160134 921105
PDR ADOCK 05000482
P PDR

POWER DISTRIBUTION LIMITS

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENTS

4.2.1.1 The indicated AFD shall be determined to be within its limits during POWER OPERATION above 50% of RATED THERMAL POWER by:

- a. Monitoring the indicated AFD for each OPERABLE excore channel *at*
- ~~1) At least once per 7 days when the AFD Monitor Alarm is OPERABLE, and~~
 - ~~2) At least once per hour for the first 24 hours after restoring the AFD Monitor Alarm to OPERABLE status.~~
- b. Monitoring and logging the indicated AFD for each OPERABLE excore channel at least once per hour ~~for the first 24 hours and at least once per 30 minutes thereafter,~~ when the AFD Monitor Alarm is inoperable. The logged values of the indicated AFD shall be assumed to exist during the interval preceding each logging.

4.2.1.2 The indicated AFD shall be considered outside of its limits when at least two OPERABLE excore channels are indicating the AFD to be outside the limits.