

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

50-440/441

November 11, 1992
PY-CEI/OEPA-0166 L

Ohio EPA
Division of Water Pollution Control
Enforcement Section, ES/MOR
1800 Watermark Drive
Columbus, Ohio 43266-0149

Gentlemen,

Enclosed are the NPDES monthly report forms for the month of October, 1992.

Please feel free to call if you have any questions.

Sincerely,

A handwritten signature in cursive script, appearing to read 'M. D. Lyster'.
Michael D. Lyster

MDL:LKB:ss

Encl. ure

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Document Control Desk
NRC Region III

130020
9211160153 921031
PDR ADOCK 05000440
R PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

IF25
11

CLEVELAND ELECTRIC ILLUM CO 31B00016001 OCT 1992
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 19 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
63461

001 DISCHARGE FROM REGENERATE
 NEUTRALIZATION PITS

FORM

CEI, PERRY


J.J. GRIMM

	1 999	1 999	1 999	2 96	3 1
	CONDUI FLOW MCD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDUE T NFLT MG/L	O&G TOTAL MG/L
01	50050	00401	00402	00530	00550
02	AH	AH	AH		
03	0.0347	8.0	7.6		
04	AH	AH	AH		
05	AH	AH	AH		
06	AH	AH	AH		
07	AH	AH	AH		
08	AH	AH	AH		
09	0.0104	7.9	7.6	8	AA
10	AH	AH	AH		
11	0.0155	7.8	7.5		
12	0.0126	7.5	7.4		AA
13	AH	AH	AH		
14	AH	AH	AH		
15	AH	AH	AH		
16	AH	AH	AH		
17	0.0154	8.3	7.6		
18	AH	AH	AH		
19	AH	AH	AH		
20	AH	AH	AH		
21	AH	AH	AH		
22	AH	AH	AH		
23	0.0150	7.4	7.2	14	
24	AH	AH	AH		
25	AH	AH	AH		
26	0.0156	7.6	7.5		AA
27	AH	AH	AH		
28	AH	AH	AH		
29	0.0144	8.1	7.6		
30	AH	AH	AH		
31	AH	AH	AH		
	0.1396	62.6	60.0	22	AA
	0.0175	7.8	7.2	11	AA
	0.0347	8.3	7.6	14	AA
	0.0126	7.4	7.2	8	AA

AA - BELOW DETECTABLE LIMIT (5 mg/l for O&G and 2.5 mg/l for RESIDUE)
 AH - SAMPLE NOT TAKEN, NO DISCHARGE PERFORMED THIS DATE

REPORTER

11-11-92



VP-Nuclear

CLEVELAND ELECTRIC ILLUM CO 31B00016002 OCT 1992
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
63461

002 DISCHARGE FROM CHEMICAL CLEANING
 LAGOON E PLANT

FORM

CEI, PERRY

J.J. GRIMM


1	1	2	3	2	2	2
999	999	96	1	96	96	96
CONDUIT	PH	RESIDUE	C&G	PHOS-T	COPPER	IRON
FLOW		T NFLT	TOTAL	P-WET	CU.TOT	E.TOT
MGD	S.U.	MG/L	MG/L	MG/L	MG/L	MG/L
50050	00400	00530	00550	00665	01042	01045

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

NO DISCHARGE OCCURRED DURING THE MONTH

REPORTER

11-11-92



VP-Nuclear

CLEVELAND ELECTRIC ILLUM CO 3IB00016004 OCT 1992
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
63461

004 POINT REP OF DISCHARGE PRIOR TO
 ENTRY TO TUNNEL

FORM

CEI, PERRY


J.J. GRIMM

	1 999	1 99	3 1	3 1
	WATER TEMP F.	CONDUIT FLOW MGD	CHLOR FREE A MG/L	PH S.U.
00011	50050	50064	00400	
01	66	117.1	0.00	
02	67	115.8	0.00	8.4
03	68	127.3	0.00	
04	66	127.9	0.00	
05	65	114.0	0.00	
06	64	93.8	0.00	8.1
07	65	105.8	0.00	
08	66	96.9	0.00	
09	67	93.4	0.00	8.2
10	67	103.8	0.00	
11	66	99.5	0.00	
12	65	95.1	0.00	
13	64	94.3	0.00	8.5
14	64	101.9	0.00	
15	66	103.0	0.00	
16	65	103.9	0.00	8.4
17	63	98.2	0.00	
18	61	89.8	0.00	
19	59	90.8	0.00	
20	59	86.5	0.00	8.2
21	60	83.1	0.00	
22	60	89.3	0.00	
23	61	98.6	0.00	8.2
24	57	124.6	0.00	
25	55	116.3	0.00	
26	56	108.1	0.00	8.2
27	55	119.9	0.00	
28	54	102.6	0.00	
29	55	109.5	0.00	
30	55	106.0	0.00	8.1
31	54	89.4	0.00	
1915	3206.2	0.00	3	
62	103.4	0.00	3	
68	127.9	0.00	8.5	
54	83.1	0.00	8.1	

NONE

REPORTER

11-11-92



VP-Nuclear

MONTHLY REPORT FORM

CLEVELAND ELECTRIC ILLUM CO 3IB00016800 OCT 1992
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

800 INTAKE WATER AT INLET TO PLANT
FROM LAKE ERIE

FORM

CEI. PERRY

J.J. GRIMM

1
999

WATER
TEMP
F.

00011


01	61
02	61
03	62
04	61
05	59
06	58
07	59
08	59
09	59
10	60
11	60
12	58
13	57
14	56
15	58
16	58
17	57
18	54
19	53
20	52
21	52
22	52
23	52
24	52
25	51
26	52
27	52
28	52
29	52
30	52
31	50

1730
56
62
50

NONE

REPORTER

11-11-92



WP-Nuclear