



UNION ELECTRIC COMPANY
Callaway Plant

November 4, 1992

Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

ULNRC-2720

Dear Sir:

DOCKET NUMBER 50-485
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPP-30
MONTHLY OPERATING REPORT
OCTOBER 1992

The enclosed Monthly Operating Report for October, 1992 is submitted pursuant to section 6.9.1.8 of the Callaway Unit 1 Technical Specifications.

W. R. Campbell
Manager, Callaway Plant

WRC/DEY/JAM/TAM/JWK/crc

Enclosure

cc: Distribution attached

160088

921116041 921031
PDR ADOCK 05000483
R PDR

Mailing Address: P.O. Box 64 - Fulton, MO 65251

JE24

cc Distribution for ULNRC-2720

with enclosures

Mr. Richard Hague, Chief
Project Section 1A
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Mr. L. R. Wharton (2 copies)
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E21
11555 Rockville, MD 20852

NRC Resident Inspector

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

DOCKET NO. 50-483
UNIT NAME CALLAWAY UNIT 1
DATE 11-06-92
COMPLETED BY J. W. Knaup
TELEPHONE 314/676-8485

PART A OPERATIONS SUMMARY

The plant operated at approximately 100% power for the entire month.

PART B PORV AND SAFETY VALVE SUMMARY

None

PART C
AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO	50-483
UNIT	Callaway Unit 1
DATE	11-06-92
COMPLETED BY	J. W. Knaup
TELEPHONE	314/676-8485

MONTH: OCTOBER 1992

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1148	17	1163
2	1146	18	1161
3	1145	19	1163
4	1144	20	1154
5	1146	21	1146
6	1151	22	1142
7	1148	23	1141
8	1150	24	1150
9	1154	25	1151
10	1155	26	1162
11	1158	27	1170
12	1156	28	1171
13	1151	29	1170
14	1147	30	1170
15	1148	31	1165
16	1159		

Part D
OPERATING DATA REPORT

DOCKET NO. 50-483
UNIT NAME CALLAWAY UNIT 1
DATE 11-06-92
COMPLETED BY J. W. Knaup
TELEPHONE 314/676-8485

OPERATING STATUS

(YTD CUM)

1. REPORTING PERIOD: OCTOBER 1992 GROSS HOURS IN REPORTING PERIOD: 745 7320 68,941.5
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3565 MAX. DEPEND. CAPACITY (MWe-Net): 1125
DESIGN ELECTRICAL RATING (MWe-Net): 1171
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net):
4. REASONS FOR RESTRICTION (IF ANY):

	<u>THIS MONTH</u>	<u>YR TO DATE</u>	<u>CUMULATIVE</u>
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	745.0	5825.2	59,913.7
6. REACTOR RESERVE SHUTDOWN HOURS.....	0	0	0
7. HOURS GENERATOR ON LINE.....	745.0	5742.3	58,591.7
8. UNIT RESERVE SHUTDOWN HOURS.....	0	0	0
9. GROSS THERMAL ENERGY GENERATED (MWH).....	2,636,341	19,656,795	195,919,658
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)...	900,004	6,715,668	66,778,832
11. NET ELECTRICAL ENERGY GENERATED (MWH)....	859,841	6,394,433	63,470,431
12. REACTOR SERVICE FACTOR.....	100.0	79.6	86.9
13. REACTOR AVAILABILITY FACTOR.....	100.0	79.6	86.9
14. UNIT SERVICE FACTOR.....	100.0	78.4	85.0
15. UNIT AVAILABILITY FACTOR.....	100.0	78.4	85.0
16. UNIT CAPACITY FACTOR (Using MDC).....	102.6	77.6	81.8
17. UNIT CAPACITY FACTOR (Using Design MWe)...	98.6	74.6	78.6
18. UNIT FORCED OUTAGE RATE.....	0.0	2.4	2.9
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			
20. IF SHUT DOWN AT END OF REPORTING PERIOD, ESTIMATED DATE OF STARTUP:			

PART E
UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-483
UNIT NAME CALLAWAY UNIT 1
DATE 11-06-92
COMPLETED BY J. W. Knaup
TELEPHONE 314/676-8485

REPORT MONTH: OCTOBER 1992

No.	DATE	TYPE	DURATION	REASON	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED	(HOURS)			
		S: SCHEDULED				

SUMMARY:

REASON	METHOD
A: EQUIPMENT FAILURE (EXPLAIN)	1: MANUAL
B: MAINT. OR TEST	2: MANUAL SCRAM
C: REFUELING	3: AUTOMATIC SCRAM
D: REGULATORY RESTRICTION	4: OTHER (EXPLAIN)
E: OPERATOR TRAINING AND LICENSE EXAMINATION	
F: ADMINISTRATIVE	
G: OPERATIONAL ERROR (EXPLAIN)	
H: OTHER (EXPLAIN)	