



November 10, 1992

Donald F. Schnell  
Senior Vice President  
Nuclear

U.S. Nuclear Regulatory Commission  
Attn: Document Control De.  
Mail Station P1-137  
Washington, D.C. 20555

ULNRC-2722

Gentlemen:

CALLAWAY PLANT  
DOCKET NUMBER 50-483  
REVISION TO TECHNICAL SPECIFICATION 3/4.9.7  
CRANE TRAVEL-SPENT FUEL STORAGE FACILITY

Union Electric Company herewith transmits an application for amendment to Facility Operating License Number NPF-30 for the Callaway Plant. This amendment application requests a revision to Technical Specification 3.9.7 and associated Bases to allow the fuel pool transfer gates to travel over fuel assemblies in the spent fuel pool for refueling activities, fuel handling system maintenance, and transfer gate seal replacement.

The Callaway Plant On-Site Review Committee and the Nuclear Safety Review Board have reviewed and approved this amendment application. Attachments 1 through 5 provide the Technical Specification changes, Safety Evaluation, Significant Hazards Evaluation, and Environmental Consideration, respectively. It has been determined that this amendment application does not involve any unreviewed safety questions as defined in 10CFR50.59, nor a significant hazard consideration as determined per 10CFR50.92.

If you have any questions concerning this amendment application, please contact us.

Very truly yours,

Donald F. Schnell

WEK/dls

Attachments: 1. Technical Specification Changes (marked-up)  
2. Technical Specification Changes (re-typed)  
3. Safety Evaluation  
4. Significant Hazards Evaluation  
5. Environmental Consideration

ADD

STATE OF MISSOURI )  
 ) S S  
CITY OF ST. LOUIS )

Donald F. Schnell, of lawful age, being first duly sworn upon oath says that he is Senior Vice President-Nuclear and an officer of Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Donald F. Schnell  
Donald F. Schnell  
Senior Vice President  
Nuclear

SUBSCRIBED and sworn to before me this 10th day  
of November, 1992.

Barbara J. Pfaff  
BARBARA J. PFAFF  
NOTARY PUBLIC, STATE OF MISSOURI  
MY COMMISSION EXPIRES APRIL 22, 1993  
ST. LOUIS COUNTY

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cermak  
CFA, Inc.  
18225-A Flower Hill Way  
Gaithersburg, MD 20879-5334

R. C. Knop  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Steedman, Missouri 65077

L. R. Wharton (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

bcc: D. Shafer/A160.761  
/QA Record (CA-758)

Nuclear Date  
E210.01  
DFS/Chrono  
D. F. Schnell  
J. E. Birk  
J. V. Laux  
M. A. Stiller  
G. L. Randolph  
R. J. Irwin  
P. Barrett  
C. D. Naslund  
W. K. Campbell  
A. C. Passwater  
D. E. Shafer  
W. E. Kahl (?)  
S. Wideman (WCNOC)  
R. C. Slovic (Bechtel)  
T. P. Sharkey  
NSRB (Sandra Dale)

*A140.01(1128)*