

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Nine Mile Point Unit #1										DOCKET NUMBER (2) 0 5 0 0 0 2 2 0										PAGE (3) 1 OF 0 2	
TITLE (4) Non-Functional Fire Barrier Penetrations																					
EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)												
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)									
0	3	1	4	8	5							0 5 0 0 0									
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8: (Check one or more of the following) (11)																					
OPERATING MODE (9)		N		20.402(b)		20.406(e)		80.73(a)(2)(iv)		73.71(b)											
POWER LEVEL (10)		1 1 0 1 0		20.406(a)(1)(i)		80.36(e)(1)		80.73(a)(2)(v)		73.71(c)											
				20.406(a)(1)(ii)		80.36(e)(2)		80.73(a)(2)(vi)		X OTHER (Specify in Abstract below and in Text, NRC Form 366A)											
				20.406(a)(1)(iii)		80.73(a)(2)(i)		80.73(a)(2)(vii)(A)		SPECIAL REPORT											
				20.406(a)(1)(iv)		80.73(a)(2)(ii)		80.73(a)(2)(vii)(B)													
				20.406(a)(1)(v)		80.73(a)(2)(iii)		80.73(a)(2)(x)													
LICENSEE CONTACT FOR THIS LER (12)																					
NAME Robert Randall, Supervisor, Technical Support								TELEPHONE NUMBER AREA CODE 3 1 5 3 4 1 9 1 2 4 4 5													
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC											
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR							
X YES (If yes, complete EXPECTED SUBMISSION DATE)										NO											

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

ABSTRACT

It has been identified that a number of ventilation duct fire penetrations at Nine Mile Point Unit #1 are not equipped with fire dampers. The penetrations were declared inoperable in compliance with Tech. Spec. 3.6.10.1 (Fire Barrier Penetrations). Fire watch patrols have been established in accordance with Tech. Spec. to perform hourly inspections until the situation is corrected. Tech. Spec. 3.6.10.1.d requires that a Special Report be submitted to the NRC for fire barrier penetrations which are non-functional for more than 14 days.

8505060113 850415
PDR ADOCK 05000220
S PDRIE 22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 9/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Nine Mile Point Unit #1	05000220	-	-	-	02	OF 02

TEXT (If more space is required, use additional NRC Form 366A's) (17)

TEXT

On March 1, 1985, it was discovered that six duct penetrations thru fire rated walls in the Turbine Building are not equipped with fire dampers. The six duct penetrations were declared inoperable in accordance with Tech. Spec. 3.6.10.1 which requires that non-functional fire barrier penetrations are restored to functional status within 14 days, or a report shall be prepared and submitted in accordance with 6.9.2.b.

CORRECTIVE ACTIONS

NMPC Engineering will include these penetrations in the overall review of the Fire Hazards Analysis for Unit #1. Upon completion of this review, any required modifications will be initiated.

In accordance with Tech. Spec. 3.6.10.1.c a hourly fire watch patrol was established for the identified duct penetrations not equipped with fire dampers. The fire watch patrol will be maintained until the new fire dampers are installed.

ASSESSMENT OF SAFETY CONSEQUENCES

Because fire watch patrols have been established in accordance with Tech. Spec. no safety consequences have arisen as a result of these events. The fire watch patrols perform hourly inspections guarding against potential fires while the penetrations are non-functional. The watches shall continue until the new fire dampers are installed.

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

April 12, 1985


Dr. Thomas E. Murley
Regional Administrator
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

RE: Docket No. 50-220
SPECIAL REPORT

Gentlemen:

In accordance with Technical Specification 3.6.10.1, we hereby
submit the following Special Report concerning fire barrier penetrations.

Very truly yours,



Thomas E. Lempges
Vice President
Nuclear Generation

TEL/lo
cc: Document Control Desk
attachments