



August 15, 1996

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555-0001

Gentlemen:

ULNRC-03417
TAC No. M94456

CALLAWAY PLANT
DOCKET NUMBER 50-483
AMENDMENT NUMBER 114

References: 1) ULNRC-3308 dated January 2, 1996
2) ULNRC-3364 dated April 12, 1996

This is to inform the Commission of the implementation of Amendment No. 114 to Callaway Facility Operating License No. NPF-30. Amendment No. 114 allows the containment personnel airlock doors to be open during core alterations and movement of irradiated fuel in containment. The changes have been issued to all controlled technical specification holders and became effective on August 14, 1996.

Very truly yours,

A. C. Passwater
Manager-Licensing and Fuels

WEK/

9608200151 960815
PDR ADOCK 05000483
P PDR

Abol 1/0

cc: T. A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

L. Joe Callan
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Kristine M. Thomas (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E16
11555 Rockville Pike
Rockville, MD 20852-2738

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Don Woodlan
TU Electric
1601 Bryan Street
Dallas, TX 75201-3411

Pat Nugent
Pacific Gas & Electric
Regulatory Services
P.O. Box 56
Avila Beach, CA 93424