



CALVERT CLIFFS NUCLEAR POWER PLANT
1650 CALVERT CLIFFS PARKWAY • LUSBY, MARYLAND 20657-4702

CHARLES H. CRUSE
PLANT GENERAL MANAGER
CALVERT CLIFFS

November 13, 1992

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2; Docket Nos. 50-317 and 50-318;
License Nos. DPR 53 and DPR 69
License Event Report 92-005
Main Steam Safety Valve Lift Settings Outside Technical
Specification Allowable Due to Manufacturer Error

Gentlemen,

The attached report is being sent to you as required under 10 CFR 50.73 guidelines. Should you have any questions regarding this report we will be pleased to discuss them with you.

Very truly yours,

CHC/DWM/bjd
Attachment

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
R. A. Capra, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
P. R. Wilson, NRC
R. I. McLean, DNR
J. H. Walter, PSC
Director, Office of Management Information
and Program Control

200033
9211200296 921113
PDR ADOCK 05000317
S PDR

11/10
Rec'd
w/out mail