

PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101



August 16, 1996

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Violation of NPDES Permit No. MD0002399

In accordance with Section 3.2 of Appendix B, "Environmental Protection Plan (Non-Radiological) Technical Specifications," Attachment (1) is provided reporting a recent violation of the National Pollution Discharge Elimination System Permit for the Calvert Cliffs Nuclear Power Plant.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in cursive script, reading "Peter Katz", is written over a horizontal line.

PEK/RCG/dlm

Attachment

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
A. W. Dromerick, NRC

T. T. Martin, NRC
Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC

210017
9608210047 960816
PDR ADOCK 05000317
S PDR

COO1 1/1

PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101

August 12, 1996



Mr. Jack Bowen
Inspection and Compliance Program
Water Management Administration
Maryland Department of the Environment
2500 Broening Highway
Baltimore, Maryland 21224

Dear Mr. Bowen:

RE: NPDES Permit Special Conditions A.3 Noncompliance
NPDES Discharge Permit MD0002399A, State Permit 92-DP-0187A

On August 5, 1996 at 9:10 AM, a sample for fecal coliform analysis was taken from the Calvert Cliffs Nuclear Power Plant Sewage Treatment Plant effluent to perform the weekly analysis as required by the Site NPDES Permit. On August 9, 1996 at 11:35 AM the laboratory reported that the fecal coliform result was 500 MPN/100ml, this exceeds the Daily Maximum Limitation of 400 MPN/100ml.

No impact upon receiving water was observed as a result of this event. The duration of this noncompliance is not known. The cause of this event is unknown and is being investigated. Plant operations were not changed during this period and all other analysis results were normal. The Sewage Treatment Plant records indicate that the chlorination system was functioning normally.

If you have any questions regarding this information, please contact Brenda D. Nuse at 410-495-4913.

Sincerely,

A handwritten signature in black ink, appearing to read "Peter E. Katz", followed by the text "FOR PEK" in a smaller, handwritten font.

PEK/BDN

cc: W. W. Baines
L. Shultz
J. F. Stine