

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) DONALD C. COOK NUCLEAR PLANT, UNIT 2										DOCKET NUMBER (2) 0 5 0 0 0				PAGE (3) 1 OF 1							
TITLE (4) MISSED FIRE WATCH INSPECTION																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)								
0	3	2	7	8	5	8	5	0	1	0	0	0	4	2	6	8	5	0 5 0 0 0			
OPERATING MODE (9) 1			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																		
POWER LEVEL (10) 1 0 0			20.402(b)				20.406(a)				50.73(a)(2)(iv)				73.71(b)						
			20.406(a)(1)(i)				50.36(a)(1)				50.73(a)(2)(v)				73.71(c)						
			20.406(a)(1)(ii)				50.36(a)(2)				50.73(a)(2)(vi)				OTHER: Specify in Abstract below and in Text NRC Form 356A						
			20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)										
			20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)										
			20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)										
LICENSEE CONTACT FOR THIS LER (12)																					
NAME J.F. STIETZEL - QUALITY CONTROL SUPERINTENDENT										TELEPHONE NUMBER AREA CODE 6 1 6 4 6 5 - 5 9 0 1											
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC											
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR							
YES (if yes, complete EXPECTED SUBMISSION DATE)										X NO											

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

ON MARCH 27, 1985, AT 2341 HOURS, WITH UNIT TWO OPERATING AT 100 PERCENT REACTOR THERMAL POWER, A FIRE WATCH FAILED TO INSPECT THE 4KV AB BUSS ROOM AS REQUIRED BY TECH. SPEC. 3.7.9.3. THE ROOM WAS NOT INSPECTED DUE TO PERSONNEL ERROR. THE FIRE WATCH FOUND THE ACCESS DOOR NO. 348 (IEEE, COMPONENT FUNCTION - DR) LOCKED AND DID NOT ATTEMPT TO GAIN ACCESS. THE AREA WAS ENTERED, AND THE REQUIRED INSPECTION COMPLETED AT 0100 HOURS ON MARCH 28, 1985. THE FIRE DETECTION SYSTEM INSIDE THE AREA WAS OPERABLE AT ALL TIMES. PREVENTIVE ACTION CONSISTED OF REINSTRUCTING THE FIRE WATCH IN HIS RESPONSIBILITY TO ENTER ALL AREAS ASSIGNED AS PART OF HIS FIRE WATCH DUTIES.

THERE WERE NO ADVERSE CONSEQUENCES FROM THIS EVENT.

8505060498 850426
PDR ADOCK 05000316
S PDR

IE 22
111



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

April 26, 1985

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Operating License DPR-74
Docket No. 50-316

Document Control Manager:

In accordance with the criteria established by 10CFR50.73
entitled Licensee Event Reporting System, the following
report/s are being submitted:

RO 85-010-0

Sincerely,

W.G. Smith, Jr.
W.G. Smith, Jr.
Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H.B. Brugger
R.W. Jurgensen
NRC Resident Inspector
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
INPO
PNSRC
J.F. Stietzel
A.A. Blind
Dottie Sherman, ANI Library

IE22
11