



**PUBLIC
SERVICE
INDIANA**

May 1, 1985

S. W. Shields
Senior Vice President -
Corporate Services

**Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555**

**Docket Nos.: STN 50-546
STN 50-547**

**Construction Permit Nos.: CPPR-170
CPPR-171**

**Marble Hill Nuclear Generating Station
Units 1 & 2**


Subject: Request for Additional Information, 4/2/85

Dear Mr. Youngblood:

**In response to your letter of April 2, 1985, Public Service Company of Indiana,
Inc. (PSI) provides the requested information in the attached summary.**

If you have any questions or comments, contact me at your convenience.

Sincerely,



S. W. Shields

**DJH/vj
Attachment**

**cc: J. G. Keppler
J. E. Konklin
J. F. Schapker
P. W. O'Conner
U.S. NRC (42)**

8505070158 850501
PDR ADOCK 05000546
A PDR

Boo!
1/1

MARBLE HILL NUCLEAR GENERATING STATION
UNITS 1 & 2
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

1. See Fig. 4.1-1 in the Marble Hill ER-CP; Figs. 1.2-21, 1.2-22, and 2.1-6 in the Marble Hill FSAR. Marble Hill ER-OL Section 4.3 and ER-CP Section 4.3 present further discussion of acreage disturbed by the project.

The transmission corridors and switchyard have not yet been abandoned and will be maintained according to company practices so long as they are not abandoned.

2. Structures erected on a foundation currently will remain in place. Temporary construction trailers may be removed. Debris generated by such removal will be disposed of in an environmentally acceptable manner. Some semi-permanent structures may also be removed.
3. The environmental control activities conducted during active construction continue to be effective. However, some deterioration of conditions is expected. The spoils areas were graded and seeded adequately and are stable. Runoff from the power block and laydown areas is routed to the construction runoff pond for sedimentation prior to discharge. The NPDES permit discharge limitations are being met.

The EOF/JPIC site is in essentially the same condition as it stood when construction was halted. The following EOF site layup actions were taken:

- (1) Exposed foundation work below grade was backfilled with crushed stone to grade level.
- (2) Seeding operations were undertaken to provide ground cover. Areas that were unseeded have overgrown with weeds.
- (3) No large borrow excavations were left open other than the retention pond.

Some areas of the site are exhibiting signs of erosion. These areas will be handled in accordance with the response to Item 5 below.

4. See Section 4.0 of the Marble Hill Site Stabilization Plan submitted 3/1/85.
5. Restoration activities will consist primarily of erosion control activities. The erosion control measures will consist of grading and seeding denuded areas, if necessary, in accordance with Indiana state highway standard specifications.
6. No additional permits or approvals from OFAs (Other Federal Agencies), state, or local agencies are anticipated.