

ILLINOIS POWER COMPANY



CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

May 3, 1985

Docket No. 50-461

Office of Nuclear Reactor Regulation  
Attention: Mr. Hugh L. Thompson, Jr., Director  
Division of Licensing  
US Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Certification of Compliance to 10CFR50.49, Environmental  
Qualification of Electric Equipment Important to Safety  
for Nuclear Power Plants (Generic Letter 84-24)


Dear Mr. Thompson:

Illinois Power Company is implementing an Environmental Qualification Program which satisfies the requirements of 10CFR50.49. Prior to operation, the plant will have at least one path to safe shutdown using fully qualified equipment or will have submitted a justification for continued safe operation (JCO), pending full equipment qualification. All other equipment within the scope of 50.49 will be fully qualified or a JCO will be submitted pending full qualification.

Illinois Power Company has in place a program which controls IE Bulletins and Information Notices from the time of receipt through closeout. This program assures that each item is reviewed for applicability to Clinton Power Station, and is acted upon. A record of both the review and action is maintained. Included within this program are those IE Bulletins and Information Notices which identify EQ problems.

I hereby affirm that the information in this letter is correct to the best of my knowledge.

Sincerely yours,

  
D. P. Hall  
Vice President

MED/lab

cc: B. L. Siegel, NRC Clinton Licensing Project Manager  
NRC Resident Office  
Regional Administrator, Region III, USNRC  
Illinois Department of Nuclear Safety

8505070264 850503  
PDR ADOCK 05000461  
A PDR

A048  
1/0