



UNION ELECTRIC COMPANY

1901 Gratiot Street, St. Louis

April 22, 1985

Donald F. Schnell
Vice President

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

ULNRC- 1087

DOCKET NUMBER 50-483

CALLAWAY PLANT, UNIT 1

INSPECTION OF ELECTRICAL CABLE INSIDE CONTAINMENT

Reference: SLNRC 84-0133 dated 12-18-84, same subject

In accordance with the referenced letter, the baseline cable inspection was performed at Callaway Plant during the recent maintenance outage. All visually inspected cable insulation specimens were found to be in satisfactory condition. This serves as notification of the fulfillment of this licensing commitment. The next inspection will be performed by April 1990.

Very truly yours,

Donald F. Schnell

GGY/bjk

8505070333 850422
PDR ADDCK 05000483
Q PDR

A047
1/0

cc: Gerald Charnoff, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M. Street, N.W.
Washington, D.C. 20036

Nicholas A. Petrick
Executive Director
SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

John H. Neisler
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

William Forney
Division of Projects and
Resident Programs, Chief, Section 1A
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Bruce Little
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

Tom Alexion
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop P-316
7920 Norfolk Avenue
Bethesda, MD 20014

bcc: 3456-8575
3456-0021.6
Nuclear Date
DFS/Chrono
D. F. Schnell
J. F. McLaughlin
J. E. Birk
W. H. Weber
F. D. Field
R. J. Schukai
M. A. Stiller
S. E. Miltenberger
J. J. Beisman
D. W. Capone
A. C. Passwater
T. H. McFarland
R. P. Wendling
D. E. Shafer
D. J. Walker
J. H. Smith (Bechtel)
G56.37 (CA-460)
Compliance (J. E. Davis)
NSRB (Laura Robertson)
G. G. Yates