



## Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

RECEIVED  
NRC

1985 APR 17 PM 1:10

REGION V

April 8, 1985  
ANPP-32330-TDS/PJC

U. S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane - Suite 210  
Walnut Creek, CA 94596-5368

Attention: Mr. D. F. Kirsch, Acting Director  
Division of Reactor Safety and Projects

Subject: Time Extension for Report - DER 85-05  
A 50.55(e) Potentially Reportable Deficiency Relating To  
Nonsegregated Bus Fire Penetrations Without Proper Taping  
On The Bus Conductor

File: 85-019-026; D.4.33.2

Reference: (A) Telephone conversation between A. Hon and T. Bradish  
on February 19, 1985  
(B) ANPP-32172, dated March 22, 1985 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in Reference (A), and an Interim Report was transmitted by Reference (B). At that time, it was estimated that a Final Report would be available by April 5, 1985.

Due to the extensive investigation and evaluation required, it is now expected that this information will be finalized by June 17, 1985, at which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt, Jr.  
Executive Vice President  
Project Director

EEVB/PJC/nj

cc: See Page Two

8505070511 850408  
PDR ADOCK 05000528  
S PDR

110  
IE-27

ANPP-32330-TDS/PJC  
Mr. D. F. Kirsch  
DER 85-05  
Page Two

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

D. B. Karner  
W. E. Ide  
D. B. Fasnacht  
A. C. Rogers  
L. A. Souza  
D. E. Fowler  
T. D. Shriver  
C. N. Russo  
B. S. Kaplan  
J. R. Bynum  
J. M. Allen  
D. Canady  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
H. D. Foster  
D. R. Hawkinson  
R. P. Zimmerman  
M. L. Clyde  
M. Matt  
T. J. Bloom  
D. N. Stover  
J. D. Houchen  
J. E. Kirby

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, GA 30339