

Reference: LCR 91-13
NLR-N92157

ATTACHMENT 1
CORRECTED MARKED-UP TS PAGE 6-6

9211300115 921116
PDR ADOCK 05000354
P PDR

ADMINISTRATIVE CONTROLS

6.2.3 SHIFT TECHNICAL ADVISOR

6.2.3.1 The Shift Technical Advisor shall provide advisory technical support to the Senior Nuclear Shift Supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to safe operation of the unit. The Shift Technical Advisor shall have a bachelor's degree or equivalent in a scientific or engineering discipline and shall have received specific training in the response and analysis of the unit for transients and accidents, and in unit design and layout, including the capabilities of instrumentation and controls in the control room.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS 3.1-1981 for comparable positions, except for the individual designated as the Radiation Protection Manager who shall ~~meet or exceed the~~ qualifications of Regulatory Guide 1.8, September 1975. The licensed Reactor Operators and Senior Reactor Operators shall also meet or exceed the minimum qualifications of the supplemental requirements specified in Sections A and C of Enclosure 1 of the March 28, 1990 NRC letter to all licensees.

INSERT 1

INSERT 2

6.3.2 The ~~Operating Engineer, Senior Nuclear Shift Supervisors, and Nuclear Shift Supervisors~~ Operating Engineer, Senior Nuclear Shift Supervisors, and Nuclear Shift Supervisors, shall hold a senior reactor operator license. The Nuclear Control Operators shall hold a reactor operator license.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Manager-Nuclear Training, shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI/ANS 3.1-1981 and 10 CFR Part 55.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Manager - Site Protection and shall meet or exceed the requirements of the SRP (NUREG-0800) Section 13.2.2.II.6, 10 CFR 50 Appendix R and Branch Technical Position CMEB 9.5.1, Section C.3.d.

6.5 REVIEW AND AUDIT

6.5.1 STATION OPERATIONS REVIEW COMMITTEE (SORC)

FUNCTION

6.5.1.1 The SORC shall function to advise the General Manager - Hope Creek Operations on all matters related to nuclear safety.

INSERTS FOR TECHNICAL SPECIFICATION PAGE 6-6

INSERT 1

, and the individual designated as the Operations Manager who shall meet or exceed the minimum qualifications of ANSI/ANS 3.1-1981 except as modified by Specification 6.3.3.

INSERT 2

6.3.3 The Operations Manager shall meet one of the following:

- (1) Hold a senior reactor operator license, or
- (2) Have held a senior reactor operator license for this or a similar unit (BWR).