

OPERATING DATA REPORT

DOCKET NO 50-0346

DATE August 1, 1996

COMPLETED BY Eugene C. Matranga

TELEPHONE 419/321-8369

OPERATING STATUS

1. Unit Name: Davis-Besse Unit 1
2. Reporting Period June, 1996
3. Licensed Thermal Power (MWt) 2772
4. Nameplate Rating (Gross MWe) 925
5. Design Electrical Rating (Net MWe) 906
6. Maximum Dependable Capacity (Gross MWe) 915
7. Maximum Dependable Capacity (Net MWe) 871
8. If Changes Occur in Capacity Ratings

(Items number 3 through 7) since last report, give reasons:

Notes

Resubmitted due to errors in lines 17 and 18 Yr-to-Date values.

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any (Net MWe):

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	720.00	4,367.00	157,080.00
12. Number Of Hours Reactor Was Critical	715.23	3,073.20	101,778.97
13. Reactor Reserve Shutdown Hours	0.00	0.00	5,532.00
14. Hours Generator On-Line	682.62	3,035.60	99,486.50
15. Unit Reserve Shutdown Hours	0.00	0.00	1,732.50
16. Gross Thermal Energy Generated (MWH)	1,810,520	8,118,039	258,355,948
17. Gross Electrical Energy Generated (MWH)	595,207	2,709,427	83,843,529
18. Net Electrical Energy Generated (MWH)	563,520	2,568,087	79,150,027
19. Unit Service Factor	94.81	69.51	63.33
20. Unit Availability Factor	94.81	69.51	64.44
21. Unit Capacity Factor (Using MDC Net)	89.86	67.52	57.85
22. Unit Capacity Factor (Using DER Net)	86.39	64.91	55.62
23. Unit Forced Outage Rate	0.00	0.00	17.91
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION