



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-067
(412) 787-5141
(412) 923-1960
Telecopy (412) 787-2629

May 6, 1985

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief
Licensing Branch 3
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
Auxiliary Systems Branch Open Item


Gentlemen:

This letter forwards a Westinghouse Electric Corporation report prepared for BVPS-2 which shows, as requested by the Auxiliary Systems Branch in a telecon on November 1, 1984, that loss of component cooling water to the reactor coolant pumps for 20 minutes will not result in multiple locked rotors.

With this report, the open item listed as "Primary Component Cooling Water System" in letter 2NRC-5-048 dated March 21, 1985, should be closed. NRC concurrence that it is closed is requested by May 15, 1985. Upon your concurrence, the appropriate revisions will be included in a future FSAR amendment.

DUQUESNE LIGHT COMPANY

By


J. J. Carey
Vice President

JJS/wjs
Attachment

cc: Mr. B. K. Singh, Project Manager (w/a)
Mr. G. Walton, NRC Resident Inspector (w/a)

8505100304 850506
PDR ADOCK 05000412
A PDR

13001
11