

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

May 15, 1996
PY-CEI/OEPA-0249L


Ohio Environmental Protection Agency
P.O. Box 163669
Columbus, Ohio 43216-3669

Gentlemen:

Enclosed are the NPDES monthly report forms for the month of April, 1996.

No violations occurred during this time period. If you have questions or require additional information, please contact Donna Tizzano at (216) 280-5514.

Very truly yours,


DGT:sc

Enclosure

cc: NRC Project Manager
NRC Resident Inspectors Office
NRC Document Control Desk (Docket No. 50-440)
NRC Region III

200025
9605200122 960430
PDR ADOCK 05000440
R PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

Cool
1/1

Perry Nuclear Power Plant

3IB00016001 APR 1996

1 1 05/13/96 OH006346

10 Center Rd.
Perry

44081 Lake

001 DISCHARGE FROM REGENERATE NEUTRALIZATION PITS

FORM

Perry-E240

D. G. Tizzano

	1 999	1 999	1 999	2 096	3 001
	CONDUIT FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDU TOT NF MG/L	OIL GR TOTAL MG/L
	50050	00401	00402	00530	00550
01	AH	AH	AH		
02	AH	AH	AH		
03	AH	AH	AH		
04	AH	AH	AH		
05	AH	AH	AH		
06	AH	AH	AH		
07	AH	AH	AH		
08	AH	AH	AH		
09	AH	AH	AH		
10	AH	AH	AH		
11	AH	AH	AH		
12	AH	AH	AH		
13	AH	AH	AH		
14	AH	AH	AH		
15	AH	AH	AH		
16	AH	AH	AH		
17	AH	AH	AH		
18	.019	7.1	7.0	13	AA
19	AH	AH	AH		
20	.021	7.5	7.0		
21	AH	AH	AH		
22	AH	AH	AH		
23	AH	AH	AH		
24	.017	8.2	8.1	12	AA
25	AH	AH	AH		
26	AH	AH	AH		
27	AH	AH	AH		
28	AH	AH	AH		
29	AH	AH	AH		
30	.059	8.4	7.9	16	AA
1					
	0.1160	31.200	30.000	41.000	AA
	0.0290	7.8000	7.5000	13.667	AA
	0.0590	8.4000	8.1000	16.000	AA
	0.0170	7.1000	7.0000	12.000	AA

AA-Below detectable limit (5 mg/l for O&G; 2.5 mg/l for residue)

AH-Sample not taken, no discharge, this date

REPORTER

5/14/96

R. J. Smith for D. C. Shelton

VP nuclear

Perry Nuclear Power Plant 31B00016002 APR 1996 1 1 05/13/96 OH006346

10 Center Rd. 002
Perry 44081 Lake

FORM

Perry-E240 D. G. Tizzano

1	1	2	2	2	2	3
999	999	096	096	096	096	001
CONDUIT	PH	RESIDU	PHOS-T	COPPER	IRON	OIL GR
FLOW		TOT NF	P-WET	CU,TOT	TOTAL	TOTAL
MGD	S.U.	MG/L	MG/L	UG/L	UG/L	MG/L
50050	00400	00530	00665	01042	01045	00550

31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61

0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

No Discharge Ocuurred During the Month

REPORTER

5/14/96

[Signature] for D.C. Shotton

VP Nuclear

Perry Nuclear Power Plant

3IB00016800 APR 1996

1 1 05/13/96 OH006346

10 Center Rd.
Perry

44081 Lake

800 INTAKE WATER TO PLANT FROM LAKE ERIE

FORM

Perry-E240

D. G. Tizzano

1
999WATER
TEMP.
F

00011

01
02
03
04
05
06
07
08
09
10
1
12
3
4
5
6
7
8
9
20
21
22
23
24
25
26
27
28
29
30
3133
32
33
32
33
33
32
32
32
32
32
33
34
34
34
33
36
40
42
44
47
50
49
49
48
49
50
50
50
50
501178.0
39.267
50.000
32.000

None

REPORTER

5/14/96

D. G. Tizzano for D.C. Shults

VP Nuclear

Perry Nuclear Power Plant

SIB00018004 APR 1998

1 1 05/13/98 OH000894

10 Center Rd.
Perry

44081 Lake

004 POINT REP OF DISCHARGE PRIOR TO TUNNEL ENTRY
FORM

Perry-E240

D. G. Tizzano

	1 999	1 999	1 999	2 096
	WATER TEMP. F	CONDUIT FLOW MGD	CHLORINE FREE A MG/L	PH S.U.
	00011	50050	50064	00400
01	37	104.0	.0	
02	36	61.5	.0	8.0
03	37	104.7	.0	
04	36	60.8	.0	
05	37	102.8	.0	8.0
06	36	60.4	.0	
07	36	56.3	.0	
08	38	82.4	.0	
09	40	80.7	.0	8.0
10	40	83.5	.0	
11	39	68.4	.0	
12	42	82.2	.0	8.0
13	43	87.3	.0	
14	42	84.0	.0	
15	43	83.1	.0	
16	37	53.1	.0	8.0
17	43	88.8	.0	
18	52	43.5	.0	
19	56	82.3	.0	8.0
20	58	86.5	.0	
21	62	81.9	.0	
22	61	86.1	.0	
23	62	91.8	.0	8.1
24	59	88.9	.0	
25	58	92.6	.0	
26	61	86.0	.0	8.2
27	62	88.8	.0	
28	60	51.0	.0	
29	61	55.1	.0	
30	60	81.9	.0	
31				

1434.0	2360.4	0.0000	64.300
47.800	78.680	0.0000	8.0375
62.000	104.70	0.0000	8.2000
36.000	43.500	0.0000	8.0000

None

REPORTER

5/14/98

[Signature]

Dr. D.C. Shelton

VP Nuclear