

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

May 6, 1985

TVA SQN TS 63

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with 10 CFR Part 50.90, we are enclosing 40 copies of a requested amendment to licenses DPR-77 and DPR-79, to change the technical specifications of Sequoyah Nuclear Plant units 1 and 2. The proposed changes are provided in enclosure 1. This proposed change requires the acoustic monitoring system to be considered one of the two required valve position indication channels for the pressurizer power operated relief valves and the safety valves. The justification for the proposed technical specification changes is provided in enclosure 2.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12.

This requested amendment has been evaluated pursuant to 10 CFR 50.92 and no significant hazards considerations are involved.

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Domer

J. A. Domer, Chief
Nuclear Licensing Branch

Sworn to and subscribed before me
this 6th day of May 1985

Paulette H. White

Notary Public
My Commission Expires 8-24-88

Enclosures
cc: See page 2

Acc'd
W/ check
\$150.00
26445

8505130364 850506
PDR ADCK 05000327
P PDR

An Equal Opportunity Employer

Director of Nuclear Reactor Regulation

May 6, 1985

cc: U.S. Nuclear Regulatory Commission (Enclosures)
Region II
Attn: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Michael H. Mobley, Director
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue North
Nashville, Tennessee 37203

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATIONS
SEQUOYAH NUCLEAR PLANT
(TVA SQN TS 63)

PROPOSED CHANGES
UNIT 1