

1901 Chouteau Avenue
Post Office Box 149
St. Louis, Missouri 63166
314-621-3222



May 22, 1996

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555-0001

Gentlemen:

ULNRC-03380

DOCKET NUMBER 50-483
CALLAWAY PLANT
AMENDMENT NUMBER 109
AND AMENDMENT NUMBER 110

This is to inform the commission of the implementation of Amendment No. 109 and Amendment No. 110 to the Callaway Facility Operating License No. NPF-30. Amendment No. 109 approved Technical Specification changes to TS 5.3.1 and 5.6.1.1 and Figure 3.9-1. These changes reflect a change in maximum initial fuel enrichment to 5.0 w/o U-235. Amendment 110 revised TS 5.3.1 to allow the use of Zirlo clad fuel. The changes have been issued to all controlled Technical Specification holders and became effective on May 15, 1996.

Very truly yours,

A handwritten signature in cursive script, appearing to read "A. C. Passwater".

A. C. Passwater
Manager - Licensing and Fuels

WBM/ml0

240109

9605280061 960522
PDR ADDCK 05000483
P PDR

Accol
1/0

cc: T. A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

L. Joe Callan
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Kristine M. Thomas (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E16
11555 Rockville Pike
Rockville, MD 20852-2738

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Don Woodlan
TU Electric
1601 Bryan Street
Dallas, TX 75201-3411

Pat Nugent
Pacific Gas & Electric
Regulatory Services
P.O. Box 56
Avila Beach, CA 93424