

Georgia Power Company  
Route 2, Box 299A  
Waynesboro, Georgia 30830  
Telephone 404 554-9961  
404 724-8114

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011



**Vogtle Project**

May 9, 1985

Director of Nuclear Reactor Regulation  
Attention: Ms. Elinor G. Adensam, Chief  
Licensing Branch #4  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

File: X7BC35  
Log: GN-604

REF: BAILEY TO DENTON, GN-598, DATED 5/6/85

NRC DOCKET NUMBERS 50-424 AND 50-425  
CONSTRUCTION PERMIT NUMBERS CPPR-108 AND CPPR-109  
VOGTLE ELECTRIC GENERATING PLANT - UNITS 1 AND 2  
REQUEST FOR ADDITIONAL INFORMATION: DSER OPEN ITEM 89

Dear Mr. Denton:

The referenced letter in its Enclosure B contained a revision to Q420.41 addressing the subject open item. The insert to Q420.41 should be revised to read:

"The reset/override design of the radiation monitor and differential pressure input to the fuel handling building isolation will be revised to allow an individual monitor channel to be reset/overridden by the operator. The final design will be such that overriding a spurious channel will not affect the other radiation monitor or differential pressure channels. The FSAR will be revised to reflect these changes when the design has been completed."

If your staff requires any additional information, please do not hesitate to contact me.

Sincerely,

J. A. Bailey  
Project Licensing Manager

JAB/sm

8505140389 850509  
PDR ADDOCK 05000424  
E PDR

3001  
1/0

Director of Nuclear Reactor Regulation  
May 9, 1985  
Page 2

File: X7BC35  
Log: GN-602

xc: D. O. Foster  
R. A. Thomas  
J. E. Joiner, Esquire  
B. W. Churchill, Esquire  
M. A. Miller  
B. Jones, Esquire  
L. T. Gucwa  
G. Bockhold, Jr.  
T. Johnson  
D. C. Teper  
L. Fowler  
Vogtle Project File

0205m