



NIAGARA MOHAWK

GENERATION
BUSINESS GROUP

NINE MILE POINT NUCLEAR STATION/LAKE ROAD, P.O. BOX 63, LYCOMING, NEW YORK 13093/TELEPHONE (315) 349-7263
FAX (315) 349-4753

CARL D. TERRY
Vice President
Nuclear Engineering

August 28, 1996
NMP2L 1658

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Subject: Relief Request

Gentlemen:

This letter provides supplemental information to Relief Request HCS-PTRR-1, Rev. 0 which was submitted in a letter dated March 18, 1996 (NMP2L 1618) and revised by another letter dated August 8, 1996 (NMP2L 1650). The supplemental information provided by this letter is in response to matters discussed with the Staff during telephone conferences on August 27, 1996.

In addition to the proposed alternate examination of Relief Request HCS-PTRR-1, the Class 2 components of the Hydrogen Recombiner System (HCS) will be subject to an inspection under pressure at least every 40 months. The inspection will consist of a walkdown of the accessible portions of the HCS outside of primary containment to determine by visual and audible observation the structural integrity and condition of the system. Accessible portions of HCS are defined as those portions of the system which do not require the erection of scaffolding, either require the removal of insulation nor constitute a hardship in maintaining radiological doses as low as reasonably achievable (ALARA) to perform an inspection.

If additional information is needed with regards to this relief request, please contact Kenneth Korcz (315-349-7222) of our Licensing staff.

Very truly yours,

C. D. Terry
Vice President - Nuclear Engineering

090013

A047 1/0

9609110114 960828
PDR ADOCK 05000410
G PDR

Page 2

CDT/KWK/lmc

xc: Regional Administrator, Region I
Mr. B. S. Norris, Senior Resident Inspector
Mr. D. S. Hood, Senior Project Manager, NRR
Records Management