



RICHARD P. CROUSE
Vice President
Nuclear
(419) 249-5221

Docket No. 50-346
License No. NPF-3
Serial No. 1135
April 22, 1985

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz
Operating Reactor Branch No. 4
Division of Licensing
United States Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes in Table 3.6-2:

1. The deletion of the isolation time for the High Pressure Injection (HPI) and Containment Spray (CS) Lines,
2. The deletion of the redundant listing for DH87 and DH88 and
3. Correct the valve number identification for the Core Flood Tank Nitrogen Fill, Sample and Vent Lines.

The attachment identifies the proposed change, Safety Evaluation and Significant Hazard Consideration. Item 1 concerns the deletion of the isolation time for the HPI and CS lines because they are required to be open to perform their safety function. Item 2 and 3 are to correct typographical errors in the Technical Specifications.


Toledo Edison request that the above amendment request be issued by December 1985.

9505150359 850422
PDR ADDCK 05000346
P PDR

*Rec'd w/attach #150.00
#433812*

Enclosed is a check for \$150 as required by 10CFR170.12(C) for license application.

Very truly yours,

A handwritten signature in cursive script, appearing to read "H. H. Brown".

RPC:GAB

Attachment

cc: DB-1 NRC Resident Inspector
State of Ohio