

**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

JUN 6 1996

Docket No. 50-443
NYN-96038


United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Seabrook Station
Monthly Operating Report

Enclosed please find Monthly Operating Report 96-05. This report addresses the operating and shutdown experience relating to Seabrook Station Unit 1 for the month of May, 1996 and is submitted in accordance with the requirements of Seabrook Station Technical Specification 6.8.1.5.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.



William A. DiPrizio
Station Director

cc: T. T. Martin, Region I Administrator
A.W. De Agazio, NRC Project Manager, Seabrook Station
J.B. Macdonald, Senior Resident Inspector, Seabrook Station

9606110308 960531
PDR ADOCK 05000443
R PDR

110034

JE24

OPERATING DATA REPORT

DOCKET NO.	50-443
UNIT	Seabrook 1
DATE	June 4, 1996
COMPLETED BY	P.E. Nardone
TELEPHONE	603/474-9521 Ext. 4074

OPERATING STATUS				
1.	Unit Name:	Seabrook Station Unit 1		
2.	Reporting Period:	MAY, 1996		
3.	Licensed Thermal Power (MWt):	3411		
4.	Nameplate Rating (Gross MWe):	1197		
5.	Design Electrical Rating (Net MWe):	1148		
6.	Maximum Dependable Capacity (Gross MWe):	1204		
7.	Maximum Dependable Capacity (Net MWe):	1158		
8.	If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report, Give Reasons:	Not Applicable		
9.	Power Level To Which Restricted, If Any (Net MWe):	None		
10.	Reasons For Restrictions, If Any:	Not Applicable		
		This Month	Yr-to-Date	Cumulative
11.	Hours in Reporting Period	744.0	3647.0	84360.0
12.	Number of Hours Reactor Was Critical	744.0	3607.9	44537.9
13.	Reactor Reserve Shutdown Hours	0.0	0.0	953.3
14.	Hours Generator On-Line	744.0	3553.7	42163.8
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	2537602	11476251	138568524
17.	Gross Elec. Energy Generated (MWH)	899603	4038518	48183808
18.	Net Electrical Energy Generated (MWH)	866353	3877892	46285648
*19.	Unit Service Factor	100.0	97.4	80.5
*20.	Unit Availability Factor	100.0	97.4	80.5
*21.	Unit Capacity Factor (Using MDC Net)	100.6	91.8	77.6
*22.	Unit Capacity Factor (Using DER Net)	101.4	92.6	77.7
*23.	Unit Forced Outage Rate	0.0	2.6	6.1
24.	Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	None Scheduled		
25.	If Shut Down At End Of Report Period, Estimated Date of Startup:	Not Applicable		

*NOTE: "Cumulative" values based on total hours starting 8/19/90, date Regular Full Power Operation began. Increased MDC values (Items 6 & 7) starting 12/01/95.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-443

UNIT Seabrook 1

DATE June 4, 1996

COMPLETED BY P.E. Nardone

TELEPHONE 603/474-9521
Ext. 4074

MONTH: MAY, 1996

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1164
2	1165
3	1164
4	1155
5	1165
6	1164
7	1165
8	1165
9	1164
10	1164
11	1165
12	1164
13	1164
14	1164
15	1164
16	1164

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	1164
18	1164
19	1165
20	1165
21	1165
22	1165
23	1165
24	1164
25	1165
26	1165
27	1165
28	1165
29	1165
30	1164
31	1164

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-443
UNIT Seabrook 1
DATE June 4, 1996
COMPLETED BY P.E. Nardone
TELEPHONE 603/474-9521
Ext. 4074

REPORT MONTH MAY, 1996

NO.	DATE	TYPE ¹	DURATION (HOURS)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT #	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE Page 1 of 1
							No entries for this month
¹ F: Forced S: Scheduled		² Reason: A - Equipment Failure (Explain) B - Maintenance or Test C - Refueling D - Regulatory Restriction E - Operator Training & License Examination F - Administrative G - Operational Error (Explain) H - Other (Explain)			³ Method: 1 - Manual 2 - Manual Scram 3 - Automatic Scram 4 - Continued from previous month 5 - Power Reduction (Duration = 0) 9 - Other (Explain)		

REFUELING INFORMATION REQUEST

DOCKET NO.	50-443
UNIT	Seabrook 1
DATE	June 4, 1996
COMPLETED BY	P.E. Nardone
TELEPHONE	603/474-9521 Ext. 4074

1. Name of Facility: Seabrook Unit 1
2. Scheduled date for next refueling shutdown: Refueling Outage 5, 06/28/97 [changed from 06/07/97]
3. Scheduled date for restart following refueling: Refueling Outage 5, 08/04/97 [38 days: based on RO 04]
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
N/A
5. Schedule date(s) for submitting licensing action and supporting information:
N/A
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
N/A
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
(a) In Core: 193 (b) 288
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present licensed capacity: 1236
No increase in storage capacity requested or planned.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:
Licensed capacity of 1236 fuel assemblies based on two annual and twelve eighteen-month refuelings with full core offload capability.
The current licensed capacity is adequate until at least the year 2010.