

Duke Power Company
P.O. Box 1006
Charlotte, NC 28201-1006

M. S. TUCKMAN
Senior Vice President
Nuclear Generation
(704)382-2200 Office
(704)382-4360 Fax



DUKE POWER

September 1, 1996

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

Subject: McGuire Nuclear Station
Docket Numbers 50-369 and -370
Proposed Technical Specification Revision to
Reduce Required Ice Condenser Ice Weight

By letter dated September 1, 1995, Duke Power proposed Technical Specification (TS) changes to reduce the mass of ice required to be present in the ice condenser at McGuire Nuclear Station. The analysis which supported this reduction assumed a loss-of-coolant accident coincident with a loss of off-site power. The turbine-driven auxiliary feedwater pump (TDAFWP) was assumed to start, and to fill the steam generators. However, an interlock has been identified which would block the start of the TDAFWP when a safety injection signal is received within 8.5 seconds of a loss of power.

Therefore, the proposed TS change is hereby withdrawn. A modification to restore the ability of the TDAFWP to start under the assumed conditions will be implemented, and a new proposed TS change will be submitted when ready.

If any additional information is required, please call Scott Gewehr at (704) 382-7581.

A handwritten signature of M. S. Tuckman in dark ink.

M. S. Tuckman

cc: Mr. V. Nerses, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-14 H25
Washington, D. C. 20555

9609120117 960901
PDR ADOCK 05000369
P PDR

Adol
1/0

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
Page 2

Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
101 Marietta Street, NW - Suite 2900
Atlanta, Georgia 30323

S. M. Shaeffer
Senior Resident Inspector
McGuire Nuclear Station

Dayne Brown, Director
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611-7687