

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y N M P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 7 8 9 14 15 25 26 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 2 0 7 0 5 0 0 8 3 8 0 9 0 9 8 3 9
 7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While reviewing Environmental Radiation fish analysis sample data, it was determined
 0 3 that the lower limit of detection sensitivity (LLD) was not met for several radio-
 0 4 nuclides during analysis of May fish samples (Environmental Tech. Spec. Table 3.2-1
 0 5 applies). This has no Environmental concerns because this is a matter of specific
 0 6 testing sensitivity and results do fall within applicable Regulatory Guide 4.8 Speci-
 0 7 fications. LERs 81-10, 81-51, 82-07, 82-12 and 83-03 reported similar occurrences.

0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 Z Z 11 X 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16
 7 8 9 10 11 12 13 18 19 20
 17 LER/RO REPORT NUMBER EVENT YEAR 8 3 0 2 5 0 4 L 0
 21 22 23 24 26 27 28 29 30 31 32
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 X 18 X 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 X 9 9 9 9
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The station Tech. Specs. specify radiological fish analysis LLD to be 80 pci/kg dry
 1 1 weight. When laboratory test data is converted from wet weight units to dry weight
 1 2 units, higher LLD values resulted. Radiological Effluent Technical Specifications
 1 3 (RETS) are in the process of being submitted to update this parameter to the current
 1 4 Regulatory Guide Values; recurrence of this problem is expected until the RETS proposal
 7 8 9 is approved.

1 5 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
 G 28 0 0 0 29 NA B 31 Supervisory Review
 7 8 9 10 11 44 45 46

1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
 Z 33 Z 34 NA
 7 8 9 10 11 44 45

1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
 0 0 0 37 Z 38 NA
 7 8 9 10 11 12 13

1 8 PERSONNEL INJURIES NUMBER DESCRIPTION 41
 0 0 0 40 NA
 7 8 9 10 11 12

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
 Z 42
 7 8 9 10

2 0 PUBLICITY ISSUED DESCRIPTION 45
 N 44
 7 8 9 10

NAME OF PREPARER

D.T. Kesel

PHONE:

(315)349-2611

NRC USE ONLY

68 69 80

September 23, 1983

Dr. Thomas E. Murley
Regional Administrator
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

RE: Docket No. 50-220
LER 83-25

Dear Dr. Murley,

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specifications, we hereby submit the following Licensee Event Report:

83-25 in accordance with Section 4.6.2a "Non-routine Environmental Operating Reports" where a report shall be submitted in the event that (b) a report level or specification is reached as specified in Section 3, "Environmental Surveillance".

This report was completed in the format designated in NUREG-0161, dated July 1977.

Sincerely,

C. V. Mangan

C. V. Mangan
Vice President

Nuclear Engineering & Licensing

TEL/jm

Attachments (3 copies)

cc: Director, Office of I&E (30 copies)

Director, Office of MIPC (3 copies)

CORRECTED
LER #
~~FOR 83-25~~