



LWP-96-064

September 11, 1996.

U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 96-013, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(B). The licensee shall report any operation or condition prohibited by the Plant's Technical Specifications.

The following commitments are being made by this letter:

1. Mechanical Maintenance preventive maintenance surveillances QCMPM 4400-11, RHRSW Bay Inspection, and QCMPM 4400-12, CW Intake Bay Inspection, will be performed to clean the zebra mussels from the walls of the bays in the 13 week system window schedule. During performance of the surveillances, the fire pump suction strainers and RHRSW bay will again be inspected for zebra mussel fouling. This will serve as the interim inspection until a more definite inspection frequency is established. Based on the known growth rate of zebra mussels, this inspection will be adequate in assuring the strainers will remain free of debris. This inspection will take place in the fourth quarter of this year which is at the end of the zebra mussel spawning season.
2. A new station task force will be formed to study the zebra mussel problem and determine potential solutions for the individual systems and for the station.
3. Establish an acceptable frequency and method for inspecting the fire pump suction strainers and RHRSW bays for zebra mussel fouling.

STMGR\06496.LWP

9609190005 960911
PDR ADOCK 05000254
S PDR
C UN

180600


1/1
Te22

LWP-96-064
September 11, 1996
page 2

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3102.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce
Station Manager

LWP/NC/as

Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. Miller, Senior Resident Inspector, Quad Cities
R. J. Singer, Mid American Energy Company
D. C. Tubbs, Mid American Energy Company
P. Piet, Licensing, ComEd
F. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center