

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 7/16/96
Laboratory: Electro Analytical

Date of Sample: 7/2 to 7/3/96
Sample Location: Sewage Pump Station


Time of sample: 09:15
Name of Sampler: Beckler

Laboratory Address: 7118 Industrial Park Blvd.
Mentor, OH 44060

Date of Analysis: 7/3 to 7/9/96
Flow: 33,000 gpd

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	7/8/96	900 mg/L
BOD	Composite	405.1	7/8/96	480 mg/L
TSS	Composite	160.2	7/9/96	150 mg/L
Silver	Composite	272.1	7/9/96	<.011 mg/L
Mercury	Composite	245.1	7/9/96	<.50 ug/L
pH	Grab	150.1	7/3/96	6.9 s.u.
Oil/Grease Gravimetric	Grab	413.1	7/9/96	12 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

 9/19/96 Sr. Vice President - Nuclear
Signature Date Title

9609190310 960913
PDR ADOCK 05000440
R PDR