

Detroit
Edison

Douglas R. Gipson
Senior Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5249

10CFR50.73(a)

September 13, 1996
NRC-96-0061

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

- References: 1) Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43
- 2) Detroit Edison letter to NRC,
Licensee Event Report (LER) No. 94-003-03,
NRC-95-0015, dated March 17, 1995
- 3) Detroit Edison letter to NRC,
Detroit Edison Response to
Generic Letter 96-01, NRC-96-0045,
dated April 18, 1996

Subject: Licensee Event Report (LER) No. 94-003-04

Please find enclosed LER No. 94-003-04, dated September 13, 1996. A copy of this LER is also being sent to the Regional Administrator, USNRC Region III. This LER addresses inadequate logic system functional testing.

LER 94-003-03 (Reference 2) contained commitments which have been superseded by Detroit Edison's Response to Generic Letter 96-01 (Reference 3). As a result, the following commitments made in Reference 2 are being eliminated:

000004

9609200111 960913
PDR ADOCK 05000341
S PDR

JE22%


1. Affected procedures will be modified to clearly indicate Technical Specification compliance steps.
2. The surveillance tracking system will be improved for component level tracking of Logic System Functional testing.
3. Specific individuals will be trained on Technical Specification (TS) compliance to ensure TS compliance is maintained.

The lessons learned from this LER were presented to Operations, I&C, Maintenance and Technical Engineering. Continued compliance with the Technical Specifications will be ensured through actions taken with respect to Generic Letter 96-01.

In Reference 3, Detroit Edison committed to evaluating administrative controls associated with plant design modifications and procedure revisions to ensure that the quality of procedures, including test overlap, is maintained. No new commitments are included in this letter.

If you have any questions, please contact Ron Wittschen, Compliance Engineer, at (313) 586-1267.

Sincerely,



cc: A. B. Beach
M. J. Jordan
A. J. Kugler
A. Vogel
M. V. Yudas, Jr.
Region III
Wayne County Emergency
Management Division