



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

CHRIS H. POINDEXTER
VICE PRESIDENT
ENGINEERING AND CONSTRUCTION

May 10, 1985

U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

ATTENTION: Mr. James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Request for Amendment

Gentlemen:

The Baltimore Gas and Electric Company hereby requests an Amendment to its Operating License Nos. DPR-53 and DPR-69 for Calvert Cliffs Unit Nos. 1 & 2, respectively, with the submittal of the proposed change to the Technical Specifications.

PROPOSED CHANGE (BG&E FCR 85-27)

Remove existing page 6-5 of the Unit Nos. 1 and 2 Technical Specifications and replace with attached, marked-up pages.

DISCUSSION

This proposed change to the Technical Specifications addresses the requirements for training and qualifications of the Shift Technical Advisor (STA). The current administrative section of the Calvert Cliffs Technical Specifications requires an STA to hold a current Senior Operator's License (SOL) and a bachelor's degree in an engineering or scientific discipline or equivalent. Currently, Calvert Cliffs' approved STA program utilizes SOL holders which have undergone an extensive upgrade training program to meet the STA requirements. Due to personnel attrition and the NRC position that all future STA's have a bachelor's degree in an engineering or scientific discipline or equivalent, BG&E is now requesting a change to the Technical Specifications to obtain additional flexibility in staffing the STA position, while still meeting the NRC position.

w/check 00
\$150
13397572
8505200048 850510
PDR ADOCK 05000317
PDR

Add:
A001
3/40

	Ltr	Encl
NRR/DHFS/LQB	1	1
NRR/DHFS/OLB	2	2

Mr. James R. Miller
May 10, 1985
Page 2

In addition to those STA's who are currently approved by the NRC to fulfill that position, this proposed change would permit an individual with a bachelor's degree in an engineering or scientific discipline or equivalent who holds a current Operator's License to fill the STA position. The current Technical Specification requirement for the STA to hold an SOL was a requirement necessitated by the previously utilized STA training program, which utilized non-degreed SOL holders. This would no longer be necessary so long as the bachelor's degree in an engineering or scientific discipline or equivalent is satisfied.

The proposed change meets all current existing NRC criteria.

DETERMINATION OF SIGNIFICANT HAZARDS CONSIDERATIONS

This proposed change has been evaluated against the standards in 10 CFR 50.92 and has been determined to involve no significant hazards considerations, in that operation of the facility in accordance with the proposed amendment would not:

- (i) Involve any increase in the probability or consequences of any accident previously evaluated in the Updated Final Safety Analysis Report.

This proposed change simply provides flexibility in meeting an administrative requirement, and does not involve any modifications or change in plant operating philosophy.

- (ii) Create the possibility of a new or different type of accident from any accident previously evaluated.

The proposed administrative change does not create the possibility of any new accidents different from any previously evaluated.

- (iii) Involve any significant reduction in the margin of safety.

The proposed change still would meet the current NRC position on training and qualification of STA's. In addition, shift staffing requirements would still be met with the change.

SAFETY COMMITTEE REVIEW

These proposed changes to the Technical Specifications and our determination of significant hazards have been reviewed by our Plant Operations and Off-Site Safety Review Committees, and they have concluded that implementation of these changes will not result in an undue risk to the health and safety of the public.

Mr. James R. Miller
May 10, 1985
Page 3

FEE DETERMINATION

Pursuant to 10 CFR 170.21, we are including BG&E Check No. B397572 in the amount of \$150.00 to the NRC to cover the application fee for this request.

Very truly yours,

CH Poindexter

STATE OF MARYLAND :

CITY OF BALTIMORE :

TO WIT:

Chris H. Poindexter, being duly sworn states that he is Vice President of the Baltimore Gas and Electric Company, a corporation of the State of Maryland; that he provides the foregoing response for the purposes therein set forth; that the statements made are true and correct to the best of his knowledge, information, and belief; and that he was authorized to provide the response on behalf of said Corporation.

WITNESS my Hand and Notarial Seal:

Minnie L. Robinson
Notary Public

My Commission Expires:

July 4, 1986
Date

AEL/LES/sjb

cc: D. A. Brune, Esquire
G. F. Trowbridge, Esquire
D. H. Jaffe, NRC
T. Foley, NRC
T. Magette, DNR