



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

September 13, 1996
6730-96-2275

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Secondary Containment Capability Test Results

The Oyster Creek Nuclear Generating Station Technical Specifications require:

- 4.5.K.2 "(Secondary Containment) tests shall be performed at least once per operating cycle..."
- 4.5.K.3 "A secondary containment capability test shall be conducted at each refueling outage prior to refueling."
- 4.5.K.4 "The results of the secondary containment capability tests shall be in the subject of a summary technical report..."

Attachment I to this letter provides the documentation of the completion of requirements 4.5.K.2 and 4.5.K.3 by docketing the report required in 4.5.K.4. If any additional information or assistance is required, please contact Mr. John Rogers of my staff at 609.971.4893.

Very truly yours,

Michael B. Roche
Vice President and Director
Oyster Creek

9609230128 960913
PDR ADOCK 05000219
P PDR

MBR/JJR

cc: Oyster Creek NRC Project Manager
Administrator, Region I
Senior Resident Inspector

230046

ADD 1/1

Attachment I

Summary Technical Report Secondary Containment Capability Test

Oyster Creek Nuclear Generating Station
Operating Cycle 15; Prior to Refueling Outage 16R
Date Performed: August 27, 1996

1. Wind Speed

Test Prerequisite:

"...calm wind..."

Observed:

7.7 mph

2. Standby Gas Treatment System Flow Rate

Test Requirements:

< 4000 cfm

Test Results:

2618 cfm

3. Reactor Building Differential Pressure

Test Requirements:

Both Railroad Airlock Doors Closed

≥ 0.25 inches W.G.

Test Results:

0.457 inches W.G.

Outer Railroad Airlock Door Open

≥ 0.250 inches W.G.

0.454 inches W.G.

Inner Railroad Airlock Door Open

≥ 0.25 inches W.G.

0.407 inches W.G.