

A-122
50-348/364-CIVP
5/18/92

058415



LIMITORQUE CORPORATION

5114 Woodall Road • P. O. Box 11318 • Lynchburg, Virginia 24506

Telephone 804-528-4400 • Telex 32-9448

92 JUN -2 P12:09

APCo Exhibit 122

OFFICE OF SECRETARY
DOCUMENTATION & SERVICE
BRANCH

October 13, 1980

NUREG 0588 DOCUMENTATION

Bechtel Power Corporation
15740 Shady Grove Road
Gaithersburg, MD 20760

Attention: Mr. A.A. Vizzi - Project Engineer

Gentlemen:

Reference: Qualification Information
Joseph M. Farley Nuclear Plant
Bechtel Job 7597-20
Alabama Power Co. P/O 66420
Limitorque O/N 3F1782

Regarding your request for qualification information, at the time Limitorque received the orders for some of the units supplied, no accepted IEEE qualification standard existed and therefore the units were not manufactured in accordance with any specific qualification requirement.

1. A review of our records show that our Qualification Report 600455 can be applied to the actuators supplied on the following orders.

<u>Limitorque O/N</u>	<u>Actuator S/N</u>	<u>MOV No.</u>
<u>UNIT 1</u>		
360278A	162456-58	3232A-C
*364499A	167055	3131
365513A	164582-84	3350A-C
376540A	195174-75	3536
378148A	195176-79	3528C, 3835A, and 3660
379035A	209324-25	3530
380365A	202202-03	3528B
381730A	206701-772	3528A, 3835B, and 3318B
387496A	222192-93	3822A-B
390553A	232405-08	3528D

9207310150 920518
PDR ADOCK 05000348
G PDR

10/28 15:36

7207227

#02

A.A. Vizzi - Project Engineer
October 13, 1980

0058416

<u>Limitorque O/N</u>	<u>Actuator S/N</u>	<u>MOV No.</u>
<u>UNIT 2</u>		
*358999A	192802-09	3441A-D
360282A	162619-21	3233A-C
*364499A	167055-	3131
365512A	164579-81	3350A-C
376540A	195174-75	3536
378148B	195730	3528D
379035A	209324-25	3530
380365A	202302-03	3660 - C.2.4
381730A	206701-12	3528A-C, 3835A-B, and 3318B
387495A	221630-31	3872A-B
*3CS243A	284499	3046

C.2.4

* - Our records indicate the actuators supplied on these orders include motors with thermal contacts. We have not conducted any environmental tests on actuators including motors with thermal contacts and would recommend that they be removed from the control circuitry.

2. Our records indicate that our Qualification Report 80003 can apply to the actuators supplied on the following orders.

UNIT 1

**257806B	151262-65	8112
358990B	169292-95	3441A-D

UNIT 2

**357806B	151262-65	8112
-----------	-----------	------

** - Our records indicate that two of the actuators supplied on this order were converted to containment units (Qualification Report 600456), however, our records do not indicate the serial number of the units so revised.

3. Our records further indicate that our Qualification Report 500198 plus addendum 1 can be applied to the actuators supplied on the following orders. Report 500376A can be used to support the capability of the actuators only (not including motor) to withstand irradiation only. It would be necessary for you to provide us with the motor ID numbers to permit us to attempt to expand this statement to include the motor.

A.A. Vizzi - Project Engineer
October 13, 1980

0058417

<u>UNIT</u>	<u>Limitorque O/N</u>	<u>Actuator S/N</u>	<u>MOV No.</u>
<u>UNIT 1</u>			
	357806AB	153642-47	8808A-C 4.2.9
<u>UNIT 2</u>			
	357806AB	153642-47	8808A-C

4. Our records also indicate that our Report #23271 can be applied to the actuators supplied on our O/N 356995B (S/N 175414) MOV 3046.

Very truly yours,

LIMTORQUE CORPORATION

J.B. Drab

J.B. Drab
Special Projects Engineer

wcd