

S-71  
50-348/364-CIVP  
5/18/92

STAFF EXH. #71

E. Q. Question Number 026

USNRC

E. Q. INSPECTION TRACKING SHEET  
FARLEY N' CLEAR PLANT

'92 JUN -2 A11:03

NRC INSPECTOR: D. BROSSAU

DATE: 11/17/87 SECRETARY  
DUCKETT & SERVICE  
BRANCH

EQ COMPONENT: STATES TERMINAL BLOCKS

EQ FILE NUMBER: 34

NRC QUESTION:

PERFORMANCE: WHAT IS THE BASIS FOR 10% IR ACCEPTANCE  
CRITERIA IN THE WCAP. WYLE ACCEPTANCE  
WAS FOR OPEN OR CLOSED CIRCUITS ONLY.

RESPONSE ASSIGNED TO: ~~J. SANDERSON~~ J.E. Love

DATE: 11/17/87

APCO RESPONSE: R

DATE: 11/17/87

The response to this question is provided in the  
attached APCO E.Q. ACTION Item # 067 and 018 Responses.