

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877-7122

C. K. McCoy
Vice President, Nuclear
Vogtle Project



August 28, 1992

ELV-03955
002132

Docket Nos. 50-424
50-425

TAC M82724
M82725

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT
LICENSE CHANGE POWER UPDATING

By letter ELV-03375 dated February 28, 1992, Georgia Power Company requested amendments to Operating Licenses NPF-68 and NPF-81 for the Vogtle Electric Generating Plant Units 1 and 2. The proposed license amendments would change the definition of rated thermal power from 3411 Mwt to 3565 Mwt. In addition to the Technical Specifications changes included with letter ELV-03375, the value of the maximum power level in section C(1) of licenses NPF-68 and NPF-81 will change from 3411 Mwt to 3565 Mwt. Attached to this letter are marked up pages from the two licenses that show the necessary changes.

Sincerely,

C. K. McCoy
C. K. McCoy

CKM/HWM/gmb

Attachment

xc: Georgia Power Company
Mr. W. B. Shipman
Mr. M. Sheibani
NORMS

U. S. Nuclear Regulatory Commission
Mr. S. D. Ebnetter, Regional Administrator
Mr. D. S. Hood, Licensing Project Manager, NRR
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

9209020113 920828
PDR ADOCK 05000424
P PDR

A001
11

10 CFR Part 50, to possess the facility at the designated location in Burke County, Georgia, in accordance with the procedures and limitations set forth in this license;

- (3) GPC, pursuant to the Act and 10 CFR Part 70, to receive, possess, and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components;
- (6) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of Vogtle Electric Generating Plant, Units 1 and 2.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified or incorporated below.

(1) Maximum Power Level

GPC is authorized to operate the facility at reactor core power levels not in excess of ³⁵⁶⁵~~3411~~ megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 31, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. GPC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) GPC, pursuant to the Act and 10 CFR Part 70, to receive, possess, and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components;
- (6) GPC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility authorized herein.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below.

(1) Maximum Power Level

GPC is authorized to operate the facility at reactor core power levels not in excess of ³⁵⁶⁵~~3411~~ megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 52, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. GPC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Initial Startup Test Program (Section 14, SER)*

Any changes to the Initial Test Program described in Section 14 of the FSAR made in accordance with the provisions of 10 CFR 50.59 shall be reported in accordance with 50.59(b) within one month of such change.

* The parenthetical notation following the title of many license conditions denotes the section of the Safety Evaluation Report and/or its supplements wherein the license condition is discussed.