

UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of]	
]	
Niagara Mohawk Power Corporation]	Docket No. 50-410
]	
(Nine Mile Point Nuclear Station Unit No. 2)]	

APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that Tables 3.3.7.2-1 and 4.3.7.2-1 of the Technical Specifications as set forth in Appendix A to that License be amended. The proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed changes to the Technical Specifications are set forth in Attachment A to this application. The proposed amendment would relocate a seismic instrument, a Triaxial Peak Accelerograph, from a reactor recirculation pump motor to the reactor pedestal. The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and an analysis which demonstrates that the proposed changes involve no significant hazards consideration pursuant to 10 CFR 50.92 are included as Attachment B.

Wherefore, the Applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By B. Ralph Sylvia
B. Ralph Sylvia
Exec. Vice President-Nuclear

Subscribed and Sworn to before me
on this 17th day of Sept 1992.

James M. Minnich
NOTARY PUBLIC

JAMES M. MINNICH
Notary Public in the State of New York
Qualified in Onondaga County No. 4786555
My Commission Expires April 28, 1993

9209240006 920917
PDR ADDCK 05000410
P PDR