

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

September 21, 1992

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 92-609
NAPS/JHL/EJW Rev. 2
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
SETTLEMENT MONITORING PROCEDURE REVISIONS

Enclosed is a summary of changes to North Anna Power Station Settlement Monitoring Procedures 1-PT-112 and 1-PT-115. This information is being transmitted for your review pursuant to Atomic Safety and Licensing Appeal Board Decision ALAB-573.

If you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager
Nuclear Licensing and Programs

Enclosure

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. M. S. Lesser
NRC Senior Resident Inspector
North Anna Power Station

ATTACHMENT 1

SUMMARY OF SETTLEMENT MONITORING PROGRAM PROCEDURE REVISIONS

The following items were revised in procedures 1-PT-112 and 1-PT-115:

1. Settlement monitoring points 114, 115, 116 and 117 were replaced with corresponding points 314, 315, 316 and 317 due to the implementation of Design Change 92-252, Installation of Missile Shields Over Fuel Oil Lines in the Emergency Diesel Generator (EDG) Compartment (Refer to LER 50-338, 339/92-010-00). Settlement monitoring points 114, 115, 116 and 117 still exist and could be used, however, the new settlement monitoring points are more readily accessible (i.e., embeded in E-line wall in the Unit 2 alleyway). Baseline elevations were established for the new points and are documented in calculation CE-0957 as required by Technical Specification Bases section 3/4.7.12, Settlement of Class 1 Structures. These settlement monitoring points were also replaced in accordance with the NRC's recommendations contained in the Safety Evaluation Report, Settlement of Class 1 Structures Technical Specification (TS) 3/4.7.12 - North Anna Power Station Units No. 1 and No. 2 (NA-1 & 2) (Tac Nos. M67985 and M67986), dated March 31, 1992.
2. Editorial changes to comply with new Administrative Procedure for procedure format.

In addition, 1-PT-115 was revised to enhance the accuracy of the survey by performing rod comparisons.

Current procedures comply with Technical Specification requirements.