

In the Matter of the Facility Operating License)
of)
PUBLIC SERVICE COMPANY OF COLORADO)

OF THE
PUBLIC SERVICE COMPANY OF COLORADO
FOR THE
FORT ST. VRAIN NUCLEAR GENERATING STATION

By A. Clegg Crawford
Vice President
Electric Production

9210010097 920925
PDR ADDCK 05000267
P PDR

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)
of)
Public Service Company of Colorado) Docket No. 50-267
Fort St. Vrain Unit No. 1)

AFFIDAVIT

A. Clegg Crawford, being first duly sworn, deposes and says: That he is Vice President, Electric Production, of Public Service Company of Colorado, the Licensee herein, that he has read the foregoing Application for Amendment to Appendix A of the Facility Operating License and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

A. Clegg Crawford
A. Clegg Crawford
Vice President
Electric Production

STATE OF Colorado)
COUNTY OF Denver)

Subscribe and sworn to before me, a Notary Public on this
25th day of September, 1992.

Audrey L. Kitzman
Notary Public

My commission expires November 29, 1995

ATTACHMENT 1

TO P-92283

SUMMARY OF PROPOSED CHANGES

SUMMARY OF PROPOSED CHANGES

<u>Page;Section</u>	<u>Description of Change</u>
Page 2-3; Section 2.12	Delete Section 2.12, Definition of Radiation Safety, in its entirety. Also, Section 2.13 is re-numbered as Section 2.12.
Page 3.1-1; LC 3.1	Revise Applicability section to delete "shielding water". Applicability will now read: "Whenever ACTIVATED GRAPHITE BLOCKS have been removed from the PCRV and remain inside the Reactor Building*."
Page 3.2-1; LC 3.2	Revise Applicability section to delete "shielding water". Applicability will now read: "Whenever ACTIVATED GRAPHITE BLOCKS have been removed from the PCRV and remain inside the Reactor Building."
Section 5, throughout	Replace "RADIATION SAFETY" with "nuclear safety."
Page 5.0-2; AC 5.3.4.c	Replace "The following items, that have been evaluated to involve an unreviewed safety question..." with "The following items which involve an unreviewed safety question..."
Page 5.0-9; AC 5.5.2	Revise Semiannual Radioactive Effluent Release Report to Annual Radioactive Effluent Release Report. Revise description to read: "The Annual Radioactive Release Report covering the activities during the previous 12 months shall be submitted within 90 days after January of each year."

SUMMARY OF PROPOSED CHANGES

Page;Section

Description of Change

Page 5.0-12; AC 5.8.2

In the second paragraph, replace the requirement that high radiation areas (> 1000 mR/hr) be "roped off" with a requirement that they be "barricaded." All other requirements (e.g., conspicuous posting and a flashing light) remain unchanged.