



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-8881

U-602049
R50-92(09-28)-LP
1N.150
EP640

September 28, 1992

10CFR50.47

Docket No. 50-461


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUBJECT: CLINTON POWER STATION
NOTIFICATION OF UNUSUAL EVENT

Dear Sir:

Please find attached a summary report of the "Notification of Unusual Event (NOUE)" which occurred at Clinton Power Station on September 22, 1992. This summary report is submitted pursuant to Appendix 1 of NUREG-0654 (Revision 1) and Table 4-1 of the Clinton Power Station Emergency Plan. If you have any questions concerning this summary report, please contact me.

Sincerely yours,


F. A. Spangenberg, III
Manager - Licensing and Safety

WLY/mjb

Attachment

cc: Regional Administrator, Region III, USNRC
J. McCormick-Barger, Chief Emergency Preparedness Section
A. Gody, NRC Clinton Licensing Project Manager
NRC Resident Office
Illinois Department of Nuclear Safety

020038

9210050160 920928
PDR ADOCK 05000461
S PDR

JE22

CLINTON POWER STATION
NOTIFICATION OF UNUSUAL EVENT

On Tuesday, September 22, 1992, at approximately 0915 hours, a Notification of Unusual Event (NOUE) was declared in accordance with Emergency Plan Implementing Procedure EC-02, Emergency Classifications. This procedure requires that a Notification of Unusual Event be declared when a potentially contaminated, injured person is transported to an offsite medical facility for treatment.

Clinton Power Station was operating at approximately 100% power in Mode 1. At approximately 0855 hours, the Control Room received notification that an employee working in the radwaste sort tent had been injured and was potentially contaminated, and that an ambulance had been called to respond.

At approximately 0915 hours, the ambulance departed the site with the victim and the Shift Supervisor declared the Notification of Unusual Event. The State of Illinois was notified at 0928 hours and the NRC Incident Response Center was notified at 0958 hours.

At approximately 0955, the Shift Supervisor received a report from the hospital that the victim was not contaminated. At approximately 1020, the Shift Supervisor received a report that the ambulance and hospital were surveyed for contamination and no evidence of contamination was found; therefore, the Shift Supervisor terminated the Notification of Unusual Event. The State of Illinois was notified at approximately 1029 hours and the NRC Incident Response Center was notified at approximately 1046.