

Exhibit B

Prairie Island Nuclear Generating Plant

License Amendment Request Dated September 21, 1992

Proposed Changes Marked Up  
On Existing Technical Specification Pages

Exhibit B consists of existing and new Technical Specification pages with the proposed changes highlighted on those pages. The existing and new pages affected by this License Amendment Request are listed below:

EXISTING PAGES	NEW PAGES
TS.1-1	TABLE TS.1-1
TS.1-2	TABLE TS.3.5-2A (Pages 1 through 6)
TS.1-4	TABLE TS.3.5-2B (Pages 1 through 8)
TS.1-5	TABLE TS.4.1-1A (Pages 1 through 5)
TS.1-7	TABLE TS.4.1-1B (Pages 1 through 7)
TS.1-8	TABLE TS.4.1-1C (Pages 1 through 4)
TS.2.3-3	B.3.5-5
TS.2.3-4	B.3.6-3
TS.3.4-3	
TS.3.5-1	
TABLE TS.3.5-2 (Pages 1 and 2)	
TABLE TS.3.5-3 (Pages 1 and 2)	
TABLE TS.3.5-4 (Pages 1 and 2)	
TABLE TS.3.5-5	
TABLE TS.3.5-6	
TS.3.10-1	
TS.4.1-1	
TABLE TS.4.1-1 (Pages 1 through 5)	
TABLE TS.4.1-2B (Pages 1 and 2)	
B.2.3-2	
B.2.3-3	
B.3.5-1	
B.3.5-2	
B.3.5-3	
B.3.5-4	
B.3.6-1	
B.3.6-2	
B.3.10-1	
B.3.10-2	
B.4.1-1	
B.4.1-2	

## 1.0 DEFINITIONS

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications.

### ACTION

ACTION shall be that part of a Specification which prescribes remedial measures required under designated conditions.

### AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY

AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY shall exist when:

1. Single doors in the Auxiliary Building Special Ventilation Zone are locked closed, and
2. At least one door in each Auxiliary Building Special Ventilation Zone air lock type passage is closed, and
3. The valves and actuation circuits that isolate the Auxiliary Building Normal Ventilation System following an accident are OPERABLE.
4. The Auxiliary Building Special Ventilation System is OPERABLE.

### CHANNEL CHECK

CHANNEL CHECK is a qualitative determination of acceptable OPERABILITY by observation of channel behavior during operation. This determination shall include comparison of the channel with other independent channels measuring the same variable.

### CHANNEL FUNCTIONAL TEST

A CHANNEL FUNCTIONAL TEST consists of injecting a simulated signal into the channel as close to the primary sensor as practicable to verify that it is OPERABLE, including alarm and/or trip initiating action.

### CHANNEL CALIBRATION

A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel such that it responds within the required range and accuracy to known values of input. The CHANNEL CALIBRATION shall encompass the entire channel including the sensors and alarm, interlock and/or trip functions and may be performed by any series of sequential, overlapping, or total channel steps such that the entire channel is calibrated.

### CHANNEL RESPONSE TEST

A CHANNEL RESPONSE TEST consists of injecting a simulated signal into the channel as near the sensor as practicable to measure the time for electronics and relay actions, including the output scram relay.

### CONTAINMENT INTEGRITY

CONTAINMENT INTEGRITY shall exist when:

1. Penetrations required to be isolated during accident conditions are either:
  - a. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
  - b. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Specifications 3.6.C and 3.6.D.
2. Blind flanges required by Table TS.4.4-1 are installed.
3. The equipment hatch is closed and sealed.
4. Each air lock is in compliance with the requirements of Specification 3.6.M.
5. The containment leakage rates are within their required limits.

### ~~COLD SHUTDOWN~~

~~A reactor is in the COLD SHUTDOWN condition when the reactor is subcritical by at least 1% k/k and the reactor coolant average temperature is less than 200°F.~~

### CORE ALTERATION

CORE ALTERATION is the movement or manipulation of any component within the reactor pressure vessel with the vessel head removed and fuel in the vessel, which may affect core reactivity. Suspension of CORE ALTERATION shall not preclude completion of movement of a component to a safe conservative position.

### CORE OPERATING LIMITS REPORT

The CORE OPERATING LIMITS REPORT is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.7.A.6. Plant operation within these operating limits is addressed in individual specifications.

HOT SHUTDOWN

~~A reactor is in the HOT SHUTDOWN condition when the reactor is subcritical by an amount greater than or equal to the margin as specified in Figure TS.3.10-1 and the reactor coolant average temperature is 547°F or greater.~~

LIMITING SAFETY SYSTEM SETTINGS

LIMITING SAFETY SYSTEM SETTINGS are settings, as specified in Section 2.3, for automatic protective devices related to those variables having significant safety functions.

MEMBERS OF THE PUBLIC

MEMBERS OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the licensee, its contractors, or its vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational occupational, or other purposes not associated with the plant.

OFFSITE DOSE CALCULATION MANUAL (ODCM)

The ODCM is the manual containing the methodology and parameters to be used in the calculation of offsite doses due to radioactive liquid and gaseous effluents, in the calculation of liquid and gaseous effluent monitoring instrumentation alarm and/or trip setpoints, and in the conduct of the Radiological Environmental Monitoring Program.



#### OPERABLE - OPERABILITY

A system, subsystem, train, component or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component or device to perform its function(s) are also capable of performing their related support function(s).

When a system, subsystem, train, component or device is determined to be inoperable solely because its emergency power source is inoperable, or solely because its normal power source is inoperable, it may be considered OPERABLE for the purpose of satisfying the requirements of its applicable Limiting Condition for Operation, provided: (1) its corresponding normal or emergency power source is OPERABLE; and (2) all of its redundant system(s), subsystem(s), train(s), component(s) and device(s) are OPERABLE, or likewise satisfy the requirements of this paragraph.

The OPERABILITY of a system or component shall be considered to be established when: (1) it satisfies the Limiting Conditions for Operation in Specification 3.0, (2) it has been tested periodically in accordance with Specification 4.0 and has met its performance requirements, and (3) its condition is consistent with the two paragraphs above.

#### OPERATIONAL MODE - MODE

An OPERATIONAL MODE (i.e., MODE) shall correspond to any one inclusive combination of core reactivity condition, power level and average reactor coolant temperature specified in Table TS.1.1.

#### PHYSICS TESTS

PHYSICS TESTS shall be those tests performed to measure the fundamental characteristics of the core and related instrumentation. PHYSICS TESTS are conducted such that the core power is sufficiently reduced to allow for the perturbation due to the test and therefore avoid exceeding power distribution limits in Specification 3.10.B.

Low power PHYSICS TESTS are run at reactor powers less than 2% of rated power.

#### POWER OPERATION

POWER OPERATION of a unit is any operating condition that results when the reactor of that unit is critical, and the neutron flux power range instrumentation indicates greater than 2% of RATED THERMAL POWER.

#### RATED THERMAL POWER

RATED THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant of 1650 megawatts thermal (MWt).

#### REFUELING

~~A unit is in the REFUELING condition when:~~

- ~~1. There is fuel in the reactor vessel.~~
- ~~2. The vessel head closure bolts are less than fully tensioned or the head is removed.~~
- ~~3. The reactor coolant average temperature is less than or equal to 140°F, and~~
- ~~4. The boron concentration of the reactor coolant system and the refueling cavity is sufficient to ensure that the more restrictive of the following conditions is met:~~
  - ~~a.  $K_{eff} \leq 0.95$ , or~~
  - ~~b. Boron concentration  $\geq 2000$  ppm.~~

#### REPORTABLE EVENT

A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 of 10 CFR Part 50.

#### SHIELD BUILDING INTEGRITY

SHIELD BUILDING INTEGRITY shall exist when:

1. Each door in each access opening is closed except when the access opening is being used for normal transit entry and exit, then at least one door shall be closed, and
2. The shield building equipment opening is closed.
3. The Shield Building Ventilation System is OPERABLE.

#### SITE BOUNDARY

The SITE BOUNDARY shall be that line beyond which the land is neither owned, nor leased, nor otherwise controlled by the licensee.

#### SOLIDIFICATION

SOLIDIFICATION shall be the conversion of wet wastes into a form that meets shipping and burial ground requirements.

#### SOURCE CHECK

A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a source of increased radioactivity.

#### STAGGERED TEST BASIS

A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the specified Surveillance Frequency so that all systems, subsystems, channels, or other designated components are tested during  $n$  Surveillance Frequency intervals, where  $n$  is the total number of systems, subsystems, channels, or other designated components in the associated function.

For example, the surveillance frequency for the automatic trip and interlock logic specifies that the functional testing of that system is monthly and that each train shall be tested at least every two months on a STAGGERED TEST BASIS. Per the definition above, for the automatic trip and interlock logic, the Surveillance Frequency interval is monthly and the number of trains (channels) is 2 ( $n=2$ ). Therefore, STAGGERED TEST BASIS requires one train be tested each month such that after two Surveillance Frequency intervals (two months) both trains will have been tested.

#### STARTUP OPERATION

The process of heating up a reactor above 200°F, making it critical, and bringing it up to POWER OPERATION.

#### THERMAL POWER

THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

#### UNRESTRICTED AREAS

An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional and/or recreational purposes.

VENTILATION EXHAUST TREATMENT SYSTEM

A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment. Such a system is not considered to have any effect on noble gas effluents. Engineered safety feature atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

VENTING

VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.

TABLE TS.1-1

TABLE TS.1-1  
OPERATIONAL MODES

<u>MODE</u>	<u>REACTIVITY CONDITION, <math>K_{eff}</math></u>	<u>% RATED THERMAL POWER</u>	<u>AVERAGE COOLANT TEMPERATURE</u>
A. POWER OPERATION	NA	> 2%	NA
B. HOT STANDBY	$\geq 0.99$	$\leq 2\%$	NA
C. HOT SHUTDOWN	$< 0.99^{**}$	NA	$\geq 535^{\circ}\text{F}$
D. INTERMEDIATE SHUTDOWN	$< 0.99^{**}$	NA	$< 535^{\circ}\text{F}$ $\geq 200^{\circ}\text{F}$
E. COLD SHUTDOWN	$< 0.99$	NA	$< 200^{\circ}\text{F}$
F. REFUELING**	$\leq 0.95^{***}$	NA	$\leq 140^{\circ}\text{F}$

\* Not a shutdown margin requirement, see Figure TS.3.10-1 for shutdown margin requirements.

\*\* Fuel in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

\*\*\* Boron concentration of the reactor coolant system and the refueling cavity sufficient to ensure that the more restrictive of the following conditions is met:

a.  $K_{eff} \leq 0.95$ , or

b. Boron concentration  $\geq 2000$  ppm.

2.3.A.2.g Reactor coolant pump bus undervoltage -  $\geq 75\%$  of normal voltage.

h. Open reactor coolant pump motor breaker.

~~1. Reactor coolant pump bus undervoltage -  
 $\geq 75\%$  of normal voltage.~~

~~2. Reactor coolant pump bus underfrequency -  $\geq 58.2$  Hz~~

i. Power range neutron flux rate.

1. Positive rate -  $\leq 15\%$  of RATED THERMAL POWER with a time constant  $\geq 2$  seconds

2. Negative rate -  $\leq 7\%$  of RATED THERMAL POWER with a time constant  $\geq 2$  seconds

3. Other reactor trips

a. High pressurizer water level -  $\leq 90\%$  of narrow range instrument span.

b. Low-low steam generator water level -  $\geq 5\%$  of narrow range instrument span.

c. Turbine Generator trip

1. Turbine stop valve indicators - closed

2. Low auto stop oil pressure -  $\geq 45$  psig

d. Safety injection - See Specification 3.5

2.3.B. Protective instrumentation settings for reactor trip interlocks shall be as follows:

1. P-6 Interlock:

Source range high flux trip shall be unblocked whenever intermediate range neutron flux is  $\leq 10^{-10}$  amperes.

2. P-7 Interlock:

"At power" reactor trips that are blocked at low power (low pressurizer pressure, high pressurizer level, and loss of flow for one or two loops) shall be unblocked whenever:

- a. Power range neutron flux is  $\geq 12\%$  of RATED THERMAL POWER or,
- b. Turbine load is  $\geq 10\%$  of full load turbine impulse pressure.

3. P-8 Interlock:

Low power block of single loop loss of flow is permitted whenever power range neutron flux is  $\leq 10\%$  of RATED THERMAL POWER.

4. P-9 Interlock:

Reactor trip on turbine trip shall be unblocked whenever power range neutron flux is  $\geq 50\%$  of RATED THERMAL POWER.

5. P-10 Interlock:

Power range high flux low setpoint trip and intermediate range high flux trip shall be unblocked whenever power range neutron flux is  $\leq 9\%$  of RATED THERMAL POWER.

C. Control Rod Withdrawal Stops

1. Block automatic rod withdrawal:

a. P-2 Interlock:

Turbine load  $\leq 15\%$  of full load turbine impulse pressure.



### 3.4.C. Steam Exclusion System

1. The reactor coolant system average temperature shall not exceed 350°F unless both isolation dampers in each ventilation duct penetrating rooms containing equipment required for a high energy line rupture outside of containment are OPERABLE (except as specified below):
  - a. If one of the two redundant steam exclusion dampers is inoperable, the operable redundant damper may remain open for 24 hours. If after 24 hours, the damper remains inoperable, one of the two dampers shall be closed.
  - b. The actuation logic (including temperature sensors) for one train of steam exclusion may be inoperable for 24 hours. If after 24 hours, the actuation logic remains inoperable, one of the two dampers shall be closed.
2. If two redundant steam exclusion dampers or two trains of actuation logic (including temperature sensors) are inoperable, close the associated dampers within 4 hours.

### D. Radioactivity

A reactor shall not be made or maintained critical nor shall reactor coolant system average temperature exceed 350°F unless the specific activity of the secondary coolant system for that reactor is less than or equal to 0.10 uCi/gm DOSE EQUIVALENT I-131. If these conditions cannot be satisfied, within one hour initiate the action necessary to place the unit in HOT SHUTDOWN, and be in at least HOT SHUTDOWN within the next 6 hours and reduce reactor system coolant average temperature below 350°F within the following 6 hours.

### 3.5 INSTRUMENTATION SYSTEM

#### Applicability

Applies to protection system instrumentation.

#### Objectives

To provide for automatic initiation of the engineered safety features in the event the principal process variable limits are exceeded, and to delineate the conditions of the reactor trip and engineered safety feature instrumentation necessary to ensure reactor safety.

#### Specification

- A. Limiting set points for instrumentation which initiates operation of the engineered safety features shall be as stated in Table TS.3.5-1.
- B. For on-line testing or in the event of failure of a sub-system instrumentation channel, plant operation shall be permitted to continue at RATED THERMAL POWER in accordance with Tables TS.3.5-2A and through TS.3.5-62B.
- ~~C. If the number of channels a particular sub-system in service falls below the limits given in the column entitled Minimum Operable Channels, or if the specified Minimum Degree of Redundancy cannot be achieved, operation shall be limited according to the requirement shown in the column titled Operator Action of Tables TS.3.5-2 through TS.3.5-6.~~
- ~~D. In the event of sub-system instrumentation channel failure permitted by Specification 3.5.B, the requirements of Tables TS.3.5-2 through TS.3.5-6 need not be observed during the short period of time the OPERABLE sub-system channels are tested where the failed channel must be blocked to prevent unnecessary reactor trip. If the test time exceeds four hours, operation shall be limited according to the requirement shown in the column titled Operator Action of Tables TS.3.5-2 through TS.3.5-6.~~

### 3.4.1 steam Exclusion System

1. The reactor coolant system average temperature shall not exceed 350°F unless both isolation dampers in each ventilation duct penetrating rooms containing equipment required for a high energy line rupture outside of containment are OPERABLE (except as specified below):
  - a. If one of the two redundant steam exclusion dampers is inoperable, the operable redundant damper may remain open for 24 hours. If after 24 hours, the damper remains inoperable, one of the two dampers shall be closed.
  - b. The actuation logic (including temperature sensors) for one train of steam exclusion may be inoperable for 24 hours. If after 24 hours, the actuation logic remains inoperable, one of the two dampers shall be closed.
2. If two redundant steam exclusion dampers or two trains of actuation logic (including temperature sensors) are inoperable, close the associated dampers within 4 hours.

### D. Radiochemistry

A reactor shall not be made or maintained critical nor shall reactor coolant system average temperature exceed 350°F unless the specific activity of the secondary coolant system for that reactor is less than or equal to 0.10 uCi/gm DOSE EQUIVALENT I-131. If these conditions cannot be satisfied, within one hour initiate the action necessary to place the unit in HOT SHUTDOWN, and be in at least HOT SHUTDOWN within the next 6 hours and reduce reactor system coolant average temperature below 350°F within the following 6 hours.

### 3.5 INSTRUMENTATION SYSTEM

#### Applicability

Applies to protection system instrumentation.

#### Objectives

To provide for automatic initiation of the engineered safety features in the event the principal process variable limits are exceeded and the conditions of the reactor trip and engineered safety features are necessary to ensure reactor safety.

#### Specification

- A. Limiting set points for instrumentation which initiates engineered safety features shall be as stated in Table TS.3.5-62B.
- B. For on-line testing or in the event of failure of instrumentation channels, plant operation shall be limited to 100% RATED THERMAL POWER in accordance with Table TS.3.5-62B.
- C. If the number of channels in a particular sub-system is less than the limits given in the column entitled Minimum Degree of Redundancy, the specified Minimum Degree of Redundancy shall be limited according to the requirements of the Operator Action of Tables TS.3.5-2 through TS.3.5-62B.
- D. In the event of sub-system instrumentation failure, the requirements of Table TS.3.5-62B need not be observed during the short period when the system channels are tested where the failed channels prevent unnecessary reactor trip. If the test is successful, operation shall be limited according to the requirements of the column titled Operator Action of Tables TS.3.5-2 through TS.3.5-62B.

TABLE TS.3.5-2 (Page 1 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR REACTOR TRIP

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS (1)	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. Manual	2	1		Notes 3, 4
2. Nuclear Flux Power Range <sup>a</sup>				
low setting	3	2	2 of 4 power	Maintain hot shutdown
high setting	3	2	range channels	
positive rate	3	2	greater than	
negative rate	3	2	10% F.P. (low	
			setting only)	
3. Nuclear Flux Intermediate Range	2	1	2 of 4 power	Maintain hot shutdown
			range channels	Note 2
			greater than	
			10% F.P.	
4. Nuclear Flux Source Range	2	1	1 of 2 Inter-	Maintain hot shutdown
			mediate range	Note 2
			channels greater	
			than 10 <sup>-10</sup> amps	
5. Overtemperature $\Delta T$	3	2		Maintain hot shutdown
6. Overpower $\Delta T$	3	2		Maintain hot shutdown
7. Low Pressurizer Pressure	3	2		Maintain hot shutdown
8. HI Pressurizer Pressure	2	1		Maintain hot shutdown
9. Pressurizer-HI Water Level	2	1		Maintain hot shutdown
10. Low Flow in one loop (>10% F.P.)	2/loop	1/loop		Maintain hot shutdown
Low Flow both loops (>10% F.P.)	2/loop	1/loop		Maintain hot shutdown
11. Turbine Trip	2	1		Maintain < 50% of
(Overspeed Protection)				rated power
12. Lo-Low Steam Generator	2/loop	1/loop		Maintain hot shutdown
Water Level				

TABLE TS.3.5-2 (Page 2 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR REACTOR TRIP

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS(1)	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
13. Undervoltage 4KV RCP Bus	1/bus	1/bus		Maintain hot shutdown
14. Underfrequency 4KV Bus	1/bus	1/bus		Maintain hot shutdown
15. Control Rod Misalignment Monitor				
a. Rod position deviation	1			Log data required by
b. Quadrant power tilt	1			TS 3.10-1 and TS 3.10-2
16. RCP Breaker Open	2	1		Maintain hot shutdown
17. Safety Injection Actuation Signal	2	1		Maintain hot shutdown
18. Automatic Trip Logic including Reactor Trip Breakers**	2	1		Notes 3, 4

Note 1: Automatic permissives not listed

Note 2: When bypass condition exists, maintain normal operation

Note 3: With the number of operable channels one less than the minimum operable channels requirement, be in at least hot shutdown within 6 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.1, provided the other channel is operable.

Note 4: When in the hot shutdown condition with the number of operable channels one less than the minimum operable channels requirement, restore the inoperable channel to operable status within 48 hours or open the reactor trip breakers within the next hour.

F.P. - Full Power

\* - One additional channel may be taken out of service for low power physics testing

\*\* - Includes both undervoltage and shunt trip circuits and if either circuit becomes inoperable the respective channel shall be considered inoperable.

SEE NEW TABLE TS.3.5-2A

TABLE TS.3.5-2  
(Page 2 of 2)  
REV 92 3/13/90

TABLE TS.3.5-3

## INSTRUMENT OPERATING CONDITIONS FOR EMERGENCY COOLING SYSTEM

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 or 2 CANNOT BE MET
1. SAFETY INJECTION				
a. Manual	2	1		Hot shutdown **
b. High Containment Pressure	2	1		Hot shutdown **
c. Steam Generator Low Steam Pressure/Loop	2	1	primary pressure less than 2000 psig	Hot shutdown **
d. Pressurizer Low Pressure	2	1	primary pressure less than 2000 psig	Hot shutdown **
2. CONTAINMENT SPRAY				
a. Manual	2	—*		Hot shutdown **
b. Hi-Hi Containment Pressure (Containment Spray)				Hot shutdown **
Channel a	2	1		
Channel b	2	1		
Channel c	2	1		
Logic	2	1		



TABLE TS.3.5-3 (continued)

## INSTRUMENT OPERATING CONDITIONS FOR EMERGENCY COOLING SYSTEMS

FUNCTIONAL UNIT	1 MINIMUM OPERATING CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
3. AUXILIARY FEEDWATER				
a. Steam Generator Low-Low Water Level	2	1		Hot shutdown
b. Undervoltage on 4.16 KV Buses 11 and 12 (21 and 22 Unit 2) (Start Turbine Driven Pump only)	2/bus	1/bus		Hot shutdown
c. Trip of Main Feedwater Pumps	2/pump	1/pump		Hot shutdown
d. Safety Injection	(See Item No. 1)			Hot shutdown
e. Manual	2	1		Hot shutdown

\* - Must actuate two switches simultaneously.

\*\* - If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in cold shutdown conditions.

SEE NEW TABLE TS.3.5-2B

TABLE TS.3.5-3 (Page 2 of 2)  
Rev. 3/2/61

TABLE TS.3.5-4 (Page 1 of 2)

INSTRUMENT OPERATING CONDITIONS FOR ISOLATION FUNCTIONS

<u>FUNCTIONAL UNIT</u>	<u>1</u> MINIMUM OPERABLE CHANNELS	<u>2</u> MINIMUM DEGREE OF REDUNDANCY	<u>3</u> PERMISSIBLE BYPASS CONDITIONS	<u>4</u> OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. CONTAINMENT ISOLATION				
a. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Hot Shutdown**
b. Manual	2	1		Hot Shutdown
2. CONTAINMENT VENTILATION ISOLATION				
a. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Maintain Purge and Inservice Purge Valves closed if (1) conditions of a, b, or c cannot be met above COLD SHUTDOWN or (2) if conditions of b or c cannot be met during fuel handling in containment.
b. High Radiation In Exhaust Air	2	1		
c. Manual	2	1		
3. STEAM LINE ISOLATION				
a. Hi-Hi Steam Flow with Safety Injection	2/loop	1		Hot Shutdown**
b. Hi Steam Flow and 2 of 4 Low $T_{avg}$ with Safety Injection	2/loop	1		Hot Shutdown**
c. Hi Containment Pressure	2	1		Hot Shutdown**
d. Manual	1/loop	-		Hot Shutdown**
4. EMERGENCY COOLDOWN EQUIPMENT ROOM ISOLATION				
a. High temperature in ventilation system ducts	2	1		Hot Shutdown**

DELETED

\*\*If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in COLD SHUTDOWN conditions.

SEE NEW TABLE TS.3.5-2B

TABLE TS.3.5-4  
Page 1 of 2  
REV 95-07/06/94

TABLE TS.3.5-4 (Page 2 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR ISOLATION FUNCTIONS

FUNCTIONAL UNIT	4			
	1	2	3	4
	MINIMUM OPERABLE CHANNELS	MINIMUM DEGREE OF REDUNDANCY	PERMISSIBLE BYPASS CONDITIONS	OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
5. FEEDWATER ISOLATION				
a. HI HI Steam Generator Level	2	1		Hot Shutdown**
b. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Hot Shutdown**
c. Reactor Trip with 2 of 4 Low T <sub>avg</sub> (Main Valves only)	2	1		Hot Shutdown**

\*\*If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in COLD SHUTDOWN conditions.

TABLE TS.3.5-5

INSTRUMENT OPERATING CONDITIONS FOR VENTILATION SYSTEMS

FUNCTIONAL UNIT	1	2	3	4
	MINIMUM OPERABLE CHANNELS	MINIMUM DEGREE OF REDUNDANCY	PERMISSIBLE BYPASS CONDITIONS	OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. SHIELD BUILDING VENTILATION SYSTEM (SBVS)				
a. Safety Injection Signal to Start Fans	2	1		Hot shutdown
b. Pressure Difference Signal for Recirculation Damper Control	2	1		Hot shutdown
2. AUXILIARY BUILDING SPECIAL VENTILATION SYSTEM (ABSVS)				
a. Safety Injection Signal to Start Fans and Isolate Normal Ventila- tion System	2	1		Hot shutdown

Table TS.3.5-5

DELETED

TABLE TS.3.5-6

## INSTRUMENT OPERATING CONDITIONS FOR AUXILIARY ELECTRICAL SYSTEM

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. Degraded Voltage 4KV Safeguards Busses	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***
2. a. Loss of voltage 4KV Safeguard Bus (90%)	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***
b. Loss of voltage 4KV Safeguard Bus (55%)	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***

\*\*\* If minimum conditions are not met within 24 hours, steps shall be taken to place the unit in cold shutdown conditions.

TABLE TS.3.5-2A (Page 1 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	A, B	1
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
2. Power Range, Neutron Flux					
a. High Setpoint	4	2	3	A, B	2
b. Low Setpoint	4	2	3	A <sup>(b)</sup> , B	2
3. Power Range, Neutron Flux, High Positive Rate	4	2	3	A, B	2
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	A, B	2
5. Intermediate Range, Neutron Flux	2	1	2	A <sup>(b)</sup> , B	3
6. Source Range, Neutron Flux					
a. Startup	2	1	2	B <sup>(c)</sup>	4
b. Shutdown	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	5
7. Overtemperature $\Delta T$	4	2	3	A, B	6
8. Overpower $\Delta T$	4	2	3	A, B	6

(a) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(b) Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

(c) Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

TABLE TS.3.5-2A (Page 2 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
9. Low Pressurizer Pressure	4	2	3	A	6
10. High Pressurizer Pressure	3	2	2	A, B	6
11. Pressurizer High Water Level	3	2	2	A	6
12. Reactor Coolant Flow Low	3/loop	2/loop	2/loop	A	6
13. Turbine Trip					
a. Low AST Oil Pressure	3	2	2	A	6
b. Turbine Stop Valve Closure	2	2	1	A	6
14. Lo-Lo Steam Generator Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	6
15. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22)	2/bus	1/bus on both buses	2 on one bus	A	11



TABLE TS.3.5-2A (Page 3 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
16. Loss of Reactor Coolant Pump					
a. RCP Breaker Open	1/pump	1	1/pump	A	1
b. Underfrequency 4kV bus	2/bus	1, bus on both buses	2 on one bus	A	11
17. Safety Injection Input from ESF	2	1	2	A, B	7
18. Automatic Trip and Interlock Logic	2	1	2	A, B	7
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
19. Reactor Trip Breakers	2	1	2	A, B	9
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
20. Reactor Trip Bypass Breakers	2	1	1	(d)	10

(a) When the Reactor Trip breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(d) When the Reactor Trip Bypass Breakers are racked in and closed for bypassing a Reactor Trip Breaker and the Control Rod System is capable of rod withdrawal.

TABLE 3.5-2A (Page 4 of 6)

Action Statements

ACTION 1: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours.

ACTION 2: With the number of OPERABLE channels less than the Total Number of Channels HOT STANDBY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours;
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1; and
- c. If THERMAL POWER is above 85% of RATED THERMAL POWER, then determine the core quadrant power balance in accordance with the requirements of Specification 3.10.C.4.
- d. One additional channel may be taken out of service for low power PHYSICS TESTS.

ACTION 3: With the number of channels OPERABLE one less than the Total Number of Channels and with the THERMAL POWER level:

- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.
- b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.

ACTION 4: With the number of OPERABLE channels one less than the Total Number of Channels suspend all operations involving positive reactivity changes.

ACTION 5: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or within the next hour open the reactor trip breakers and suspend all operations involving positive reactivity changes.

TABLE 3.5-2A (Page 5 of 6)

Action Statements

ACTION 6: With the number of OPERABLE channels one less than the Total Number of Channels, HOT STANDBY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 7: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours; however, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1 provided the other channel is OPERABLE.

ACTION 8: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

- ACTION 9:
- a. With one of the diverse trip features (Undervoltage or Shunt Trip Attachment) inoperable, restore it to OPERABLE status within 48 hours or declare the breaker inoperable and apply the requirements of b below. The breaker shall not be bypassed while one of the diverse trip features is inoperable, except for the time required for performing maintenance and testing to restore the diverse trip feature to OPERABLE status.
  - b. With one of the Reactor Trip Breakers otherwise inoperable, be in at least HOT SHUTDOWN within 6 hours; however, one Reactor Trip Breaker may be bypassed for up to 4 hours for surveillance testing per Specification 4.1, provided the other Reactor Trip Breaker is OPERABLE.

ACTION 10: With the Reactor Trip Bypass Breaker inoperable, restore the Reactor Trip Bypass Breaker to OPERABLE status prior to using the Reactor Trip Bypass Breaker to bypass a Reactor Trip Breaker. If the Reactor Trip Bypass Breaker is ricked in and closed for bypassing a Reactor Trip Breaker and it becomes inoperable, be in at least HOT SHUTDOWN within 6 hours. Restore the Bypass Breaker to OPERABLE status within the next 48 hours or open the Bypass Breaker within the following hour.

TABLE 3.5-2A (Page 6 of 6)

Action Statements

ACTION 11: With the number of OPERABLE channels less than the Total Number of Channels, POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel(s) is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 19: NOT USED

ACTION 12: NOT USED

ACTION 13: NOT USED

ACTION 14: NOT USED

ACTION 15: NOT USED

ACTION 16: NOT USED

ACTION 17: NOT USED

ACTION 18: NOT USED

TABLE TS.3.5-2B (Page 1 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. SAFETY INJECTION					
a. Manual Initiation	2	1	2	A, B, C, D	23
b. High Containment Pressure	3	2	2	A, B, C, D	24
c. Steam Generator Low Steam Pressure/Loop	3/Loop	2 in any Loop	2/Loop	A, B, C <sup>(*)</sup>	24
d. Pressurizer Low Pressure	3	2	2	A, B, C <sup>(*)</sup>	24
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
2. CONTAINMENT SPRAY					
a. Manual Initiation	2	2	2	A, B, C, D	23
b. Hi-Hi Containment Pressure	3 channels with 2 sensors per channel	1 sensor per channel in all 3 channels	1 sensor per channel in all 3 channels	A, B, C, D	23
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20

(\*) Trip function may be blocked in this MODE below a Reactor Coolant System Pressure of 2000 psig.

TABLE TS.3.5-2B (Page 2 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
3. CONTAINMENT ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	A, B, C, D	23
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
4. CONTAINMENT VENTILATION ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	(b)	22
c. Manual Containment Spray	See 2a above for Manual Containment Spray requirements.				
d. Manual Containment Isolation	See 3b above for Manual Containment Isolation requirements.				
e. High Radiation in Exhaust Air	2	1	2	(b)	22
f. Automatic Actuation Logic and Actuation Relays	2	1	2	(b)	22

(b) Whenever CONTAINMENT INTEGRITY is required and either of the containment purge systems are in operation.

TABLE TS.3.5-2B (Page 3 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION					
a. Manual	1/Loop	1/Loop	1/Loop	A, B, C, D <sup>(c)</sup>	27
b. Hi-Hi Containment Pressure	3	2	2	A, B, C, D <sup>(c)</sup>	24
c. Hi-Hi Steam Flow with Safety Injection					
1. Hi-Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(c)</sup>	29
2. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
d. Hi Steam Flow and 2 of 4 Low Tave with Safety Injection:					
1. Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(d)</sup>	29
2. Tave	4	2	3	A, B, C, D <sup>(d)</sup>	24
3. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

(d) When reactor coolant system average temperature is greater than 520°F and either main steam isolation valve is open.



TABLE TS.3.5-2B (Page 4 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION (continued)					
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(c)</sup>	25
6. FEEDWATER ISOLATION					
a. Hi-Hi Steam Generator Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	24
b. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
c. Reactor Trip with 2 of 4 Low Tave (Main Valves only):					
1. Reactor Trip	2	1	2	A, B	28
2. Low Tave	4	2	3	A, B	24
d. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B	28

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

TABLE TS.3.5-2B (Page 5 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
7. AUXILIARY FEEDWATER					
a. Manual	2	1	2	A, B, C, D <sup>(*)</sup>	26
b. Steam Generator Low-Low Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B, C, D <sup>(*)</sup>	24
c. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22) (Start Turbine Driven Pump only)	2/bus	1/bus on both buses	2 on one bus	A, B	29
d. Trip of Main Feedwater Pumps					
1. Turbine Driven	2	2	2	A, B	26
2. Motor Driven	2	2	2	A, B	26
e. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
f. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(*)</sup>	20

(e) When reactor coolant system average temperature is greater than 350°F.

TABLE TS.3.5-2B (Page 6 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. LOSS OF POWER					
a. Loss of Voltage (90%) Coincident with Degraded Voltage (90%) or Loss of Voltage (55%) Coincident with Degraded Voltage (90%)					
1. Loss of Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
2. Loss of Voltage 4kv Safeguards Bus (55%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
3. Degraded Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Loss of Voltage 55% or 90% on other phase	1/Bus	A, B, C, D	29

TABLE TS.3.5-2 (Page 1 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR REACTOR TRIP

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS (1)	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. Manual	2	1		Notes 3, 4
2. Nuclear Flux Power Range*				
low setting	3	2	2 of 4 power	Maintain hot shutdown
high setting	3	2	range channels	
positive rate	3	2	greater than	
negative rate	3	2	10% F.P. (low	
			setting only)	
3. Nuclear Flux Intermediate Range	2	1	2 of 4 power	Maintain hot shutdown
			range channels	Note 2
			greater than	
			10% F.P.	
4. Nuclear Flux Source Range	2	1	1 of 2 Inter-	Maintain hot shutdown
			mediate range	Note 2
			channels greater	
			than $10^{-10}$ amps	
5. Overtemperature $\Delta T$	3	2		Maintain hot shutdown
6. Overpower $\Delta T$	3	2		Maintain hot shutdown
7. Low Pressurizer Pressure	3	2		Maintain hot shutdown
8. HI Pressurizer Pressure	2	1		Maintain hot shutdown
9. Pressurizer-HI Water Level	2	1		Maintain hot shutdown
10. Low Flow in one loop (>10% F.P.)	2/loop	1/loop		Maintain hot shutdown
Low Flow both loops (>10% F.P.)	2/loop	1/loop		
11. Turbine Trip (Overspeed Protection)	2	1		Maintain < 50% of rated power
12. Lo-Lo Steam Generator Water Level	2/loop	1/loop		Maintain hot shutdown

SEE NEW TABLE TS.3.5-2A

TS.3.5-2  
Page 1 of 2  
REV 75-0120/05

TABLE TS.3.5-2 (Page 2 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR REACTOR TRIP

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS(1)	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
13. Undervoltage 4KV RCP Bus	1/bus	1/bus		Maintain hot shutdown
14. Underfrequency 4KV Bus	1/bus	1/bus		Maintain hot shutdown
15. Control Rod Misalignment Monitor		<b>DELETED</b>		
a. Rod position deviation	1			Log data required by
b. Quadrant power tilt	1			TS 3.10.1 and TS 3.10.3
16. RCP Breaker Open	2	1		Maintain hot shutdown
17. Safety Injection Actuation Signal	2	1		Maintain hot shutdown
18. Automatic Trip Logic including Reactor Trip Breakers**	2	1		Notes 3, 4

Note 1: Automatic permissives not listed

Note 2: When bypass condition exists, maintain normal operation

Note 3: With the number of operable channels one less than the minimum operable channels requirement, be in at least hot shutdown within 6 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.1, provided the other channel is operable.

Note 4: When in the hot shutdown condition with the number of operable channels one less than the minimum operable channels requirement, restore the inoperable channel to operable status within 48 hours or open the reactor trip breakers within the next hour.

F.P. = Full Power

\* = One additional channel may be taken out of service for low power physics testing

\*\* = Includes both undervoltage and shunt trip circuits and if either circuit becomes inoperable the respective channel shall be considered inoperable.

SEE NEW TABLE TS.3.5-2A

TABLE TS.3.5-2  
(Page 2 of 2)  
REV 92 3/13/90

TABLE TS.3.5-3

## INSTRUMENT OPERATING CONDITIONS FOR EMERGENCY COOLING SYSTEM

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 or 2 CANNOT BE MET
1. SAFETY INJECTION				
a. Manual	2	1		Hot shutdown **
b. High Containment Pressure	2	1		Hot shutdown **
c. Steam Generator Low Steam Pressure/Loop	2	1	primary pressure less than 2000 psig	Hot shutdown **
d. Pressurizer Low Pressure	2	1	primary pressure less than 2000 psig	Hot shutdown **
2. CONTAINMENT SPRAY				
a. Manual	2	—*		Hot shutdown **
b. Hi-Hi Containment Pres- sure (Containment Spray)				Hot shutdown **
Channel a	2	1		
Channel b	2	1		
Channel c	2	1		
Logic	2	1		

TABLE TS.3.5-3 (continued)

INSTRUMENT OPERATING CONDITIONS FOR EMERGENCY COOLING SYSTEMS

<u>FUNCTIONAL UNIT</u>	<u>1</u> MINIMUM OPERATING CHANNELS	<u>2</u> MINIMUM DEGREE OF REDUNDANCY	<u>3</u> PERMISSIBLE BYPASS CONDITIONS	<u>4</u> OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
3. AUXILIARY FEEDWATER				
a. Steam Generator Low-Low Water Level	2	1		Hot shutdown
b. Undervoltage on 4.16 KV Buses 11 and 12 (21 and 22 Unit 2) (Start Turbine Driven Pump only)	2/bus	1/bus		Hot shutdown
c. Trip of Main Feedwater Pumps	2/pump	1/pump		Hot shutdown
d. Safety Injection	(See Item No. 1)			Hot shutdown
e. Manual	2	1		Hot shutdown

\* - Must actuate two switches simultaneously.

\*\* - If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in cold shutdown conditions.

SEE NEW TABLE TS.3.5-2B

TABLE TS.3.5-3 (Page 2 of 3)  
REV 44 3/2/61

TABLE TS.3.5-4 (Page 1 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR ISOLATION FUNCTIONS

<u>FUNCTIONAL UNIT</u>	<u>1</u> MINIMUM OPERABLE CHANNELS	<u>2</u> MINIMUM DEGREE OF REDUNDANCY	<u>3</u> PERMISSIBLE BYPASS CONDITIONS	<u>4</u> OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. CONTAINMENT ISOLATION				
a. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Hot Shutdown**
b. Manual	2	1		Hot Shutdown
2. CONTAINMENT VENTILATION ISOLATION				
a. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Maintain Purge and Inservice Pt Valves closed if (1) conditions of a, b, or c cannot be met and COLD SHUTDOWN or (2) if condition of b or c cannot be met during fuel handling in containment.
b. High Radiation in Exhaust Air	2	1		
c. Manual	2	1		
3. STEAM LINE ISOLATION				
a. HI-HI Steam Flow with Safety Injection	2/loop	1		Hot Shutdown**
b. HI Steam Flow and 2 of 4 Low T <sub>avg</sub> with Safety Injection	2/loop	1		Hot Shutdown**
c. HI Containment Pressure	2	1		Hot Shutdown**
d. Manual	1/loop	-		Hot Shutdown**
4. EMERGENCY COOLDOWN EQUIPMENT ROOM ISOLATION				
a. High temperature in ventilation system ducts	2	1		Hot Shutdown**

DELETED

\*\*If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in COLD SHUTDOWN conditions.

SEE NEW TABLE TS.3.5-2B

TABLE TS.3.5-4  
Page 1 of 2  
REV 95 4/30/91



TABLE TS.3.5-4 (Page 2 of 2)

## INSTRUMENT OPERATING CONDITIONS FOR ISOLATION FUNCTIONS

FUNCTIONAL UNIT	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
5. FEEDWATER ISOLATION				
a. Hi Hi Steam Generator Level	2	1		Hot Shutdown**
b. Safety Injection	(See Item No. 1 of Table TS.3.5-3)			Hot Shutdown**
c. Reactor Trip with 2 of 4 Low T <sub>avg</sub> (Main Valves only)	2	1		Hot Shutdown**

\*\*If minimum conditions are not met within 24 hours, steps shall be taken on the affected unit to place the unit in COLD SHUTDOWN conditions.

TABLE TS.3.5-5

## INSTRUMENT OPERATING CONDITIONS FOR VENTILATION SYSTEMS

FUNCTIONAL UNIT	1	2	3	4
	MINIMUM OPERABLE CHANNELS	MINIMUM DEGREE OF REDUNDANCY	PERMISSIBLE BYPASS CONDITIONS	OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. SHIELD BUILDING VENTILATION SYSTEM (SBVS)				
a. Safety Injection Signal to Start Fans	2	1		Hot shutdown
b. Pressure Difference Signal for Recirculation Damper Control	2	1		Hot shutdown
2. AUXILIARY BUILDING SPECIAL VENTILATION SYSTEM (ABSVS)				
a. Safety Injection Sigr 1 to Start Fans and Isolate Normal Ventila- tion System	2	1		Hot shutdown

Table TS.3.5-5

DELETED

SEE NEW TABLE TS.3.5-2B

TABLE TS.3.5-6  
REV 50 10/28/81

TABLE TS.3.5-6

FUNCTIONAL UNIT	INSTRUMENT OPERATING CONDITIONS FOR AUXILIARY ELECTRICAL SYSTEM			
	1 MINIMUM OPERABLE CHANNELS	2 MINIMUM DEGREE OF REDUNDANCY	3 PERMISSIBLE BYPASS CONDITIONS	4 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET
1. Degraded Voltage 4KV Safeguards Busses	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***
2. a. Loss of voltage 4KV Safeguard Bus (90%)	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***
b. Loss of voltage 4KV Safeguard Bus (55%)	1/Bus	1/Bus	---	Place inoperable channel in the tripped condition within one hour or be in hot shutdown.***

\*\*\* If minimum conditions are not met within 24 hours, steps shall be taken to place the unit in cold shutdown conditions.

TABLE TS.3.5-2A (Page 1 of 6)

## REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	A, B	1
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
2. Power Range, Neutron Flux					
a. High Setpoint	4	2	3	A, B	2
b. Low Setpoint	4	2	3	A <sup>(b)</sup> , B	2
3. Power Range, Neutron Flux, High Positive Rate	4	2	3	A, B	2
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	A, B	2
5. Intermediate Range, Neutron Flux	2	1	2	A <sup>(b)</sup> , B	3
6. Source Range, Neutron Flux					
a. Startup	2	1	2	B <sup>(c)</sup>	4
b. Shutdown	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	5
7. Overtemperature $\Delta T$	4	2	3	A, B	6
8. Overpower $\Delta T$	4	2	3	A, B	6

(a) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(b) Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

(c) Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

TABLE TS.3.5-2A (Page 2 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
9. Low Pressurizer Pressure	4	2	3	A	6
10. High Pressurizer Pressure	3	2	2	A, B	6
11. Pressurizer High Water Level	3	2	2	A	6
12. Reactor Coolant Flow Low	3/loop	2/loop	2/loop	A	6
13. Turbine Trip					
a. Low AST Oil Pressure	3	2	2	A	6
b. Turbine Stop Valve Closure	2	2	1	A	6
14. Lo-Lo Steam Generator Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	6
15. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22)	2/bus	1/bus on both buses	2 on one bus	A	11

TABLE TS.3.5-2A (Page 3 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
16. Loss of Reactor Coolant Pump					
a. RCP Breaker Open	1/pump	1	1/pump	A	1
b. Underfrequency 4kV bus	2/bus	1/bus on both buses	2 on one bus	A	11
17. Safety Injection Input from ESF	2	1	2	A, B	7
18. Automatic Trip and Interlock Logic	2	1	2	A, B	7
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
19. Reactor Trip Breakers	2	1	2	A, B	9
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
20. Reactor Trip Bypass Breakers	2	1	1	(d)	10

(a) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(d) When the Reactor Trip Bypass Breakers are racked in and closed for bypassing a Reactor Trip Breaker and the Control Rod System is capable of rod withdrawal.

TABLE 3.5-2A (Page 4 of 6)

Action Statements

ACTION 1: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours.

ACTION 2: With the number of OPERABLE channels less than the Total Number of Channels HOT STANDBY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours;
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1; and
- c. If THERMAL POWER is above 85% of RATED THERMAL POWER, then determine the core quadrant power balance in accordance with the requirements of Specification 3.10.C.4.
- d. One additional channel may be taken out of service for low power PHYSICS TESTS.

ACTION 3: With the number of channels OPERABLE one less than the Total Number of Channels and with the THERMAL POWER level:

- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.
- b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.

ACTION 4: With the number of OPERABLE channels one less than the Total Number of Channels suspend all operations involving positive reactivity changes.

ACTION 5: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or within the next hour open the reactor trip breakers and suspend all operations involving positive reactivity changes.

TABLE 3.5-2A (Page 5 of 6)

Action Statements

ACTION 6: With the number of OPERABLE channels one less than the Total Number of Channels, HOT STANDBY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 7: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours; however, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1 provided the other channel is OPERABLE.

ACTION 8: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

- ACTION 9:
- a. With one of the diverse trip features (Undervoltage or Shunt Trip Attachment) inoperable, restore it to OPERABLE status within 48 hours or declare the breaker inoperable and apply the requirements of b below. The breaker shall not be bypassed while one of the diverse trip features is inoperable, except for the time required for performing maintenance and testing to restore the diverse trip feature to OPERABLE status.
  - b. With one of the Reactor Trip Breakers otherwise inoperable, be in at least HOT SHUTDOWN within 6 hours; however, one Reactor Trip Breaker may be bypassed for up to 4 hours for surveillance testing per Specification 4.1, provided the other Reactor Trip Breaker is OPERABLE.

ACTION 10: With the Reactor Trip Bypass Breaker inoperable, restore the Reactor Trip Bypass Breaker to OPERABLE status prior to using the Reactor Trip Bypass Breaker to bypass a Reactor Trip Breaker. If the Reactor Trip Bypass Breaker is racked in and closed for bypassing a Reactor Trip Breaker and it becomes inoperable, be in at least HOT SHUTDOWN within 6 hours. Restore the Bypass Breaker to OPERABLE status within the next 48 hours or open the Bypass Breaker within the following hour.



TABLE 3.5-2A (Page 6 of 6)

Action Statements

ACTION 11: With the number of OPERABLE channels less than the Total Number of Channels, POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel(s) is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 19: NOT USED

ACTION 12: NOT USED

ACTION 13: NOT USED

ACTION 14: NOT USED

ACTION 15: NOT USED

ACTION 16: NOT USED

ACTION 17: NOT USED

ACTION 18: NOT USED

TABLE TS.3.5-2B (Page 1 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. SAFETY INJECTION					
a. Manual Initiation	2	1	2	A, B, C, D	23
b. High Containment Pressure	3	2	2	A, B, C, D	24
c. Steam Generator Low Steam Pressure/Loop	3/Loop	2 in any Loop	2/Loop	A, B, C <sup>(a)</sup>	24
d. Pressurizer Low Pressure	3	2	2	A, B, C <sup>(a)</sup>	24
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
2. CONTAINMENT SPRAY					
a. Manual Initiation	2	2	2	A, B, C, D	23
b. Hi-Hi Containment Pressure	3 channels with 2 sensors per channel	1 sensor per channel in all 3 channels	1 sensor per channel in all 3 channels	A, B, C, D	21
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20

---

(a) Trip function may be blocked in this MODE below a Reactor Coolant System Pressure of 2000 psig.

TABLE TS.3.5-2B (Page 2 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
3. CONTAINMENT ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	A, B, C, D	23
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
4. CONTAINMENT VENTILATION ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	(b)	22
c. Manual Containment Spray	See 2a above for Manual Containment Spray requirements.				
d. Manual Containment Isolation	See 3b above for Manual Containment Isolation requirements.				
e. High Radiation in Exhaust Air	2	1	2	(b)	22
f. Automatic Actuation Logic and Actuation Relays	2	1	2	(b)	22

---

(b) Whenever CONTAINMENT INTEGRITY is required and either of the containment purge systems are in operation.

TABLE TS.3.5-2B (Page 3 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION					
a. Manual	1/Loop	1/Loop	1/Loop	A, B, C, D <sup>(c)</sup>	27
b. Hi-Hi Containment Pressure	3	2	2	A, B, C, D <sup>(c)</sup>	24
c. Hi-Hi Steam Flow with Safety Injection					
1. Hi-Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(c)</sup>	29
2. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
d. Hi Steam Flow and 2 of 4 Low Tave with Safety Injection:					
1. Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(d)</sup>	29
2. Tave	4	2	3	A, B, C, D <sup>(d)</sup>	24
3. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

(d) When reactor coolant system average temperature is greater than 520°F and either main steam isolation valve is open.

TABLE TS.3.5-2B (Page 4 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION (continued)					
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(c)</sup>	25
6. FEEDWATER ISOLATION					
a. Hi-Hi Steam Generator Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	24
b. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
c. Reactor Trip with 2 of 4 Low Tave (Main Valves only):					
1. Reactor Trip	2	1	2	A, B	28
2. Low Tave	4	2	3	A, B	24
d. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B	28

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

TABLE TS.3.5-2B (Page 5 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
7. AUXILIARY FEEDWATER					
a. Manual	2	1	2	A, B, C, D <sup>(*)</sup>	26
b. Steam Generator Low-Low Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B, C, D <sup>(*)</sup>	24
c. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22) (Start Turbine Driven Pump only)	2/bus	1/bus on both buses	2 on one bus	A, B	29
d. Trip of Main Feedwater Pumps					
1. Turbine Driven	2	2	2	A, B	26
2. Motor Driven	2	2	2	A, B	26
e. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
f. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(*)</sup>	20

---

(e) When reactor coolant system average temperature is greater than 350°F.

TABLE TS.3.5-2B (Page 6 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. LOSS OF POWER					
a. Loss of Voltage (90%) Coincident with Degraded Voltage (90%) or Loss of Voltage (55%) Coincident with Degraded Voltage (90%)					
1. Loss of Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
2. Loss of Voltage 4kv Safeguards Bus (55%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
3. Degraded Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Loss of Voltage 55% or 90% on other phase	1/Bus	A, E, C, D	29

TABLE 3.5-2B (Page 7 of 8)

Action Statements

ACTION 20: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 21: With the number of OPERABLE channels less than the Total Number of Channels, operation may proceed provided the inoperable channel(s) is placed in the tripped condition and the Minimum Channels OPERABLE requirement is met. The inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing per Specification 4.1.

ACTION 22: With the number of OPERABLE channels less than the Total Number of Channels, operation may continue provided the containment purge supply and exhaust valves are maintained closed.

ACTION 23: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

ACTION 24: With the number of OPERABLE channels one less than the Total Number of Channels, operation in the applicable MODE may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and,
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.



TABLE 3.5-2B (Page 8 of 8)

Action Statements

ACTION 25: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours. Operation in HOT SHUTDOWN may proceed provided the main steam isolation valves are closed, if not, reduce reactor coolant system average temperature below 350°F within the following 6 hours. However, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 26: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within 6 hours and reduce reactor coolant system average temperature below 350°F within the following 6 hours.

ACTION 27: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours and close the associated valve.

ACTION 28: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 5 hours. However, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 29: With the number of OPERABLE channels less than the Total Number of Channels, operation in the applicable MODE may proceed provided the following conditions are satisfied:

- a. The inoperable channel(s) is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1

### 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

#### Applicability

Applies to the limits on core fission power distribution and to the limits on control rod operations.

#### Objective

To assure 1) core subcriticality after reactor trip, 2) acceptable core power distributions during POWER OPERATION, and 3) limited potential reactivity insertions caused by hypothetical control rod ejection.

#### Specification

##### A. Shutdown Margin

The shutdown margin with allowance for a stuck control rod assembly shall exceed the applicable value shown in Figure TS.3.10-1 under all steady-state operating conditions, except for PHYSICS TESTS, from zero to full power, including effects of axial power distribution. The shutdown margin as used here is defined as the amount by which the reactor core would be subcritical at HOT SHUTDOWN temperature conditions if all control rod assemblies were tripped, assuming that the highest worth control rod assembly remained fully withdrawn, and assuming no changes in xenon or boron concentration.

##### B. Power Distribution Limits

1. At all times, except during low power PHYSICS TESTING, measured hot channel factors,  $F_Q^H$  and  $F_{\Delta H}^H$ , as defined below and in the bases, shall meet the following limits:

$$F_Q^H \times 1.03 \times 1.05 \leq (F_Q^{RTP} / P) \times K(Z)$$

$$F_{\Delta H}^H \times 1.04 \leq F_{\Delta H}^{RTP} \times [1 + PFDH(1-P)]$$

where the following definitions apply:

- $F_Q^{RTP}$  is the  $F_Q$  limit at RATED THERMAL POWER specified in the CORE OPERATING LIMITS REPORT.
- $F_{\Delta H}^{RTP}$  is the  $F_{\Delta H}$  limit at RATED THERMAL POWER specified in the CORE OPERATING LIMITS REPORT.
- PFDH is the Power Factor Multiplier for  $F_{\Delta H}^H$  specified in the CORE OPERATING LIMITS REPORT.
- $K(Z)$  is a normalized function that limits  $F_Q(z)$  axially as specified in the CORE OPERATING LIMITS REPORT.
- $Z$  is the core height location.
- $P$  is the fraction of RATED THERMAL POWER at which the core is operating. In the  $F_Q^H$  limit determination when  $P \leq 0.50$ , set  $P = 0.50$ .

#### 4.1 OPERATIONAL SAFETY REVIEW

##### Applicability

Applies to items directly related to safety limits and limiting conditions for operation.

##### Objective

To specify the minimum frequency and type of surveillance to be applied to plant equipment and conditions.

##### Specification

- A. Calibration, testing, and checking of instrumentation channels and testing of logic channels shall be performed as specified in Tables TS.4.1-1A, 4.1-1B and 4.1-1C.
- B. Equipment tests shall be conducted as specified in Table TS.4.1-2A.
- C. Sampling tests shall be conducted as specified in Table TS.4.1-2B.
- D. Whenever the plant condition is such that a system or component is not required to be OPERABLE the surveillance testing associated with that system or component may be discontinued. ~~The asterisked items in Tables 4.1-1, 4.1-2A, and 4.1-2B are required at all times, however,~~ Discontinued surveillance tests shall be resumed less than one test interval before establishing plant conditions requiring OPERABILITY of the associated system or component, unless such testing is not practicable (i.e., nuclear power range calibration cannot be done prior to reaching POWER OPERATION) in which case the testing will be resumed within 48 hours of attaining the plant condition which permits testing to be accomplished.

TABLE TS.4.1-1 (Page 1 of 5)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND  
TEST OF INSTRUMENT CHANNELS

Channel Description	Check	Calibrate	Functional Test	Response Test	Remarks
1. Nuclear Power Range	S(1) M(4)	D(2) Q(4)	H(3) H(5) H(6) P(7)	R	1) Once/shift when in service 2) Heat balance 3) Signal to $\Delta T$ ; bistable action (permissive, rod stop, trips), with the exception of the items covered in Remark #7. 4) Upper and lower chambers for axial off-set using in-core detectors 5) Stimulated signal for testing positive and negative rate bistable action 6) Quadrant Power Tilt Monitor 7) P8 and P10 permissives and the 25% High Flux Low Setpoint Trip.
2. Nuclear Intermediate Range	*S(1)	NA	T(2)	R	1) Once/shift when in service 2) Log Level; bistable action (permissive, rod stop, trips)
3. Nuclear Source Range	*S(1)	NA	T(2)	R	1) Once/shift when in service 2) Bistable action (alarm, trips)
4. Reactor Coolant Temperature	S(1,2)	R(1,2,3)	H(1) H(2) T(3)	R(1) E(2)	1) Overtemperature $\Delta T$ 2) Overpower $\Delta T$ 3) Control Rod Bank Insertion Limit Monitor
5. Reactor Coolant Flow	S	R	H	NA	
6. Pressurizer Water Level	S	R	H	NA	
7. Pressurizer Pressure	S	R	H	NA	
8. 4KV Voltage & Frequency	NA	R	H	NA	
8a. RCP Breakers	NA	R	T	NA	Reactor protection circuits only

TABLE TS.4.1-1 (Page 2 of 5)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND  
TEST OF INSTRUMENT CHANNELS

Channel Description	Check S(1) M(2)	Calibrate R	Functional Test		Response Test	Remarks
			T(2)	T(3)		
9. Analog Rod Position					NA	1) With step counters 2) Rod Position Deviation Monitor Tested by updating computer bank count and comparing with analog rod position test signal
10. Rod Position Bank Counters	S(1,2) M(3)	NA		T(3)	NA	1) With analog rod position Following rod motion in excess of six inches when the computer is out of service 2) Control rod banks insertion limit monitor and control rod position deviation monitors
11a. Steam Generator Low Level	S	R	M		NA	
11b. Steam Generator High Level	S	R	M		NA	
12. Steam Flow	S	R	M		NA	
13. Charging Flow	S	R	NA		NA	
14. Residual Heat Removal Pump Flow	S(1)	R	NA		NA	1) When in operation
15. Boric Acid Tank Level	D	R(1)	M(1)		NA	1) Transfer logic to Refueling Water Storage Tank
16. Refueling Water Storage Tank Level	W	R	M(1)		NA	1) Functional test can be performed by bleeding transmitter
17. Volume Control Tank	S	R	NA		NA	
18a. Containment Pressure SI Signal	S	R	M(1)		NA	Wide Range Containment Pressure 1) Isolation Valve Signal
18b. Containment Pressure Steam line Isolation	S	R	M		NA	Narrow Range Containment Pressure

TABLE TS.4.1-1 (Page 3 of 5)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND  
TEST OF INSTRUMENT CHANNELS

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Functional Test</u>	<u>Response Test</u>	<u>Remarks</u>
18c. Containment Pressure Containment Spray	S	R	M	NA	
18d. Annulus Pressure (Vacuum Breaker)	NA	R	R	NA	
19. Auto Load Sequencers	NA	NA	M	NA	
20. Boric Acid Make-up Flow Channel	NA		NA	NA	
21. Containment Sump Level	NA	R	R	NA	Includes Sumps A, B, and C
22. Accumulator Level and Pressure	S	R	R	NA	
23. Steam Generator Pressure	S	R	M	NA	
24. Turbine First Stage Pressure	S	R	M	NA	
25. Emergency Plan Radiation Instruments	*M	R	M	NA	Includes those named in the emergency procedure (referenced in Spec. 6.5.A.6)
**26a. Protection Systems Logic Channel Testing	NA	NA	M	NA	Includes reactor trip logic for both the undervoltage and shunt trips
**26b. Reactor Trip Breakers	NA	NA	M(1)	R(2)	1) Includes independent testing of both undervoltage and shunt trip attach- ment of the reactor trip breakers. 2) Automatically trip the undervoltage trip attachment.
**26c. Manual Reactor Trip	NA	NA	R	NA	Includes independent testing of both undervoltage and shunt trip circuits. The test shall also verify the operabil- ity of the bypass breaker.

SEE NEW TABLES TS.4.1-1A THROUGH TS.4.1-1C

Table TS.4.1-1  
(Page 3 of 5)  
Rev. 10-1-79



TABLE TS.4.1-1 (Page 4 of 5)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND  
TEST OF INSTRUMENT CHANNELS

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Functional Test</u>	<u>Response Test</u>	<u>Remarks</u>
26 d. Reactor Trip Bypass Breaker	NA	NA	M(1)	R(2)	1) Manually trip the undervoltage trip attachment remotely (i.e. from the protection system racks). 2) Automatically trip the undervoltage trip attachment
27. Turbine Overspeed Protection Trip Channel	NA	R	M	NA	
28. Deleted					
29. Deleted					
30. Deleted					
31. Seismic Monitors	R	R	NA	NA	
32. Coolant Flow - RTD Bypass Flowmeter	S	R	M	NA	
33. CRDM Cooling Shroud	S	NA	R	NA	FSAR page 3.2-56
34. Reactor Gap Exhaust Air Temperature	S	NA	R	NA	
35a. Post-Accident Monitoring Instruments	M	R	NA	NA	Includes all those in Table TS.3.15-1 (except for containment hydrogen monitors which are separately specified in this table)
b. Post-Accident Monitoring Radiation Instruments	D	R	M	NA	Includes all those in Table TS.3.15-2
c. Post-Accident Monitoring Reactor Vessel Level Instrumentation	M	R	NA	NA	Includes all those in Table TS.3.15-3
36. Steam Exclusion Actuation System	W	Y	M	NA	See FSAR Appendix I, Section I.14.5
37. Overpressure Mitigation System	NA	R	R	NA	Instrument Chann.'s for PORV Control Including Overpressure Mitigation System

SEE NEW TABLES TS.4.1-1A THROUGH TS.4.1-1C

Table TS.4.1-1  
Page 4 of 5  
REV 78 8/26/86

TABLE TS.4.1-1 (Page 5 of 5)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND  
TEST OF INSTRUMENT CHANNELS

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Functional Test</u>	<u>Response Test</u>	<u>Remarks</u>
38. Degraded Voltage 4 KV Safeguard Busses	NA	R	M	NA	
39. Loss of Voltage 4 KV Safeguard Busses	NA	R	M	NA	
40. Auxiliary Feedwater Pump Suction Pressure	NA	R	R	NA	
41. Auxiliary Feedwater Pump Discharge Pressure	NA	R	R	NA	
42. NaOH Caustic Stand Pipe Level	W	R	M	NA	
Control Room Ventilation System Chlorine Monitors	S	Y	M(1)	NA	
44. Hydrogen Monitors	S	Q(2)	M	NA	
45. Containment Temperature Monitors	M	R	NA	NA	

S - Shift

D - Daily

W - Weekly

M - Monthly

Q - Quarterly

P - Prior to each startup if not done previous week

T - Prior to each startup following shutdown, in excess of 2 days if not done in the previous 30 days

Y - Yearly

R - Each refueling shutdown

NA - Not applicable

\* See Specification 4.1.D

(1) Verification of the chlorine monitor control logic only.

(2) Test will be conducted per manufacturer's recommendations.

\*\* (NSP Note: Not effective for Unit 2 shunt trip circuitry until Unit 2 Cycle 10 startup)

SEE NEW TABLES TS.4.1-1A THROUGH TS.4.1-1C

Table TS.4.1-1  
(Page 5 of 5)  
REV 75 6/26/05



TABLE TS.4.1-1A (Page 1 of 5)

## REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	R <sup>(13)</sup>	N.A.	A, B, C <sup>(11)</sup> , D <sup>(11)</sup> , E <sup>(11)</sup>
2. Power Range, Neutron Flux					
a) High Setpoint	S	D <sup>(5, 7)</sup> M <sup>(6, 7)</sup> Q <sup>(7, 8)</sup>	Q <sup>(18)</sup>	R	A, B
b) Low Setpoint	S	R <sup>(7)</sup>	S/U <sup>(17)</sup>	R	A <sup>(3)</sup> , B
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R <sup>(7)</sup>	Q	R	A, B
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R <sup>(7)</sup>	Q	R	A, B
5. Intermediate Range, Neutron Flux	S	R <sup>(7)</sup>	S/U <sup>(4)</sup>	R	A <sup>(3)</sup> , B
6. Source Range, Neutron Flux					
a. Startup	S	R <sup>(7)</sup>	S/U <sup>(4)</sup>	R	B <sup>(2)</sup>
b. Shutdown	S	R <sup>(7)</sup>	Q <sup>(10)</sup>	R	C <sup>(11)</sup> , D <sup>(11)</sup> , E <sup>(11)</sup>
7. Overtemperature $\Delta T$	S	R	Q	R	A, B
8. Overpower $\Delta T$	S	R	Q	R	A, B

TABLE 4.1-1A (Page 2 of 5)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
9. Low Pressurizer Pressure	S	R	Q	N.A.	A
10. High Pressurizer Pressure	S	R	Q	N.A.	A, B
11. Pressurizer High Water Level	S	R	Q	N.A.	A
12. Reactor Coolant Flow Low	S	P	Q	N.A.	A
13. Turbine Trip					
a. Low AST Oil Pressure	N.A.	R	S/U <sup>(4, 11)</sup>	N.A.	A
b. Turbine Stop Valve Closure	N.A.	R	S/U <sup>(4, 11)</sup>	N.A.	A
14. Lo-Lo Steam Generator Water Level	S	R	Q	N.A.	A, B
15. Undervoltage 4KV RCP Bus	N.A.	R	Q	N.A.	A

TABLE TS.4.1-1A (Page 3 of 5)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
16. Loss of Reactor Coolant Pump					
a. RCP Breaker Open	N.A.	R	S/U <sup>(4)</sup>	N.A.	A
b. Underfrequency 4KV Bus	N.A.	R	Q	N.A.	A
17. Safety Injection Input	N.A.	N.A.	R	N.A.	A, B
18. Automatic Trip and Interlock Logic	N.A.	N.A.	M <sup>(9)</sup>	R	A, B, C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
19. Reactor Trip Breakers	N.A.	N.A.	M <sup>(9), 12)</sup>	R	A, B, C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
20. Reactor Trip Bypass Breakers	N.A.	N.A.	M <sup>(14)</sup>	R <sup>(15)</sup>	See Note (16)

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
M	Monthly
Q	Quarterly
S/U	Prior to each reactor startup
R	Each Refueling Shutdown
N.A.	Not applicable.

TABLE NOTATION

- |  |   |
|--|---|
| <p>(1) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.</p> <p>(2) Below P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.</p> <p>(3) Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.</p> <p>(4) Prior to each startup following shutdown in excess of two days if not done in previous 30 days.</p> <p>(5) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%.</p> | <p>(6) Single point comparison of incore to excore for axial off-set above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than 2%.</p> <p>(7) Neutron detectors may be excluded from CHANNEL CALIBRATION.</p> <p>(8) Incore - Excore Calibration, above 75% of RATED THERMAL POWER.</p> <p>(9) Each train shall be tested at least every two months on a STAGGERED TEST BASIS.</p> |
|--|---|

TABLE 4.1-1A (Page 5 of 5)

TABLE NOTATIONS Continued

TABLE NOTATION (Continued)

(10) Quarterly surveillance in MODES 3, 4 and 5 shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window.	(17) Prior to each startup if not done previous week.
(11) Setpoint verification is not applicable.	(18) Including quadrant power tilt monitor.
(12) The Functional Test shall independently verify the OPERABILITY of the undervoltage and shunt trip attachments of the Reactor Trip Breakers.	
(13) The Functional Test shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the Manual Reactor Trip Function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit(s).	
(14) Manually trip the undervoltage trip attachment remotely (i.e., from the protection system racks).	
(15) Automatic undervoltage trip.	
(16) Whenever the Reactor Trip Bypass Breakers are racked in and closed for bypassing a Reactor Trip Breaker and the Control Rod Drive System is capable of rod withdrawal.	

TABLE TS.4.1-1B (Page 1 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. SAFETY INJECTION					
a. Manual Initiation	N.A.	N.A.	R <sup>(1)</sup>	N.A.	A, B, C, D
b. High Containment Pressure	S	R	Q	N.A.	A, B, C, D
c. Steam Generator Low Steam Pressure/Loop	S	R	Q	N.A.	A, B, C <sup>(2)</sup>
d. Pressurizer Low Pressure	S	R	Q	N.A.	A, B, C <sup>(2)</sup>
e. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D
2. CONTAINMENT SPRAY					
a. Manual Initiation	N.A.	N.A.	R	N.A.	A, B, C, D
b. Hi-Hi Containment Pressure	S	R	Q	N.A.	A, B, C, D
c. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D

TABLE TS.4.1-1B (Page 2 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
3. CONTAINMENT ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
b. Manual	N.A.	N.A.	F	N.A.	A, B, C, D
c. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D
4. CONTAINMENT VENTILATION ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
b. Manual	N.A.	N.A.	R	N.A.	See Note (8)
c. Manual Containment Spray	See 2a above for all Manual Containment Spray Surveillance Requirements				
d. Manual Containment Isolation	See 3b above for all Manual Containment Isolation Surveillance Requirements				
e. High Radiation in Exhaust Air	D <sup>(7)</sup>	R	M	N.A.	See Note (8)
f. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	See Note (8)

TABLE TS.4.1-1B (Page 3 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
5. STEAM LINE ISOLATION					
a. Manual	N.A.	N.A.	R	N.A.	A, B, C, D <sup>(4)</sup>
b. Hi-Hi Containment Pressure	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
c. Hi-Hi Steam Flow with Safety Injection					
1. Hi-Hi Steam Flow	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
2. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
d. Hi Steam Flow and 2 of 4 Low T <sub>avg</sub> with Safety Injection					
1. Hi Steam Flow	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
2. Tave	S	R	Q	N.A.	A, B, C, D <sup>(6)</sup>
3. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
e. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D <sup>(4)</sup>



TABLE TS.4.1-1B (Page 4 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
6. FEEDWATER ISOLATION					
a. Hi-Hi Steam Generator Level	S	R	Q	N.A.	A, B
b. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
c. Reactor Trip with 2 of 4 Low $T_{avg}$ (Main Valves Only)					
1. Reactor Trip	N.A.	N.A.	R	N.A.	A, B
2. Tave	S	R	Q	N.A.	A, B
d. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B

TABLE TS.4.1-1B (Page 5 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
7. AUXILIARY FEEDWATER					
a. Manual	N.A.	N.A.	R	N.A.	A, B, C, D <sup>(5)</sup>
b. Steam Generator Low-Low Water Level	S	R	Q	N.A.	A, B, C, D <sup>(5)</sup>
c. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2; 21 and 22) (Start Turbine Driven Pump only)	N.A.	R	R	N.A.	A, B
d. Trip of Main Feedwater Pumps					
1. Turbine Driven	N.A.	N.A.	R	N.A.	A, B
2. Motor Driven	N.A.	N.A.	R	N.A.	A, B
e. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
f. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D <sup>(5)</sup>

TABLE TS.4.1-1B (Page 6 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
8. LOSS OF POWER					
a. Loss of Voltage (90%) Coincident with Degraded Voltage (90%) or Loss of Voltage (55%) Coincident with Degraded Voltage (90%)					
1. Loss of Voltage 4kv Safeguards Bus (90%)	N.A.	R	M	N.A.	A, B, C, D
2. Loss of Voltage 4kv Safeguards Bus (55%)	N.A.	R	M	N.A.	A, B, C, D
3. Degraded Voltage 4kv Safeguards Bus (90%)	N.A.	R	M	N.A.	A, B, C, D

TABLE 4.1-1B (Page 7 of 7)

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
M	Monthly
Q	Quarterly
R	Each Refueling Shutdown
N.A.	Not Applicable

TABLE NOTATION

- |   |  |
|---|--|
| <p>(1) One manual switch shall be tested at each refueling on a STAGGERED TEST BASIS.</p> <p>(2) Trip function may be blocked in this MODE below a reactor coolant system pressure of 2000 psig.</p> <p>(3) Each train shall be tested at least every two months on a STAGGERED TEST BASIS.</p> <p>(4) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.</p> <p>(5) When reactor coolant system average temperature is greater than 350°F.</p> <p>(6) When reactor coolant system average temperature is greater than 520°F and either main steam isolation valve is open.</p> | <p>(7) See Table 4.17-1.</p> <p>(8) Whenever CONTAINMENT INTEGRITY is required and either of the containment purge systems are in operation.</p> |
|---|--|

TABLE TS.4.1-1C (Page 1 of 4)

MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Control Rod Insertion Monitor	M	R	S/U <sup>(1)</sup>	N.A.	A, B
2. Analog Rod Position	S	R	S/U <sup>(1)</sup>	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
3. Rod Position Deviation Monitor	M	N.A.	S/U <sup>(1)</sup>	N.A.	A, B
4. Rod Position Bank Counters	S <sup>(3)</sup>	N.A.	N.A.	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
5. Charging Flow	S	R	N.A.	N.A.	A, B, C, D
6. Residual Heat Removal Pump Flow	S	R	N.A.	N.A.	D <sup>(2)</sup> , E <sup>(2)</sup> , F <sup>(2)</sup>
7. Boric Acid Tank Level	D	R <sup>(4)</sup>	M <sup>(4)</sup>	N.A.	A, B, C, D
8. Refueling Water Storage Tank Level	W	R	M	N.A.	A, B, C, D
9. Volume Control Tank	S	R	N.A.	N.A.	A, B, C, D
10. Annulus Pressure (Vacuum Breaker)	N.A.	R	R	N.A.	See Note (12)
11. Auto Load Sequencers	N.A.	N.A.	M	N.A.	A, B, C, D
12. Boric Acid Make-up Flow Channel	N.A.	R	N.A.	N.A.	A, B, C, D

TABLE TS.4.1-1C (Page 2 of 4)

MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
13. Containment Sump A, B and C Level	N.A.	R	R	N.A.	A, B, C, D
14. Accumulator Level and Pressure	S	R	R	N.A.	A, B, C, D
15. Turbine First Stage Pressure	S	R	M	N.A.	A
16. Emergency Plan Radiation Instruments <sup>(6)</sup>	M	R	M	N.A.	A, B, C, D, E, F
17. Seismic Monitors	R	R	N.A.	N.A.	A, B, C, D, E, F
18. Coolant Flow - RTD Bypass Flowmeter	S	R	M	N.A.	A, B, C, D <sup>(5)</sup>
19. CRDM Cooling Shroud	S	N.A.	R	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
20. Reactor Gap Exhaust Air Temperature	S	N.A.	R	N.A.	A, B, C, D
21. Post-Accident Monitoring Instruments (Table TS.3.15-1) <sup>(7)</sup>	M	R	N.A.	N.A.	A, B
22. Post-Accident Monitoring Radiation Instruments (Table TS.3.15-2)	D	R	M	N.A.	A, B

TABLE TS.4.1-1C (Page 3 of 4)

MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
23. Post-Accident Monitoring Reactor Vessel Level Instrumentation (Table TS.3.15-3)	M	R	N.A.	N.A.	A, B
24. Steam Exclusion Actuation	W	Y	M	N.A.	A, B, C, D <sup>(10)</sup>
25. Overpressure Mitigation	N.A.	R	R	N.A.	D <sup>(11)</sup> , E
26. Auxiliary Feedwater Pump Suction Pressure	N.A.	R	R	N.A.	A, B, C, D <sup>(10)</sup>
27. Auxiliary Feedwater Pump Discharge Pressure	N.A.	R	R	N.A.	A, B, C, D <sup>(10)</sup>
28. NaOH Caustic Stand Pipe Level	W	R	M	N.A.	A, B, C, D
29. Control Room Ventilation System Chlorine Monitors	S	Y	M <sup>(8)</sup>	N.A.	A, B, C, D, E, F
30. Hydrogen Monitors	S	Q	N	N.A.	A, B
31. Containment Temperature Monitors	M	R	N.A.	N.A.	A, B, C, D
32. Turbine Overspeed Protection Trip Channel	N.A.	R	M	N.A.	A

TABLE TS.4.1-1C  
(Page 3 of 4)  
REV

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
W	Weekly
M	Monthly
Q	Quarterly
S/U	Prior to each startup
Y	Yearly
R	Each refueling shutdown
N.A.	Not applicable

TABLE NOTATION

- |   |   |
|---|---|
| <p>(1) Prior to each startup following shutdown in excess of two days if not done in previous 30 days.</p> <p>(2) When the reactor trip system breakers are closed and the control rod drive system is capable of rod withdrawal.</p> <p>(3) Following rod motion in excess of six inches when the computer is out of service.</p> <p>(4) Transfer logic to Refueling Water Storage Tank.</p> <p>(5) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.</p> | <p>(6) Includes those instruments named in the emergency procedure.</p> <p>(7) Except for containment hydrogen monitors which are separately specified in this table.</p> <p>(8) Verification of the chlorine monitor control logic only.</p> <p>(9) When RHR is in operation.</p> <p>(10) When the reactor coolant system average temperature is greater than 350°F.</p> <p>(11) When the reactor coolant system average temperature is less than 310°F.</p> <p>(12) Whenever CONTAINMENT INTEGRITY is required.</p> |
|---|---|



TABLE TS.4.1-2B

MINIMUM FREQUENCIES FOR SAMPLING TESTS

<u>TEST</u>	<u>FREQUENCY</u>	<u>FSAR Section Reference</u>
1. RCS Gross Activity Determination	5/week	
2. RCS Isotopic Analysis for DOSE EQUIVALENT I-131 Concentration	1/14 days (when at power)	
3. RCS Radiochemistry $\bar{E}$ determination	1/6 months(1) (when at power)	
4. RCS Isotopic Analysis for Iodine Including I-131, I-133, and I-135	a) Once per 4 hours, whenever the specific activity exceeds 1.0 uCi/gram DOSE EQUIVALENT I-131 or 100/ $\bar{E}$ uCi/gram (at or above cold shutdown), and  b) One sample between 2 and 6 hours following THERMAL POWER change exceeding 15 percent of the RATED THERMAL POWER within a one hour period ( above hot shutdown)	
5. RCS Radiochemistry (2)	Monthly	
6. RCS Tritium Activity	Weekly	
7. RCS Chemistry (Cl*, F*, O2)	5/Week	
8. RCS Boron Concentration*(3)	2/Week (4)	9.2
9. RWST Boron Concentration	Weekly	
10. Boric Acid Tanks Boron Concentration	2/Week	
11. Caustic Standpipe NaOH Concentration	Monthly	6.4
12. Accumulator Boron Concentration	Monthly	6
13. Spent Fuel Pit Boron Concentration	Monthly (7)	9.5.5

\* Required at all times.

TABLE TS.4.1-2B

MINIMUM FREQUENCIES FOR SAMPLING TESTS

<u>TEST</u>	<u>FREQUENCY</u>	<u>FSAR Section Reference</u>
14. Secondary Coolant Gross Beta-Gamma activity	Weekly	
15. Secondary Coolant Isotopic Analysis for DOSE EQUIVALENT I-131 concentration	1/6 months (5)	
16. Secondary Coolant Chemistry		
pH	5/week (6)	
pH Control Additive	5/week (6)	
Sodium	5/week (6)	

Notes:

1. Sample to be taken after a minimum of 2 EFPD and 20 days of POWER OPERATION have elapsed since reactor was last subcritical for 48 hours or longer.
2. To determine activity of corrosion products having a half-life greater than 30 minutes.
3. During REFUELING, the boron concentration shall be verified by chemical analysis daily.
4. The maximum interval between analyses shall not exceed 5 days.
5. If activity of the samples is greater than 10% of the limit in Specification 3.4.D, the frequency shall be once per month.
6. The maximum interval between analyses shall not exceed 3 days.
7. The minimum spent fuel pool boron concentration from Specification 3.8.B.1.b shall be verified by chemical analysis weekly while a spent fuel cask containing fuel is located in the spent fuel pool.

\* ~~See Specification 4.1.D~~

## 2.3 LIMITING SAFETY SYSTEM SETTINGS, PROTECTIVE INSTRUMENTATION

### Bases continued

The overpower and overtemperature protection setpoints include the effects of fuel densification on core safety limits.

A loss of coolant flow incident can result from a mechanical or electrical failure in one or more reactor coolant pumps, or from a fault in the power supply to these pumps. If the reactor is at power at the time of the incident, the immediate effect of loss of coolant flow is a rapid increase in coolant temperature. This increase could result in departure from nucleate boiling (DNB) with subsequent fuel damage if the reactor is not tripped promptly. The following trip circuits provide the necessary protection against a loss of coolant flow incident:

- a. Low reactor coolant flow
- b. Low voltage on pump power supply bus
- c. Pump circuit breaker opening (low frequency on pump power supply bus opens pump circuit breaker)

The low flow reactor trip protects the core against DNB in the event of either a decreasing actual measured flow in the loops or a sudden loss of ~~power to~~ one or both reactor coolant pumps. The set point specified is consistent with the value used in the accident analysis (Reference 7). The low loop flow signal is caused by a condition of less than 90% flow as measured by the loop flow instrumentation.

The reactor coolant pump bus undervoltage trip is a direct reactor trip (not a reactor coolant pump circuit breaker trip) which protects the core against DNB in the event of a loss of power to the reactor coolant pumps. The set point specified is consistent with the value used in the accident analysis (Reference 7).

~~The loss of power signal reactor coolant pump breaker reactor trip~~ is caused by the reactor coolant pump breaker opening as actuated by either high current, low supply voltage or low electrical frequency, or by a manual control switch. The significant feature of the reactor coolant pump breaker reactor trip is the frequency set point,  $\geq 58.2$  cps, which assures a trip signal before the pump inertia is reduced to an unacceptable value.

The high pressurizer water level reactor trip protects the pressurizer safety valves against water relief. The specified set point allows adequate operating instrument error (Reference 2) and transient level overshoot beyond their trip setting so that the trip function prevents the water level from reaching the safety valves.

The low-low steam generator water level reactor trip protects against loss of feedwater flow accidents. The specified set point assures that there will be sufficient water inventory in the steam generators at the time of trip to allow for starting delays for the auxiliary feedwater system (Reference 8).

## 2.3 LIMITING SAFETY SYSTEM SETTINGS, PROTECTIVE INSTRUMENTATION

### Bases continued

The specified reactor trips are blocked at low power where they are not required for protection and would otherwise interfere with normal plant operations. The prescribed set point above which these trips are unblocked assure their availability in the power range where needed. The reactor trips related to loss of one or both reactor coolant pumps are unblocked at approximately 10% of RATED THERMAL POWER.

The other reactor trips specified in 2.3.A.3. above provide additional protection. The safety injection signal trips the reactor to decrease the severity of the accident condition. The reactor is tripped when the turbine generator trips above a power level equivalent to the load rejection capacity of the steam dump valves. This reduces the severity of the loss-of-load transient.

The positive power range rate trip provides protection against rapid flux increases which are characteristic of rod ejection events from any power level. Specifically, this trip compliments the power range nuclear flux high and low trip to assure that the criteria are met for rod ejection from partial power.

The negative power range rate trip provides protection against DNB for control rod drop accidents. Most rod drop events will cause a sufficiently rapid decrease in power to trip the reactor on the negative power range rate trip signal. Any rod drop events which do not insert enough reactivity to cause a trip are analyzed to ensure that the core does not experience DNB. Administrative limits in Specification 3.10 require a power reduction if design power distribution limits are exceeded by a single misaligned or dropped rod.

### References

1. USAR, Section 14.4.1
2. USAR, Section 14.3
3. USAR, Section 14.6.1
4. USAR, Section 14.4.1
5. USAR, Section 7.4.1.1 7.2
6. USAR, Section 3.3.2
7. USAR, Section 14.4.8
8. USAR, Section 14.1.10

### 3.5 INSTRUMENTATION SYSTEM

#### Bases

Instrumentation has been provided to sense accident conditions and to initiate reactor trip and operation of the Engineered Safety Features (Reference 1). The OPERABILITY of the Reactor Trip System and the Engineered Safety System instrumentation and interlocks ensures that: (1) the associated ACTION and/or reactor trip will be initiated when the parameter monitored by each channel or combination thereof reaches its setpoint, (2) the specified coincidence logic and sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance consistent with maintaining an appropriate level of reliability of the Reactor Protection and Engineered Safety Features instrumentation and, (3) sufficient system functions capability is available from diverse parameters.

The OPERABILITY of these systems is required to provide the overall reliability, redundancy and diversity assumed available in the facility design for the protection and mitigation of accident and transient conditions. The integrated operation of each of these systems is consistent with the assumptions used in the safety analysis.

Specified surveillance and maintenance outage times have been determined in accordance with WCAP-10271, "Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation System", and supplements to that report. Out of service times were determined based on maintaining an appropriate level of reliability of the Reactor Protection System and Engineered Safety Features instrumentation.

The evaluation of surveillance frequencies and out of service times for the reactor protection and engineered safety feature instrumentation described in WCAP-10271 included the allowance for testing in bypass. The evaluation assumed that the average amount of time the channels within a given trip function would be in bypass for testing was 4 hours.

#### Safety Injection

The Safety Injection System is actuated automatically to provide emergency cooling and reduction of reactivity in the event of a loss-of-coolant accident or a steam line break accident.

Safety injection in response to a loss-of-coolant accident (LOCA) is provided by a high containment pressure signal backed up by the low pressurizer pressure signal. These conditions would accompany the depressurization and coolant loss during a LOCA.

Safety injection in response to a steam line break is provided directly by a low steam line pressure signal, backed up by the low pressurizer pressure signal and, in case of a break within the containment, by the high containment pressure signal.

The safety injection of highly borated water will offset the temperature-induced reactivity addition that could otherwise result from cooldown following a steam line break.

### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

##### Containment Spray

Containment sprays are also actuated by a high containment pressure signal (Hi-Hi) to reduce containment pressure in the event of a loss-of-coolant or steam line break accident inside the containment.

The containment sprays are actuated at a higher containment pressure (approximately 50% of design containment pressure) than is safety injection (10% of design). Since spurious actuation of containment spray is to be avoided, it is initiated on coincidence of high containment pressure sensed by three sets of one-out-of-two containment pressure signals provided for its actuation.

##### Containment Isolation

A containment isolation signal is initiated by any signal causing automatic initiation of safety injection or may be initiated manually. The containment isolation system provides the means of isolating the various pipes passing through the containment walls as required to prevent the release of radioactivity to the environment in the event of a loss-of-coolant accident.

##### Steam Line Isolation

In the event of a steam line break, the steam line stop valve of the affected line is automatically isolated to prevent continuous, uncontrolled steam release from more than one steam generator. The steam lines are isolated on high containment pressure (Hi-Hi) or high steam line flow in coincidence with low  $T_{avg}$  and safety injection or high steam flow (Hi-Hi) in coincidence with safety injection. Adequate protection is afforded for breaks inside or outside the containment even when it is assumed that the steam line check valves do not function properly.

##### Containment Ventilation Isolation

Valves in the containment purge and inservice purge systems automatically close on receipt of a Safety Injection signal or a high radiation signal. Gaseous and particulate monitors in the exhaust stream or a gaseous monitor in the exhaust stack provide the high radiation signal.

##### Ventilation System Isolation

In the event of a high energy line rupture outside of containment, redundant isolation dampers in certain ventilation ducts are closed (Reference 4).



### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

#### Safeguards Bus Voltage

Relays are provided on buses 15, 16, 25, and 26 to detect loss of voltage and degraded voltage (the voltage level at which safety related equipment may not operate properly). On loss of voltage, the automatic voltage restoring scheme is initiated immediately. When degraded voltage is sensed, the voltage restoring scheme is initiated if acceptable voltage is not restored within a short time period. This time delay prevents initiation of the voltage restoring scheme when large loads are started and bus voltage momentarily dips below the degraded voltage setpoint.

#### Auxiliary Feedwater System Actuation

Following signals automatically start the pumps and open the steam admission control valve to the turbine driven pump of the affected unit:

1. Low-low water level in either steam generator
2. Trip of both main feedwater pumps
3. Safety Injection signal
4. Undervoltage on both 4.16 kV normal buses (turbine driven pump only)

Manual control from both the control room and the Hot Shutdown Panel are also available. The design provides assurance that water can be supplied to the steam generators for decay heat removal when the normal feedwater system is not available.

#### Underfrequency 4kV Bus

The underfrequency 4kV bus trip does not provide a direct reactor trip signal to the reactor protection system. A reactor coolant pump bus underfrequency signal from both buses provides a trip signal to both reactor coolant pump breakers. Trip of the reactor coolant pump breakers results in a reactor trip. The underfrequency trip protects against postulated flow coastdown events.

#### Limiting Instrument Setpoints

1. The high containment pressure limit is set at about 10% of the maximum internal pressure. Initiation of Safety Injection protects against loss of coolant (Reference 2) or steam line break accidents as discussed in the safety analysis.
2. The Hi-Hi containment pressure limit is set at about 50% of the maximum internal pressure for initiation of containment spray and at about 30% for initiation of steam line isolation. Initiation of Containment Spray and Steam Line Isolation protects against large loss of coolant (Reference 2) or steam line break accidents (Reference 3) as discussed in the safety analysis.
3. The pressurizer low pressure limit is set substantially below system operating pressure limits. However, it is sufficiently high to protect against a loss of coolant accident as shown in the safety analysis (Reference 2).

## 5.5 INSTRUMENTATION SYSTEM

BASES continued

### Limiting Instrument Setpoints (continued)

4. The steam line low pressure signal is lead/lag compensated and its set-point is set well above the pressure expected in the event of a large steam line break accident as shown in the safety analysis (Reference 3).
5. The high steam line flow limit is set at approximately 20% of nominal full-load flow at the no-load pressure and the high-high steam line flow limit is set at approximately 120% of nominal full-load flow at the full load pressure in order to protect against large steam break accidents. The coincident low  $T_{avg}$  setting limit for steam line isolation initiation is set below its hot shutdown value. The safety analysis shows that these settings provide protection in the event of a large steam break (Reference 3).
6. Steam generator low-low water level and 4.16 kV Bus 11 and 12 (21 and 22 in Unit 2) low bus voltage provide initiation signals for the Auxiliary Feedwater System. Selection of these setpoints is discussed in the Bases of Section 2.3 of the Technical Specification.
7. High radiation signals providing input to the Containment Ventilation Isolation circuitry are set in accordance with the Radioactive Effluent Technical Specifications. The setpoints are established to prevent exceeding the limits of 10 CFR Part 20 at the SITE BOUNDARY.
8. The degraded voltage protection setpoint is  $90 \pm 2\%$  of nominal 4160 V bus voltage. Testing and analysis have shown that all safeguards loads will operate properly at or above the degraded voltage setpoint. The degraded voltage protection time delay of  $6 \pm 2$  seconds has been shown by testing and analysis to be long enough to allow for voltage dips resulting from the starting of large loads. This time delay is also consistent with the maximum time delay assumed in the ECCS analysis for starting of a safety injection pump. A maximum limit on the degraded voltage setpoint has been established to prevent unnecessary actuation of the voltage restoring scheme.

The loss of voltage protection setpoint is approximately 55% of nominal 4160 V bus voltage. Relays initiate a rapid (less than two seconds) transfer to an alternate source on loss of voltage.



### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

#### Instrument Operating Conditions

During plant operations, the complete instrumentation systems will normally be in service. Reactor safety is provided by the Reactor Protection System, which automatically initiates appropriate action to prevent exceeding established limits. Safety is not compromised, however, by continuing operation with certain instrumentation channels out of service since provisions were made for this in the plant design. This specification outlines limiting conditions for operation necessary to preserve the effectiveness of the Reactor Control and Protection System when any one or more of the channels is out of service.

Almost all reactor protection channels are supplied with sufficient redundancy to provide the capability for CHANNEL CALIBRATION and test at power. Exceptions are backup channels such as reactor coolant pump breakers. The removal of one trip channel on process control equipment is accomplished by placing that channel bistable in a tripped mode; e.g., a two-out-of-three circuit becomes a one-out-of-two circuit. The source and intermediate range nuclear instrumentation system channels are not intentionally placed in a tripped mode since these are one-out of-two trips, and the trips are therefore bypassed during testing. Testing does not trip the system unless a trip condition exists in a concurrent channel.

#### References

1. USAR, Section 7.4.2
2. USAR, Section 14.6.1
3. USAR, Section 14.5.5
4. FSAR, Appendix I

### 3.6 CONTAINMENT SYSTEM

#### Bases

Proper functioning of the Shield Building vent system is essential to the performance of the containment system. Therefore, except for reasonable periods of maintenance outage for one redundant chain of equipment, the system should be wholly in readiness whenever above 200°F. Proper functioning of the auxiliary building special vent system and isolation of the auxiliary building normal vent system are similarly necessary to preclude possible unfiltered leakage through penetrations that enter the special ventilation zone.

For a train of the Shield Building Ventilation System to be considered OPERABLE, the safety injection actuation input and the pressure difference input for recirculation damper control must be OPERABLE. For a train of the Auxiliary Building Special Ventilation System to be considered OPERABLE, the safety injection actuation input to start fans and to isolate the normal ventilation system must be OPERABLE.

The auxiliary building special ventilation zone and its associated ventilation system have been designed to serve as secondary containment following a loss of coolant accident (Reference 2). Special care was taken to design the access doors in the boundary and isolation valves in normal ventilation systems so that AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY can be intact during reactor operation. The zone can perform its accident function with openings if they can be closed within 6 minutes, since the accident analysis assumed direct leakage of primary containment atmosphere to the environs when the shield building is at positive pressure (6 minutes). As noted in Reference 2, part of the Shield Building is part of the Auxiliary Building Special Ventilation Zone Integrity. The part of the Shield Building which is part of the Auxiliary Building Special Ventilation Zone is subject to the Technical Specifications of the SHIELD BUILDING INTEGRITY and not those associated with AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY.

The action statement which allows SHIELD BUILDING INTEGRITY to be lost for 24 hours will allow for minor modifications to be made to the Shield Building during power operations.

The COLD SHUTDOWN condition precludes any energy release or buildup of containment pressure from flashing of reactor coolant in the event of a system break.

The shutdown margin for the COLD SHUTDOWN condition assures sub-criticality with the vessel closed, even if the most reactive rod control cluster assembly were inadvertently withdrawn.

The 2 psig limit on internal pressure provides adequate margin between the maximum internal pressure of 46 psig and the peak accident pressure resulting from the postulated Design Basis Accident (Reference 1).

The containment vessel is designed for 0.8 psi internal vacuum, the occurrence of which will be prevented by redundant vacuum breaker systems.

### 3.6 CONTAINMENT SYSTEM

#### Bases continued

The containment has a nil ductility transition temperature of 0°F. Specifying a minimum temperature of 30°F will provide adequate margin above NDTT during power operation when containment is required.

The conservative calculation of off-site doses for the loss of coolant accident (References 2, 4) is based on an initial shield building annulus air temperature of 60°F and an initial containment vessel air temperature < 104°F. The calculated period following LOCA for which the shield building annulus pressure is positive, and the calculated off-site doses are sensitive to this initial air temperature difference. The specified 44°F temperature difference is consistent with the LOCA accident analysis (Reference 4).

The initial testing of inleakage into the shield building and the auxiliary building special ventilation zone (ABSVZ) has resulted in greater specified inleakage (Figure TS.4.4-1, change No. 1) and the necessity to deenergize the turbine building exhaust fans in order to achieve a negative pressure in the ABSVZ (TS.3.6.E.2). The staff's conservative calculation of doses for these conditions indicated that changing allowable containment leak rate from 0.5% to 0.25%/day would offset the increased leakage (Reference 3).

High efficiency particulate absolute (HEPA) filters are installed before the charcoal adsorbers to prevent clogging of the iodine adsorbers for all emergency air treatment systems. The Charcoal adsorbers are installed to reduce the potential release of radioiodine to the environment.

The operability of the equipment and systems required for the control of hydrogen gas ensures that this equipment will be available to maintain the hydrogen concentration within containment below its flammable limit during post-LOCA conditions. Either recombiner unit is capable of controlling the expected hydrogen generation associated with (1) zirconium-water reactions, (2) radiolytic decomposition of water, and (3) corrosion of metals within containment. These hydrogen control systems are consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA", March 1971.

Air locks are provided with two doors, each of which is designed to seal against the maximum containment pressure resulting from the limiting DBA. Should an air lock become inoperable as a result of an inoperable air lock door or an inoperable door interlock, power operation may continue provided that at least one OPERABLE air lock door is closed. With an air lock door inoperable, access through the closed or locked OPERABLE door is only permitted for repair of inoperable air lock equipment.

### 3.6 CONTAINMENT SYSTEM

#### Bases continued

OPERABILITY of air locks is required to ensure that CONTAINMENT INTEGRITY maintained. Should an air lock become inoperable for reasons other than an inoperable air lock door, the air lock leak tight integrity must be restored within 24 hours or actions must be taken to place the unit in a condition for which CONTAINMENT INTEGRITY is not required.

#### References

1. USAR, Section 5
2. USAR, Section 10.3.4 and FSAR Appendix G
3. Letter to NSP dated November 29, 1973
4. Letter to NSP dated September 16, 1974

### 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

#### Bases

Throughout the 3.10 Technical Specifications, the terms "rod(s)" and "RCCA(s)" are synonymous.

#### A. Shutdown Margin

~~Trip shutdown reactivity is provided consistent with plant safety analyses assumptions. One percent shutdown margin is adequate except for the steam break analysis, which requires more shutdown reactivity due to the more negative moderator temperature coefficient at end of life (when boron concentration is low). Figure TS.3.10-1 is drawn accordingly.~~

A sufficient shutdown margin ensures that: (1) the reactor can be made subcritical from all operating conditions, (2) the reactivity transients associated with postulated accident conditions are controllable within acceptable limits, and (3) the reactor will be maintained sufficiently subcritical to preclude inadvertent criticality in the shutdown condition.

Shutdown Margin requirements vary throughout core life as a function of fuel depletion, reactor coolant system boron concentration and reactor coolant average temperature. The most restrictive condition occurs at end of life and is associated with a postulated steam line break accident and resulting uncontrolled reactor coolant system cooldown. In the analysis of this accident, a minimum Shutdown Margin as defined by Figure TS.3.10-1 is required to control the reactivity transient. Accordingly, the Shutdown Margin requirement is based upon this limiting condition and is consistent with plant safety analysis assumptions. With reactor coolant system average temperature less than 200°F, the reactivity transients resulting from a postulated steam line break cooldown are minimal and a 1%  $\Delta k/k$  Shutdown Margin provides adequate protection.

#### B. Power Distribution Control

The specifications of this section provide assurance of fuel integrity during Condition I (Normal Operations) and II (Incidents of Moderate frequency) events. (a) maintaining the minimum DNER in the core of greater than or equal to 1.30 for Exxon fuel and 1.17 for Westinghouse fuel during normal operation and in short term transients, and (b) limiting the fission gas release, fuel pellet temperature and cladding mechanical properties to within assumed design criteria. The ECCS analysis was performed in accordance with SECY 83-472. One calculation at the 95% probability level was performed as well as one calculation with all the required features of 10 CFR Part 50, Appendix K. The 95% probability level calculation used the peak linear heat generation rate specified in the CORE OPERATING LIMITS REPORT. The Appendix K calculation used the peak linear heat generation rate specified in the CORE OPERATING LIMITS REPORT for the  $F_Q$  limit specified in the CORE OPERATING LIMITS REPORT. Maintaining 1) peaking factors below the  $F_Q$  limit specified in the CORE OPERATING LIMITS REPORT during all Condition I events and 2) the peak linear heat generation rate below the value specified in the CORE OPERATING LIMITS REPORT at the 95% probability level assures compliance with the ECCS analysis.

### 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

Bases continued

#### B. Power Distribution Control (continued)

During operation, the plant staff compares the measured hot channel factors,  $F_{HQ}^N$  and  $F_{\Delta H}^N$ , (described later) to the limits determined in the transient and LOCA analyses. The terms on the right side of the equations in Section 3.10.B.1 represent the analytical limits. Those terms on the left side represent the measured hot channel factors corrected for engineering, calculational, and measurement uncertainties.

$F_{HQ}^N$  is the measured Nuclear Hot Channel Factor, defined as the maximum local heat flux on the surface of a fuel rod divided by the average heat flux in the core. Heat fluxes are derived from measured neutron fluxes and fuel enrichment.

The  $K(Z)$  function specified in the CORE OPERATING LIMITS REPORT is a normalized function that limits  $F_{HQ}^N$  axially. The  $K(Z)$  value is based on large and small break LOCA analyses.

$V(Z)$  is an axially dependent function applied to the equilibrium measured  $F_{HQ}^N$  to bound  $F_{HQ}^N$ 's that could be measured at non-equilibrium conditions. This function is based on power distribution control analyses that evaluated the effect of burnable poisons, rod position, axial effects, and xenon worth.

$F_{HQ}^E$ , Engineering Heat Flux Hot Channel Factor, is defined as the allowance on heat flux required for manufacturing tolerances. The engineering factor allows for local variations in enrichment, pellet density and diameter, surface area of the fuel rod and eccentricity of the gap between pellet and clad. Combined statistically the net effect is a factor of 1.03 to be applied to fuel rod surface heat flux.

The 1.05 multiplier accounts for uncertainties associated with measurement of the power distribution with the movable incore detectors and the use of those measurements to establish the assembly local power distribution.

$F_{HQ}^N$  (equil) is the measured limiting  $F_{HQ}^N$  obtained at equilibrium conditions during target flux determination.

$F_{\Delta H}^N$ , Nuclear Enthalpy Rise Hot Channel Factor, is defined as the ratio of the integral of linear power along the rod with the highest integrated power to the average rod power.



#### 4.1 OPERATIONAL SAFETY REVIEW

##### Bases

##### CHANNEL CHECK

Failures such as blown instrument fuses, defective indicators, faulted amplifiers which result in "upscale" or "downscale" indication can be easily recognized by simple observation of the functioning of an instrument or system. Furthermore, such failures are, in many cases, revealed by alarm or annunciator action, and a check supplements this type of built-in surveillance.

Based on experience in operation of both conventional and nuclear plant systems, when the plant is in operation, the minimum checking frequencies set forth are deemed adequate for reactor and steam system instrumentation.

##### CHANNEL CALIBRATION

Calibration is performed to ensure the presentation and acquisition of accurate information.

The nuclear flux (linear level) channels daily calibration against a thermal power calculation will account for errors induced by changing rod patterns and core physics parameters.

Other channels are subject only to the "drift" errors induced within the instrumentation itself and, consequently, can tolerate longer intervals between calibration. Process system instrumentation error induced by drift can be expected to remain within acceptable tolerances if recalibration is performed at intervals of each refueling shutdown.

Substantial calibration shifts within a channel (essentially a channel failure) will be revealed during routine checking and testing procedures.

##### CHANNEL FUNCTIONAL TESTS

The specified surveillance intervals for the Reactor Protection and Engineered Safety Features instrumentation have been determined in accordance with WCAP-10271, "Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation System", and supplements to that report. Surveillance intervals were determined based on maintaining an appropriate level of reliability of the Reactor Protection System and Engineered Safety Features instrumentation.

~~Minimum testing frequency is based on evaluation of unsafe failure rate data and reliability analysis. This is based on operating experience at conventional and nuclear plants.~~

## 4.1 OPERATIONAL SAFETY REVIEW

Bases continued

## Channel Functional Tests (continued)

An "unsafe failure" is defined as one which negates channel OPERABILITY and which, due to its nature, is revealed only when the channel is tested or attempts to respond to a bonafide signal. The minimum testing frequency for those instrument channels connected to the safety system is based on an average unsafe failure rate of  $2.5 \times 10^{-6}$  failure/hr per channel.

For a specified test interval  $W$  and an  $M$  out of  $N$  redundant system with identical and independent channels having a constant failure rate  $F$ , the average availability  $A$  is given by:

$$A = W \cdot Q \left( \frac{W}{N-M+2} \right) = 1 - \frac{N! (FW)^{N-M+1}}{(N-M+2)!(M-1)!}$$

where  $A$  is defined as the fraction of time during which the system is functional, and  $Q$  is the probability of failure of such a system during a time interval  $W$ .

For a 2-out-of-3 system  $A = 0.9999968$ , assuming a channel failure rate,  $F$ , equal to  $2.5 \times 10^{-6}$  hr<sup>-1</sup> and a test interval,  $W$ , equal to 720 hours.

This average availability of the 2-out-of-3 system is high, hence the test interval of one month is acceptable.

Because of their greater degree of redundancy, the 1/3 and 2/4 logic arrays provide an even greater measure of protection and are thereby acceptable for the same testing interval. Those items specified for monthly testing are associated with process components where other means of verification provide additional assurance that the channel is OPERABLE, thereby requiring less frequent testing.

## CHANNEL RESPONSE TESTS

Measurement of response times for protection channels are performed to assure response times within those assumed for accident analysis (USAR, Section 14).



Exhibit C

Prairie Island Nuclear Generating Plant

License Amendment Request Dated September 21, 1992

Revised Technical Specification Pages

Exhibit C consists of revised and new pages for the Prairie Island Nuclear Generating Plant Technical Specification with the proposed changes incorporated. The revised and new pages are listed below:

<u>REVISED PAGES</u>	<u>NEW PAGES</u>
TS.1-1	TABLE TS.1-1
TS.1-2	TABLE TS.3.5-2A (Pages 1 through 6)
TS.1-4	TABLE TS.3.5-2B (Pages 1 through 8)
TS.1-5	TABLE TS.4.1-1A (Pages 1 through 5)
TS.1-7	TABLE TS.4.1-1B (Pages 1 through 7)
TS.1-8	TABLE TS.4.1-1C (Pages 1 through 4)
TS.2.3-3	B.3.5-5
TS.2.3-4	B.3.6-3
TS.3.4-3	
TS.3.5-1	
TS.3.10-1	
TS.4.1-1	
TABLE TS.4.1-2B (Pages 1 and 2)	
B.2.3-2	
B.2.3-3	
B.3.5-1	
B.3.5-2	
B.3.5-3	
B.3.5-4	
B.3.6-1	
B.3.6-2	
B.3.10-1	
B.3.10-2	
B.4.1-1	

## 1.0 DEFINITIONS

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications.

### ACTION

ACTION shall be that part of a Specification which prescribes remedial measures required under designated conditions.

### AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY

AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY shall exist when:

1. Single doors in the Auxiliary Building Special Ventilation Zone are locked closed, and
2. At least one door in each Auxiliary Building Special Ventilation Zone air lock type passage is closed, and
3. The valves and actuation circuits that isolate the Auxiliary Building Normal Ventilation System following an accident are OPERABLE.
4. The Auxiliary Building Special Ventilation System is OPERABLE.

### CHANNEL CHECK

CHANNEL CHECK is a qualitative determination of acceptable OPERABILITY by observation of channel behavior during operation. This determination shall include comparison of the channel with other independent channels measuring the same variable.

### CHANNEL FUNCTIONAL TEST

A CHANNEL FUNCTIONAL TEST consists of injecting a simulated signal into the channel as close to the primary sensor as practicable to verify that it is OPERABLE, including alarm and/or trip initiating action.

### CHANNEL CALIBRATION

A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel such that it responds within the required range and accuracy to known values of input. The CHANNEL CALIBRATION shall encompass the entire channel including the sensors and alarm, interlock and/or trip functions and may be performed by any series of sequential, overlapping, or total channel steps such that the entire channel is calibrated.

### CHANNEL RESPONSE TEST

A CHANNEL RESPONSE TEST consists of injecting a simulated signal into the channel as near the sensor as practicable to measure the time for electronics and relay actions, including the output scram relay.

CONTAINMENT INTEGRITY

CONTAINMENT INTEGRITY shall exist when:

1. Penetrations required to be isolated during accident conditions are either:
  - a. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
  - b. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Specifications 3.6.C and 3.6.D.
2. Blind flanges required by Table TS.4.4-1 are installed.
3. The equipment hatch is closed and sealed.
4. Each air lock is in compliance with the requirements of Specification 3.6.M.
5. The containment leakage rates are within their required limits.

CORE ALTERATION

CORE ALTERATION is the movement or manipulation of any component within the reactor pressure vessel with the vessel head removed and fuel in the vessel, which may affect core reactivity. Suspension of CORE ALTERATION shall not preclude completion of movement of a component to a safe conservative position.

CORE OPERATING LIMITS REPORT

The CORE OPERATING LIMITS REPORT is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.7.A.6. Plant operation within these operating limits is addressed in individual specifications.

LIMITING SAFETY SYSTEM SETTINGS

LIMITING SAFETY SYSTEM SETTINGS are settings, as specified in Section 2.3, for automatic protective devices related to those variables having significant safety functions.

MEMBERS OF THE PUBLIC

MEMBERS OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the licensee, its contractors, or its vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational occupational, or other purposes not associated with the plant.

OFFSITE DOSE CALCULATION MANUAL (ODCM)

The ODCM is the manual containing the methodology and parameters to be used in the calculation of offsite doses due to radioactive liquid and gaseous effluents, in the calculation of liquid and gaseous effluent monitoring instrumentation alarm and/or trip setpoints, and in the conduct of the Radiological Environmental Monitoring Program.

### OPERABLE - OPERABILITY

A system, subsystem, train, component or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component or device to perform its function(s) are also capable of performing their related support function(s).

When a system, subsystem, train, component or device is determined to be inoperable solely because its emergency power source is inoperable, or solely because its normal power source is inoperable, it may be considered OPERABLE for the purpose of satisfying the requirements of its applicable Limiting Condition for Operation, provided: (1) its corresponding normal or emergency power source is OPERABLE; and (2) all of its redundant system(s), subsystem(s), train(s), component(s) and device(s) are OPERABLE, or likewise satisfy the requirements of this paragraph.

The OPERABILITY of a system or component shall be considered to be established when: (1) it satisfies the Limiting Conditions for Operation in Specification 3.0, (2) it has been tested periodically in accordance with Specification 4.0 and has met its performance requirements, and (3) its condition is consistent with the two paragraphs above.

### OPERATIONAL MODE - MODE

An OPERATIONAL MODE (i.e., MODE) shall correspond to any one inclusive combination of core reactivity condition, power level and average reactor coolant temperature specified in Table TS.1.1.

### PHYSICS TESTS

PHYSICS TESTS shall be those tests performed to measure the fundamental characteristics of the core and related instrumentation. PHYSICS TESTS are conducted such that the core power is sufficiently reduced to allow for the perturbation due to the test and therefore avoid exceeding power distribution limits in Specification 3.10.B.

Low power PHYSICS TESTS are run at reactor powers less than 2% of rated power.

### POWER OPERATION

POWER OPERATION of a unit is any operating condition that results when the reactor of that unit is critical, and the neutron flux power range instrumentation indicates greater than 2% of RATED THERMAL POWER.

RATED THERMAL POWER

RATED THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant of 1650 megawatts thermal (MWt).

REPORTABLE EVENT

A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 of 10 CFR Part 50.

SHIELD BUILDING INTEGRITY

SHIELD BUILDING INTEGRITY shall exist when:

1. Each door in each access opening is closed except when the access opening is being used for normal transit entry and exit, then at least one door shall be closed, and
2. The shield building equipment opening is closed.
3. The Shield Building Ventilation System is OPERABLE.

SITE BOUNDARY

The SITE BOUNDARY shall be that line beyond which the land is neither owned, nor leased, nor otherwise controlled by the licensee.

SOLIDIFICATION

SOLIDIFICATION shall be the conversion of wet wastes into a form that meets shipping and burial ground requirements.

SOURCE CHECK

A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a source of increased radioactivity.

STAGGERED TEST BASIS

A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the specified Surveillance Frequency so that all systems, subsystems, channels, or other designated components are tested during  $n$  Surveillance Frequency intervals, where  $n$  is the total number of systems, subsystems, channels, or other designated components in the associated function.

For example, the surveillance frequency for the automatic trip and interlock logic specifies that the functional testing of that system is monthly and that each train shall be tested at least every two months on a STAGGERED TEST BASIS. Per the definition above, for the automatic trip and interlock logic, the Surveillance Frequency interval is monthly and the number of trains (channels) is 2 ( $n=2$ ). Therefore, STAGGERED TEST BASIS requires one train be tested each month such that after two Surveillance Frequency intervals (two months) both trains will have been tested.

STARTUP OPERATION

The process of heating up a reactor above 200°F, making it critical, and bringing it up to POWER OPERATION.

THERMAL POWER

THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

UNRESTRICTED AREAS

An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional and/or recreational purposes.

VENTILATION EXHAUST TREATMENT SYSTEM

A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment. Such a system is not considered to have any effect on noble gas effluents. Engineered safety feature atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

VENTING

VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.



TABLE TS.1-1

TABLE TS.1-1  
OPERATIONAL MODES

<u>MODE</u>	<u>REACTIVITY CONDITION, <math>K_{eff}</math></u>	<u>% RATED THERMAL POWER</u>	<u>AVERAGE COOLANT TEMPERATURE</u>
A. POWER OPERATION	NA	> 2*	NA
B. HOT STANDBY	$\geq 0.99$	$\leq 2\%$	NA
C. HOT SHUTDOWN	$< 0.99^*$	NA	$\geq 535^\circ\text{F}$
D. INTERMEDIATE SHUTDOWN	$< 0.99^*$	NA	$< 535^\circ\text{F}$ $\geq 200^\circ\text{F}$
E. COLD SHUTDOWN	$< 0.99$	NA	$< 200^\circ\text{F}$
F. REFUELING**	$\leq 0.95^{***}$	NA	$\leq 140^\circ\text{F}$

---

\* Not a shutdown margin requirement, see Figure TS.3.10-1 for shutdown margin requirements.

\*\* Fuel in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

\*\*\* Boron concentration of the reactor coolant system and the refueling cavity sufficient to ensure that the more restrictive of the following conditions is met:

a.  $K_{eff} \leq 0.95$ , or

b. Boron concentration  $\geq 2000$  ppm.



2.3.A.2.g. Reactor coolant pump bus undervoltage -  $\geq 75\%$  of normal voltage.

h. Open reactor coolant pump motor breaker.

Reactor coolant pump bus underfrequency -  $\geq 58.2$  Hz

i. Power range neutron flux rate.

1. Positive rate -  $\leq 15\%$  of RATED THERMAL POWER with a time constant  $\geq 2$  seconds

2. Negative rate -  $\leq 7\%$  of RATED THERMAL POWER with a time constant  $\geq 2$  seconds

3. Other reactor trips

a. High pressurizer water level -  $\leq 90\%$  of narrow range instrument span.

b. Low-low steam generator water level -  $\geq 5\%$  of narrow range instrument span.

c. Turbine Generator trip

1. Turbine stop valve indicators - closed

2. Low auto stop oil pressure -  $\geq 45$  psig

d. Safety injection - See Specification 3.5

2.3.B. Protective instrumentation settings for reactor trip interlocks shall be as follows:

1. P-6 Interlock:

Source range high flux trip shall be unblocked whenever intermediate range neutron flux is  $\leq 10^{-10}$  amperes.

2. P-7 Interlock:

"At power" reactor trips that are blocked at low power (low pressurizer pressure, high pressurizer level, and loss of flow for one or two loops) shall be unblocked whenever:

- a. Power range neutron flux is  $\geq 12\%$  of RATED THERMAL POWER or,
- b. Turbine load is  $\geq 10\%$  of full load turbine impulse pressure.

3. P-8 Interlock:

Low power block of single loop loss of flow is permitted whenever power range neutron flux is  $\leq 10\%$  of RATED THERMAL POWER.

4. P-9 Interlock:

Reactor trip on turbine trip shall be unblocked whenever power range neutron flux is  $\geq 50\%$  of RATED THERMAL POWER.

5. P-10 Interlock:

Power range high flux low setpoint trip and intermediate range high flux trip shall be unblocked whenever power range neutron flux is  $\leq 9\%$  of RATED THERMAL POWER.

C. Control Rod Withdrawal Stops

1. Block automatic rod withdrawal:

a. P-2 Interlock:

Turbine load  $\leq 15\%$  of full load turbine impulse pressure.

### 3.4.C. Steam Exclusion System

1. The reactor coolant system average temperature shall not exceed 350°F unless both isolation dampers in each ventilation duct penetrating rooms containing equipment required for a high energy line rupture outside of containment are OPERABLE (except as specified below):
  - a. If one of the two redundant steam exclusion dampers is inoperable, the operable redundant damper may remain open for 24 hours. If after 24 hours, the damper remains inoperable, one of the two dampers shall be closed.
  - b. The actuation logic (including temperature sensors) for one train of steam exclusion may be inoperable for 24 hours. If after 24 hours, the actuation logic remains inoperable, one of the two dampers shall be closed.
2. If two redundant steam exclusion dampers or two trains of actuation logic (including temperature sensors) are inoperable, close the associated dampers within 4 hours.

### D. Radiochemistry

A reactor shall not be made or maintained critical nor shall reactor coolant system average temperature exceed 350°F unless the specific activity of the secondary coolant system for that reactor is less than or equal to 0.10 uCi/gm DOSE EQUIVALENT I-131. If these conditions cannot be satisfied, within one hour initiate the action necessary to place the unit in HOT SHUTDOWN, and be in at least HOT SHUTDOWN within the next 6 hours and reduce reactor system coolant average temperature below 350°F within the following 6 hours.

### 3.5 INSTRUMENTATION SYSTEM

#### Applicability

Applies to protection system instrumentation.

#### Objectives

To provide for automatic initiation of the engineered safety features in the event the principal process variable limits are exceeded, and to delineate the conditions of the reactor trip and engineered safety feature instrumentation necessary to ensure reactor safety.

#### Specification

- A. Limiting set points for instrumentation which initiates operation of the engineered safety features shall be as stated in Table TS.3.5-1.
- B. For on-line testing or in the event of failure of a sub-system instrumentation channel, plant operation shall be permitted to continue at RATED THERMAL POWER in accordance with Tables TS.3.5-2A and TS.3.5-2B.

TABLE TS.3.5-2A (Page 1 of 6)

## REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	A, B	1
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
2. Power Range, Neutron Flux					
a. High Setpoint	4	2	3	A, B	2
b. Low Setpoint	4	2	3	A <sup>(b)</sup> , B	2
3. Power Range, Neutron Flux, High Positive Rate	4	2	3	A, B	2
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	A, B	2
5. Intermediate Range, Neutron Flux	2	1	2	A <sup>(b)</sup> , B	3
6. Source Range, Neutron Flux					
a. Startup	2	1	2	B <sup>(c)</sup>	4
b. Shutdown	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	5
7. Overtemperature $\Delta T$	4	2	3	A, B	6
8. Overpower $\Delta T$	4	2	3	A, B	6

(a) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(b) Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

(c) Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

TABLE TS.3.5-2A (Page 2 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
9. Low Pressurizer Pressure	4	2	3	A	6
10. High Pressurizer Pressure	3	2	2	A, B	6
11. Pressurizer High Water Level	3	2	2	A	6
12. Reactor Coolant Flow Low	3/loop	2/loop	2/loop	A	6
13. Turbine Trip					
a. Low AST Oil Pressure	3	2	2	A	6
b. Turbine Stop Valve Closure	2	2	1	A	6
14. Lo-Lo Steam Generator Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	6
15. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22)	2/bus	1/bus on both buses	2 on one bus	A	11

TABLE TS.3.5-2A (Page 3 of 6)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
16. Loss of Reactor Coolant Pump					
a. RCP Breaker Open	1/pump	1	1/pump	A	1
b. Underfrequency 4kV bus	2/bus	1/bus on both buses	2 on one bus	A	11
17. Safety Injection Input from ESF	2	1	2	A, B	7
18. Automatic Trip and Interlock Logic	2	1	2	A, B	7
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
19. Reactor Trip Breakers	2	1	2	A, B	9
	2	1	2	C <sup>(a)</sup> , D <sup>(a)</sup> , E <sup>(a)</sup>	8
20. Reactor Trip Bypass Breakers	2	1	1	(d)	10

---

(a) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

(d) When the Reactor Trip Bypass Breakers are racked in and closed for bypassing a Reactor Trip Breaker and the Control Rod System is capable of rod withdrawal.

TABLE 3.5-2A (Page 4 of 6)

Action Statements

ACTION 1: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours.

ACTION 2: With the number of OPERABLE channels less than the Total Number of Channels HOT STAND-BY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours;
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1; and
- c. If THERMAL POWER is above 85% of RATED THERMAL POWER, then determine the core quadrant power balance in accordance with the requirements of Specification 3.10.C.4.
- d. One additional channel may be taken out of service for low power PHYSICS TESTS.

ACTION 3: With the number of channels OPERABLE one less than the Total Number of Channels and with the THERMAL POWER level:

- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.
- b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.

ACTION 4: With the number of OPERABLE channels one less than the Total Number of Channels suspend all operations involving positive reactivity changes.

ACTION 5: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or within the next hour open the reactor trip breakers and suspend all operations involving positive reactivity changes.



TABLE 3.5-2A (Page 5 of 6)

Action Statements

ACTION 6: With the number of OPERABLE channels one less than the Total Number of Channels, HOT STANDBY and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 7: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours; however, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1 provided the other channel is OPERABLE.

ACTION 8: With the number of OPERABLE channels one less than the Total Number of Channels restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

ACTION 9: a. With one of the diverse trip features (Undervoltage or Shunt Trip Attachment) inoperable, restore it to OPERABLE status within 48 hours or declare the breaker inoperable and apply the requirements of b below. The breaker shall not be bypassed while one of the diverse trip features is inoperable, except for the time required for performing maintenance and testing to restore the diverse trip feature to OPERABLE status.

- b. With one of the Reactor Trip Breakers otherwise inoperable, be in at least HOT SHUTDOWN within 6 hours; however, one Reactor Trip Breaker may be bypassed for up to 4 hours for surveillance testing per Specification 4.1, provided the other Reactor Trip Breaker is OPERABLE.

ACTION 10: With the Reactor Trip Bypass Breaker inoperable, restore the Reactor Trip Bypass Breaker to OPERABLE status prior to using the Reactor Trip Bypass Breaker to bypass a Reactor Trip Breaker. If the Reactor Trip Bypass Breaker is racked in and closed for bypassing a Reactor Trip Breaker and it becomes inoperable, be in at least HOT SHUTDOWN within 6 hours. Restore the Bypass Breaker to OPERABLE status within the next 48 hours or open the Bypass Breaker within the following hour.

TABLE 3.5-2A (Page 6 of 6)

Action Statements

ACTION 11: With the number of OPERABLE channels less than the Total Number of Channels, POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel(s) is placed in the tripped condition within 6 hours, and
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

ACTION 19: NOT USED

ACTION 12: NOT USED

ACTION 13: NOT USED

ACTION 14: NOT USED

ACTION 15: NOT USED

ACTION 16: NOT USED

ACTION 17: NOT USED

ACTION 18: NOT USED

TABLE TS.3.5-2B (Page 1 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. SAFETY INJECTION					
a. Manual Initiation	2	1	2	A, B, C, D	23
b. High Containment Pressure	3	2	2	A, B, C, D	24
c. Steam Generator Low Steam Pressure/Loop	3/Loop	2 in any Loop	2/Loop	A, B, C <sup>(a)</sup>	24
d. Pressurizer Low Pressure	3	2	2	A, B, C <sup>(a)</sup>	24
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
2. CONTAINMENT SPRAY					
a. Manual Initiation	2	2	2	A, B, C, D	23
b. HI-HI Containment Pressure	3 channels with 2 sensors per channel	1 sensor per channel in all 3 channels	1 sensor per channel in all 3 channels	A, B, C, D	21
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20

(a) Trip function may be blocked in this MODE below a Reactor Coolant System Pressure of 2000 psig.

TABLE TS.3.5-2B (Page 2 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
3. CONTAINMENT ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	A, B, C, D	23
c. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D	20
4. CONTAINMENT VENTILATION ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
b. Manual	2	1	2	(b)	22
c. Manual Containment Spray	See 2a above for Manual Containment Spray requirements.				
d. Manual Containment Isolation	See 3b above for Manual Containment Isolation requirements.				
e. High Radiation in Exhaust Air	2	1	2	(b)	22
f. Automatic Actuation Logic and Actuation Relays	2	1	2	(b)	22

(b) Whenever CONTAINMENT INTEGRITY is required and either of the containment purge systems are in operation.

TABLE TS.3.5-2B (Page 3 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION					
a. Manual	1/Loop	1/Loop	1/Loop	A, B, C, D <sup>(c)</sup>	27
b. Hi-Hi Containment Pressure	3	2	2	A, B, C, D <sup>(c)</sup>	24
c. Hi-Hi Steam Flow with Safety Injection					
1. Hi-Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(c)</sup>	29
2. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
d. Hi Steam Flow and 2 of 4 Low Tave with Safety Injection:					
1. Hi Steam Flow	2/Loop	1 in any Loop	1/Loop	A, B, C, D <sup>(d)</sup>	29
2. Tave	4	2	3	A, B, C, D <sup>(d)</sup>	24
3. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

(d) When reactor coolant system average temperature is greater than 520°F and either main steam isolation valve is open.

TABLE TS.3.5-2B (Page 4 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
5. STEAM LINE ISOLATION (continued)					
e. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(c)</sup>	25
6. FEEDWATER ISOLATION					
a. Hi-Hi Steam Generator Level	3/SG	2/SG in any SG	2/SG in each SG	A, B	24
b. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
c. Reactor Trip with 2 of 4 Low Tave (Main Valves only):					
1. Reactor Trip	2	1	2	A, B	28
2. Low Tave	4	2	3	A, B	24
d. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B	28

(c) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.

TABLE TS.3.5-2B (Page 5 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
7. AUXILIARY FEEDWATER					
a. Manual	2	1	2	A, B, C, D <sup>(e)</sup>	26
b. Steam Generator Low-Low Water Level	3/SG	2/SG in any SG	2/SG in each SG	A, B, C, D <sup>(e)</sup>	24
c. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22) (Start Turbine Driven Pump only)	2/bus	1/bus on both buses	2 on one bus	A, B	29
d. Trip of Main Feedwater Pumps					
1. Turbine Driven	2	2	2	A, B	26
2. Motor Driven	2	2	2	A, B	26
e. Safety Injection	See 1 above for all Safety Injection initiating functions and requirements.				
f. Automatic Actuation Logic and Actuation Relays	2	1	2	A, B, C, D <sup>(e)</sup>	20

(e) When reactor coolant system average temperature is greater than 350°F.



TABLE TS.3.5-2B (Page 6 of 8)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. LOSS OF POWER					
a. Loss of Voltage (90%) Coincident with Degraded Voltage (90%) or Loss of Voltage (55%) Coincident with Degraded Voltage (90%)					
1. Loss of Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
2. Loss of Voltage 4kv Safeguards Bus (55%)	2/Bus	1/Bus with Degraded Voltage on other phase	1/Bus	A, B, C, D	29
3. Degraded Voltage 4kv Safeguards Bus (90%)	2/Bus	1/Bus with Loss of Voltage 55% or 90% on other phase	1/Bus	A, B, C, D	29

TABLE TS.3.5-2B  
(Page 6 of 8)  
REV



TABLE 3.5-2B (Page 7 of 8)

Action Statements

ACTION 20: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 21: With the number of OPERABLE channels less than the Total Number of Channels, operation may proceed provided the inoperable channel(s) is placed in the tripped condition and the Minimum Channels OPERABLE requirement is met. The inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing per Specification 4.1.

ACTION 22: With the number of OPERABLE channels less than the Total Number of Channels, operation may continue provided the containment purge supply and exhaust valves are maintained closed.

ACTION 23: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

ACTION 24: With the number of OPERABLE channels one less than the Total Number of Channels, operation in the applicable MODE may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours, and,
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1.

TABLE 3.5-2B (Page 8 of 8)

Action Statements

ACTION 25: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours. Operation in HOT SHUTDOWN may proceed provided the main steam isolation valves are closed, if not, reduce reactor coolant system average temperature below 350°F within the following 6 hours. However, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 26: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within 6 hours and reduce reactor coolant system average temperature below 350°F within the following 6 hours.

ACTION 27: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 6 hours and close the associated valve.

ACTION 28: With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT SHUTDOWN within the next 6 hours. However, one channel may be bypassed for up to 8 hours for surveillance testing per Specification 4.1, provided the other channel is OPERABLE.

ACTION 29: With the number of OPERABLE channels less than the Total Number of Channels, operation in the applicable MODE may proceed provided the following conditions are satisfied:

- a. The inoperable channel(s) is placed in the tripped condition within 6 hours, and,
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel(s) may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.1

## 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

Applicability

Applies to the limits on core fission power distribution and to the limits on control rod operations.

Objective

To assure 1) core subcriticality after reactor trip, 2) acceptable core power distributions during POWER OPERATION, and 3) limited potential reactivity insertions caused by hypothetical control rod ejection.

SpecificationA. Shutdown Margin

The shutdown margin with allowance for a stuck control rod assembly shall exceed the applicable value shown in Figure TS.3.10-1 under all steady-state operating conditions, except for PHYSICS TESTS, from zero to full power, including effects of axial power distribution. The shutdown margin as used here is defined as the amount by which the reactor core would be subcritical at HOT SHUTDOWN temperature conditions if all control rod assemblies were tripped, assuming that the highest worth control rod assembly remained fully withdrawn, and assuming no changes in xenon or boron concentration.

B. Power Distribution Limits

1. At all times, except during low power PHYSICS TESTING, measured hot channel factors,  $F_Q^N$  and  $F_{\Delta H}^N$ , as defined below and in the bases, shall meet the following limits:

$$F_Q^N \times 1.03 \times 1.05 \leq (F_Q^{\text{RTP}} / P) \times K(Z)$$

$$F_{\Delta H}^N \times 1.04 \leq F_{\Delta H}^{\text{RTP}} \times [1 + \text{PFDH}(1-P)]$$

where the following definitions apply:

- $F_Q^{\text{RTP}}$  is the  $F_Q$  limit at RATED THERMAL POWER specified in the CORE OPERATING LIMITS REPORT.
- $F_{\Delta H}^{\text{RTP}}$  is the  $F_{\Delta H}$  limit at RATED THERMAL POWER specified in the CORE OPERATING LIMITS REPORT.
- PFDH is the Power Factor Multiplier for  $F_{\Delta H}^N$  specified in the CORE OPERATING LIMITS REPORT.
- $K(Z)$  is a normalized function that limits  $F_Q(z)$  axially as specified in the CORE OPERATING LIMITS REPORT.
- $Z$  is the core height location.
- $P$  is the fraction of RATED THERMAL POWER at which the core is operating. In the  $F_Q^N$  limit determination when  $P \leq 0.50$ , set  $P = 0.50$ .

#### 4.1 OPERATIONAL SAFETY REVIEW

##### Applicability

Applies to items directly related to safety limits and limiting conditions for operation.

##### Objective

To specify the minimum frequency and type of surveillance to be applied to plant equipment and conditions.

##### Specification

- A. Calibration, testing, and checking of instrumentation channels and testing of logic channels shall be performed as specified in Tables TS.4.1-1A, 4.1-1B and 4.1-1C.
- B. Equipment tests shall be conducted as specified in Table TS.4.1-2A.
- C. Sampling tests shall be conducted as specified in Table TS.4.1-2B.
- D. Whenever the plant condition is such that a system or component is not required to be OPERABLE the surveillance testing associated with that system or component may be discontinued. Discontinued surveillance tests shall be resumed less than one test interval before establishing plant conditions requiring OPERABILITY of the associated system or component, unless such testing is not practicable (i.e., nuclear power range calibration cannot be done prior to reaching POWER OPERATION) in which case the testing will be resumed within 48 hours of attaining the plant condition which permits testing to be accomplished.

TABLE TS.4.1-1A (Page 1 of 5)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	R <sup>(13)</sup>	N.A.	A, B, C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
2. Power Range, Neutron Flux					
a) High Setpoint	S	D <sup>(5, 7)</sup> M <sup>(6, 7)</sup> Q <sup>(7, 8)</sup>	Q <sup>(18)</sup>	P	A, B
b) Low Setpoint	S	R <sup>(7)</sup>	S/U <sup>(17)</sup>	R	A <sup>(3)</sup> , B
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R <sup>(7)</sup>	Q	R	A, B
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R <sup>(7)</sup>	Q	R	A, B
5. Intermediate Range, Neutron Flux	S	R <sup>(7)</sup>	S/U <sup>(4)</sup>	R	A <sup>(3)</sup> , B
6. Source Range, Neutron Flux					
a. Startup	S	R <sup>(7)</sup>	S/U <sup>(4)</sup>	R	B <sup>(2)</sup>
b. Shutdown	S	R <sup>(7)</sup>	Q <sup>(10)</sup>	R	C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
7. Overtemperature ΔT	S	R	Q	R	A, B
8. Overpower ΔT	S	R	Q	R	A, B

TABLE 4.1-1A (Page 2 of 5)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
9. Low Pressurizer Pressure	S	R	Q	N.A.	A
10. High Pressurizer Pressure	S	R	Q	N.A.	A, B
11. Pressurizer High Water Level	S	R	Q	N.A.	A
12. Reactor Coolant Flow Low	S	R	Q	N.A.	A
13. Turbine Trip					
a. Low AST Oil Pressure	N.A.	R	S/T	N.A.	A
b. Turbine Stop Valve Closure	N.A.	R	S/T	N.A.	A
14. Lo-Lo Steam Generator Water Level	S	R	Q	N.A.	A, B
15. Undervoltage 4KV RCP Bus	N.A.	R	Q	N.A.	A

TABLE TS.4.1-1A (Page 3 of 5)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
16. Loss of Reactor Coolant Pump					
a. RCP Breaker Open	N.A.	R	S/U <sup>(4)</sup>	N.A.	A
b. Underfrequency 4KV Bus	N.A.	R	Q	N.A.	A
17. Safety Injection Input	N.A.	N.A.	R	N.A.	A, B
18. Automatic Trip and Interlock Logic	N.A.	N.A.	M <sup>(9)</sup>	R	A, B, C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
19. Reactor Trip Breakers	N.A.	N.A.	M <sup>(9, 12)</sup>	R	A, B, C <sup>(1)</sup> , D <sup>(1)</sup> , E <sup>(1)</sup>
20. Reactor Trip Bypass Breakers	N.A.	N.A.	M <sup>(14)</sup>	R <sup>(15)</sup>	See Note (16)

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
M	Monthly
Q	Quarterly
S/U	Prior to each reactor startup
R	Each Refueling Shutdown
N.A.	Not applicable.

TABLE NOTATION

- |  |   |
|--|---|
| <p>(1) When the Reactor Trip Breakers are closed and the Control Rod Drive System is capable of rod withdrawal.</p> <p>(2) Below P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.</p> <p>(3) Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.</p> <p>(4) Prior to each startup following shutdown in excess of two days if not done in previous 30 days.</p> <p>(5) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%.</p> | <p>(6) Single point comparison of incore to excore for axial off-set above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than 2%.</p> <p>(7) Neutron detectors may be excluded from CHANNEL CALIBRATION.</p> <p>(8) Incore - Excore Calibration, above 75% of RATED THERMAL POWER.</p> <p>(9) Each train shall be tested at least every two months on a STAGGERED TEST BASIS.</p> |
|--|---|



TABLE NOTATIONS (Continued)

TABLE NOTATION (Continued)

- |   |   |
|---|---|
| <p>(10) Quarterly surveillance in MODES 3, 4 and 5 shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window.</p> <p>(11) Setpoint verification is not applicable.</p> <p>(12) The Functional Test shall independently verify the OPERABILITY of the undervoltage and shunt trip attachments of the Reactor Trip Breakers.</p> <p>(13) The Functional Test shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the Manual Reactor Trip Function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit(s).</p> <p>(14) Manually trip the undervoltage trip attachment remotely (i.e., from the protection system racks).</p> <p>(15) Automatic undervoltage trip.</p> <p>(16) Whenever the Reactor Trip Bypass Breakers are racked in and closed for bypassing a Reactor Trip Breaker and the Control Rod Drive System is capable of rod withdrawal.</p> | <p>(17) Prior to each startup if not done previous week.</p> <p>(18) Including quadrant power tilt monitor.</p> |
|---|---|

TABLE TS.4.1-1B (Page 1 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. SAFETY INJECTION					
a. Manual Initiation	N.A.	N.A.	R <sup>(1)</sup>	N.A.	A, B, C, D
b. High Containment Pressure	S	R	Q	N.A.	A, B, C, D
c. Steam Generator Low Steam Pressure/Loop	S	R	Q	N.A.	A, B, C <sup>(2)</sup>
d. Pressurizer Low Pressure	S	R	Q	N.A.	A, B, C <sup>(2)</sup>
e. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D
2. CONTAINMENT SPRAY					
a. Manual Initiation	N.A.	N.A.	R	N.A.	A, B, C, D
b. Hi-Hi Containment Pressure	S	R	Q	N.A.	A, B, C, D
c. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D

TABLE TS.4.1-1B (Page 2 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
3. CONTAINMENT ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
b. Manual	N.A.	N.A.	R	N.A.	A, B, C, D
c. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D
4. CONTAINMENT VENTILATION ISOLATION					
a. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
b. Manual	N.A.	N.A.	R	N.A.	See Note (8)
c. Manual Containment Spray	See 2a above for all Manual Containment Spray Surveillance Requirements				
d. Manual Containment Isolation	See 3b above for all Manual Containment Isolation Surveillance Requirements				
e. High Radiation in Exhaust Air	D <sup>(7)</sup>	R	M	N.A.	See Note (8)
f. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	See Note (8)

TABLE TS.4.1-1B (Page 3 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
5. STEAM LINE ISOLATION					
a. Manual	N.A.	N.A.	R	N.A.	A, B, C, D <sup>(4)</sup>
b. Hi-Hi Containment Pressure	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
c. Hi-Hi Steam Flow with Safety Injection					
1. Pi-Hi Steam Flow	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
2. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
d. Hi Steam Flow and 2 of 4 Low T <sub>avg</sub> with Safety Injection					
1. Hi Steam Flow	S	R	Q	N.A.	A, B, C, D <sup>(4)</sup>
2. T <sub>avg</sub>	S	R	Q	N.A.	A, B, C, D <sup>(5)</sup>
3. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
e. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D <sup>(4)</sup>

TABLE TS.4.1-1B (Page 4 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
6. FEEDWATER ISOLATION					
a. Hi-Hi Steam Generator Level	S	R	Q	N.A.	A, B
b. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
c. Reactor Trip with 2 of 4 Low T <sub>avg</sub> (Main Valves Only)					
1. Reactor Trip	N.A.	N.A.	R	N.A.	A, B
2. Tave	S	R	Q	N.A.	A, B
d. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B

TABLE TS.4.1-1B (Page 5 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
7. AUXILIARY FEEDWATER					
a. Manual	N.A.	N.A.	R	N.A.	A, B, C, D <sup>(5)</sup>
b. Steam Generator Low-Low Water Level	S	R	Q	N.A.	A, B, C, D <sup>(5)</sup>
c. Undervoltage on 4.16 kV Buses 11 and 12 (Unit 2: 21 and 22) (Start Turbine Driven Pump only)	N.A.	R	R	N.A.	A, B
d. Trip of Main Feedwater Pumps					
1. Turbine Driven	N.A.	N.A.	R	N.A.	A, B
2. Motor Driven	N.A.	N.A.	R	N.A.	A, B
e. Safety Injection	See 1 above for all Safety Injection Surveillance Requirements				
f. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	M <sup>(3)</sup>	N.A.	A, B, C, D <sup>(5)</sup>

TABLE TS.4.1-1B (Page 6 of 7)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
8. LOSS OF POWER					
a. Loss of Voltage (90%) Coincident with Degraded Voltage (90%) or Loss of Voltage (55%) Coincident with Degraded Voltage (90%)					
1. Loss of Voltage 4kv Safeguards Bus (90%)	N.A.	R	M	N.A.	A, B, C, D
2. Loss of Voltage 4kv Safeguards Bus (55%)	N.A.	R	M	N.A.	A, B, C, D
3. Degraded Voltage 4kv Safeguards Bus (90%)	N.A.	R	M	N.A.	A, B, C, D

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
M	Monthly
Q	Quarterly
R	Each Refueling Shutdown
N.A.	Not Applicable

TABLE NOTATION

- |   |  |
|---|--|
| <p>(1) One manual switch shall be tested at each refueling on a STAGGERED TEST BASIS.</p> <p>(2) Trip function may be blocked in this MODE below a reactor coolant system pressure of 2000 psig.</p> <p>(3) Each train shall be tested at least every two months on a STAGGERED TEST BASIS.</p> <p>(4) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.</p> <p>(5) When reactor coolant system average temperature is greater than 350°F.</p> <p>(6) When reactor coolant system average temperature is greater than 520°F and either main steam isolation valve is open.</p> | <p>(7) See Table 4.17-1.</p> <p>(8) Whenever CONTAINMENT INTEGRITY is required and either of the containment purge systems are in operation.</p> |
|---|--|



TABLE TS.4.1-1C (Page 1 of 4)

MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Control Rod Insertion Monitor	M	R	S/U <sup>(1)</sup>	N.A.	A, B
2. Analog Rod Position	S	R	S/U <sup>(1)</sup>	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
3. Rod Position Deviation Monitor	M	N.A.	S/U <sup>(1)</sup>	N.A.	A, B
4. Rod Position Bank Counters	S <sup>(3)</sup>	N.A.	N.A.	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
5. Charging Flow	S	R	N.A.	N.A.	A, B, C, D
6. Residual Heat Removal Pump Flow	S	R	N.A.	N.A.	D <sup>(9)</sup> , E <sup>(9)</sup> , F <sup>(9)</sup>
7. Boric Acid Tank Level	D	R <sup>(4)</sup>	M <sup>(4)</sup>	N.A.	A, B, C, D
8. Refueling Water Storage Tank Level	W	R	M	N.A.	A, B, C, D
9. Volume Control Tank	S	R	N.A.	N.A.	A, B, C, D
10. Annulus Pressure (Vacuum Breaker)	N.A.	R	R	N.A.	See Note (12)
11. Auto Load Sequencers	N.A.	N.A.	M	N.A.	A, B, C, D
12. Boric Acid Make-up Flow Channel	N.A.	R	N.A.	N.A.	A, B, C, D

TABLE TS.4.1-1C (Page 2 of 4)

MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
13. Containment Sump A, B and C Level	N.A.	R	R	N.A.	A, B, C, D
14. Accumulator Level and Pressure	S	R	R	N.A.	A, B, C, D
15. Turbine First Stage Pressure	S	R	M	N.A.	A
16. Emergency Plan Radiation Instruments <sup>(6)</sup>	M	R	M	N.A.	A, B, C, D, E, F
17. Seismic Monitors	R	R	N.A.	N.A.	A, B, C, D, E, F
18. Coolant Flow - RTD Bypass Flowmeter	S	R	M	N.A.	A, B, C, D <sup>(5)</sup>
19. CRDM Cooling Shroud	S	N.A.	R	N.A.	A, B, C <sup>(2)</sup> , D <sup>(2)</sup> , E <sup>(2)</sup>
20. Reactor Gap Exhaust Air Temperature	S	N.A.	R	N.A.	A, B, C, D
21. Post-Accident Monitoring Instruments (Table TS.3.15-1) <sup>(7)</sup>	M	R	N.A.	N.A.	A, B
22. Post-Accident Monitoring Radiation Instruments (Table TS.3.15-2)		R	M	N.A.	A, B

TABLE TS.4.1-1C  
(Page 2 of 4)  
REV

TABLE TS.4.1-1C (Page 3 of 4)

## MISCELLANEOUS INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>FUNCTIONAL TEST</u>	<u>RESPONSE TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
23. Post-Accident Monitoring Reactor Vessel Level Instrumentation (Table TS.3.15-3)	M	R	N.A.	N.A.	A, B
24. Steam Exclusion Actuation	W	Y	M	N.A.	A, B, C, D <sup>(10)</sup>
25. Overpressure Mitigation	N.A.	R	R	N.A.	D <sup>(11)</sup> , E
26. Auxiliary Feedwater Pump Suction Pressure	N.A.	R	R	N.A.	A, B, C, D <sup>(10)</sup>
27. Auxiliary Feedwater Pump Discharge Pressure	N.A.	R	R	N.A.	A, B, C, D <sup>(10)</sup>
28. NaOH Caustic Stand Pipe Level	W	R	M	N.A.	A, B, C, D
29. Control Room Ventilation System Chlorine Monitors	S	Y	M <sup>(8)</sup>	N.A.	A, B, C, D, E, F
30. Hydrogen Monitors	S	Q	M	N.A.	A, B
31. Containment Temperature Monitors	M	R	N.A.	N.A.	A, B, C, D
32. Turbine Overspeed Protection Trip Channel	N.A.	R	M	N.A.	A

TABLE TS.4.1-1C  
(Page 3 of 4)  
REV

TABLE NOTATIONSFREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Shift
D	Daily
W	Weekly
M	Monthly
Q	Quarterly
S/U	Prior to each startup
Y	Yearly
R	Each refueling shutdown
N.A.	Not applicable

TABLE NOTATION

- |   |   |
|---|---|
| <p>(1) Prior to each startup following shutdown in excess of two days if not done in previous 30 days.</p> <p>(2) When the reactor trip system breakers are closed and the control rod drive system is capable of rod withdrawal.</p> <p>(3) Following rod motion in excess of six inches when the computer is out of service.</p> <p>(4) Transfer logic to Refueling Water Storage Tank.</p> <p>(5) When reactor coolant system average temperature is greater than 350°F and either main steam isolation valve is open.</p> | <p>(6) Includes those instruments named in the emergency procedure.</p> <p>(7) Except for containment hydrogen monitors which are separately specified in this table.</p> <p>(8) Verification of the chlorine monitor control logic only.</p> <p>(9) When RHR is in operation.</p> <p>(10) When the reactor coolant system average temperature is greater than 350°F.</p> <p>(11) When the reactor coolant system average temperature is less than 310°F.</p> <p>(12) Whenever CONTAINMENT INTEGRITY is required.</p> |
|---|---|

TABLE TS.4.1-2B

MINIMUM FREQUENCIES FOR SAMPLING TESTS

<u>TEST</u>	<u>FREQUENCY</u>
1. RCS Gross Activity Determination	5/week
2. RCS Isotopic Analysis for DOSE EQUIVALENT I-131 Concentration	1/14 days (when at power)
3. RCS Radiochemistry $\bar{E}$ determination	1/6 months(1) (when at power)
4. RCS Isotopic Analysis for Iodine Including I-131, I-133, and I-135	a) Once per 4 hours, whenever the specific activity exceeds 1.0 $\mu$ Ci/gram DOSE EQUIVALENT I-131 or 100/ $\bar{E}$ $\mu$ Ci/gram (at or above cold shutdown), and b) One sample between 2 and 6 hours following THERMAL POWER change exceeding 15 percent of the RATED THERMAL POWER within a one hour period ( above hot shutdown)
5. RCS Radiochemistry (2)	Monthly
6. RCS Tritium Activity	Weekly
7. RCS Chemistry (Cl*, F*, O2)	5/Week
8. RCS Boron Concentration*(3)	2/Week (4)
9. RWST Boron Concentration	Weekly
10. Boric Acid Tanks Boron Concentration	2/Week
11. Caustic Standpipe NaOH Concentration	Monthly
12. Accumulator Boron Concentration	Monthly
13. Spent Fuel Pit Boron Concentration	Monthly (7)

\* Required at all times.

TABLE TS.4.1-2B

MINIMUM FREQUENCIES FOR SAMPLING TESTS

<u>TEST</u>	<u>FREQUENCY</u>
14. Secondary Coolant Gross Beta-Gamma activity	Weekly
15. Secondary Coolant Isotopic Analysis for DOSE EQUIVALENT I-131 concentration	1/6 months (5)
16. Secondary Coolant Chemistry	
pH	5/week (6)
pH Control Additive	5/week (6)
Sodium	5/week (6)

Notes:

1. Sample to be taken after a minimum of 2 EFPD and 20 days of POWER OPERATION have elapsed since reactor was last subcritical for 48 hours or longer.
2. To determine activity of corrosion products having a half-life greater than 30 minutes.
3. During REFUELING, the boron concentration shall be verified by chemical analysis daily.
4. The maximum interval between analyses shall not exceed 5 days.
5. If activity of the samples is greater than 10% of the limit in Specification 3.4.D, the frequency shall be once per month.
6. The maximum interval between analyses shall not exceed 3 days.
7. The minimum spent fuel pool boron concentration from Specification 3.8.B.1.b shall be verified by chemical analysis weekly while a spent fuel cask containing fuel is located in the spent fuel pool.



### 2.3 LIMITING SAFETY SYSTEM SETTINGS, PROTECTIVE INSTRUMENTATION

#### Bases continued

The overpower and overtemperature protection setpoints include the effects of fuel densification on core safety limits.

A loss of coolant flow incident can result from a mechanical or electrical failure in one or more reactor coolant pumps, or from a fault in the power supply to these pumps. If the reactor is at power at the time of the incident, the immediate effect of loss of coolant flow is a rapid increase in coolant temperature. This increase could result in departure from nucleate boiling (DNB) with subsequent fuel damage if the reactor is not tripped promptly. The following trip circuits provide the necessary protection against a loss of coolant flow incident:

- a. Low reactor coolant flow
- b. Low voltage on pump power supply bus
- c. Pump circuit breaker opening (low frequency on pump power supply bus opens pump circuit breaker)

The low flow reactor trip protects the core against DNB in the event of either a decreasing actual measured flow in the loops or a sudden loss of one or both reactor coolant pumps. The set point specified is consistent with the value used in the accident analysis (Reference 7). The low loop flow signal is caused by a condition of less than 90% flow as measured by the loop flow instrumentation.

The reactor coolant pump bus undervoltage trip is a direct reactor trip (not a reactor coolant pump circuit breaker trip) which protects the core against DNB in the event of a loss of power to the reactor coolant pumps. The set point specified is consistent with the value used in the accident analysis (Reference 7).

The reactor coolant pump breaker reactor trip is caused by the reactor coolant pump breaker opening as actuated by either high current, low supply voltage or low electrical frequency, or by a manual control switch. The significant feature of the reactor coolant pump breaker reactor trip is the frequency set point, 258.2 cps, which assures a trip signal before the pump inertia is reduced to an unacceptable value.

The high pressurizer water level reactor trip protects the pressurizer safety valves against water relief. The specified set point allows adequate operating instrument error (Reference 2) and transient level overshoot beyond their trip setting so that the trip function prevents the water level from reaching the safety valves.

The low-low steam generator water level reactor trip protects against loss of feedwater flow accidents. The specified set point assures that there will be sufficient water inventory in the steam generators at the time of trip to allow for starting delays for the auxiliary feedwater system (Reference 2).

## 2.3 LIMITING SAFETY SYSTEM SETTINGS, PROTECTIVE INSTRUMENTATION

### Bases continued

The specified reactor trips are blocked at low power where they are not required for protection and would otherwise interfere with normal plant operations. The prescribed set point above which these trips are unblocked assures their availability in the power range where needed. The reactor trips related to loss of one or both reactor coolant pumps are unblocked at approximately 10% of RATED THERMAL POWER.

The other reactor trips specified in 2.3.A.3. above provide additional protection. The safety injection signal trips the reactor to decrease the severity of the accident condition. The reactor is tripped when the turbine generator trips above a power level equivalent to the load rejection capacity of the steam dump valves. This reduces the severity of the loss-of-load transient.

The positive power range rate trip provides protection against rapid flux increases which are characteristic of rod ejection events from any power level. Specifically, this trip compliments the power range nuclear flux high and low trip to assure that the criteria are met for rod ejection from partial power.

The negative power range rate trip provides protection against LNB for control rod drop accidents. Most rod drop events will cause a sufficiently rapid decrease in power to trip the reactor on the negative power range rate trip signal. Any rod drop events which do not insert enough reactivity to cause a trip are analyzed to ensure that the core does not experience DNF. Administrative limits in Specification 3.10 require a power reduction if design power distribution limits are exceeded by a single misaligned or dropped rod.

### References

1. USAR, Section 14.4.1
2. USAR, Section 14.3
3. USAR, Section 14.6.1
4. USAR, Section 14.4.1
5. USAR, Section 7.4.1.1, 7.2
6. USAR, Section 3.3.2
7. USAR, Section 14.4.8
8. USAR, Section 14.1.10



### 3.5 INSTRUMENTATION SYSTEM

#### Bases

Instrumentation has been provided to sense accident conditions and to initiate reactor trip and operation of the Engineered Safety Features (Reference 1). The OPERABILITY of the Reactor Trip System and the Engineered Safety System instrumentation and interlocks ensures that: (1) the associated ACTION and/or reactor trip will be initiated when the parameter monitored by each channel or combination thereof reaches its setpoint, (2) the specified coincidence logic and sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance consistent with maintaining an appropriate level of reliability of the Reactor Protection and Engineered Safety Features instrumentation and, (3) sufficient system functions capability is available from diverse parameters.

The OPERABILITY of these systems is required to provide the overall reliability, redundancy and diversity assumed available in the facility design for the protection and mitigation of accident and transient conditions. The integrated operation of each of these systems is consistent with the assumptions used in the safety analysis.

Specified surveillance and maintenance outage times have been determined in accordance with WCAP-10271, "Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation System", and supplements to that report. Out of service times were determined based on maintaining an appropriate level of reliability of the Reactor Protection System and Engineered Safety Features instrumentation.

The evaluation of surveillance frequencies and out of service times for the reactor protection and engineered safety feature instrumentation described in WCAP-10271 included the allowance for testing in bypass. The evaluation assumed that the average amount of time the channels within a given trip function would be in bypass for testing was 4 hours.

#### Safety Injection

The Safety Injection System is actuated automatically to provide emergency cooling and reduction of reactivity in the event of a loss-of-coolant accident or a steam line break accident.

Safety injection in response to a loss-of-coolant accident (LOCA) is provided by a high containment pressure signal backed up by the low pressurizer pressure signal. These conditions would accompany the depressurization and coolant loss during a LOCA.

Safety injection in response to a steam line break is provided directly by a low steam line pressure signal, backed up by the low pressurizer pressure signal and, in case of a break within the containment, by the high containment pressure signal.

The safety injection of highly heated water will offset the temperature-induced reactivity addition that could otherwise result from cooldown following a steam line break.

### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

##### Containment Spray

Containment sprays are also actuated by a high containment pressure signal (Hi-Hi) to reduce containment pressure in the event of a loss-of-coolant or steam line break accident inside the containment.

The containment sprays are actuated at a higher containment pressure (approximately 50% of design containment pressure) than is safety injection (10% of design). Since spurious actuation of containment spray is to be avoided, it is initiated on coincidence of high containment pressure sensed by three sets of one-out-of-two containment pressure signals provided for its actuation.

##### Containment Isolation

A containment isolation signal is initiated by any signal causing automatic initiation of safety injection or may be initiated manually. The containment isolation system provides the means of isolating the various pipes passing through the containment walls as required to prevent the release of radioactivity to the environment in the event of a loss-of-coolant accident.

##### Steam Line Isolation

In the event of a steam line break, the steam line stop valve of the affected line is automatically isolated to prevent continuous, uncontrolled steam release from more than one steam generator. The steam lines are isolated on high containment pressure (Hi-Hi) or high steam line flow in coincidence with low  $T_{avg}$  and safety injection or high steam flow (Hi-Hi) in coincidence with safety injection. Adequate protection is afforded for breaks inside or outside the containment even when it is assumed that the steam line check valves do not function properly.

##### Containment Ventilation Isolation

Valves in the containment purge and inservice purge systems automatically close on receipt of a Safety Injection signal or a high radiation signal. Gaseous and particulate monitors in the exhaust stream or a gaseous monitor in the exhaust stack provide the high radiation signal.

##### Ventilation System Isolation

In the event of a high energy line rupture outside of containment, redundant isolation dampers in certain ventilation ducts are closed (Reference 4).

### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

#### Safeguards Bus Voltage

Relays are provided on buses 15, 16, 25, and 26 to detect loss of voltage and degraded voltage (the voltage level at which safety related equipment may not operate properly). On loss of voltage, the automatic voltage restoring scheme is initiated immediately. When degraded voltage is sensed, the voltage restoring scheme is initiated if acceptable voltage is not restored within a short time period. This time delay prevents initiation of the voltage restoring scheme when large loads are started and bus voltage momentarily dips below the degraded voltage setpoint.

#### Auxiliary Feedwater System Actuation

The following signals automatically start the pumps and open the steam admission control valve to the turbine driven pump of the affected unit:

1. Low-low water level in either steam generator
2. Trip of both main feedwater pumps
3. Safety Injection signal
4. Undervoltage on both 4.16 kV normal buses (turbine driven pump only)

Manual control from both the control room and the Hot Shutdown Panel are also available. The design provides assurance that water can be supplied to the steam generators for decay heat removal when the normal feedwater system is not available.

#### Underfrequency 4kV Bus

The underfrequency 4kV bus trip does not provide a direct reactor trip signal to the reactor protection system. A reactor coolant pump bus underfrequency signal from both buses provides a trip signal to both reactor coolant pump breakers. Trip of the reactor coolant pump breakers results in a reactor trip. The underfrequency trip protects against postulated flow coastdown events.

#### Limiting Instrument Setpoints

1. The high containment pressure limit is set at about 10% of the maximum internal pressure. Initiation of Safety Injection protects against loss of coolant (Reference 2) or steam line break accidents as discussed in the safety analysis.
2. The Hi-Hi containment pressure limit is set at about 50% of the maximum internal pressure for initiation of containment spray and at about 30% for initiation of steam line isolation. Initiation of Containment Spray and Steam Line Isolation protects against large loss of coolant (Reference 2) or steam line break accidents (Reference 3) as discussed in the safety analysis.
3. The pressurizer low pressure limit is set substantially below system operating pressure limits. However, it is sufficiently high to protect against a loss of coolant accident as shown in the safety analysis (Reference 2).

### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

#### Limiting Instrument Setpoints (continued)

4. The steam line low pressure signal is lead/lag compensated and its set-point is set well above the pressure expected in the event of a large steam line break accident as shown in the safety analysis (Reference 3).
5. The high steam line flow limit is set at approximately 20% of nominal full-load flow at the no-load pressure and the high-high steam line flow limit is set at approximately 120% of nominal full-load flow at the full load pressure in order to protect against large steam break accidents. The coincident low  $T_{avg}$  setting limit for steam line isolation initiation is set below its hot shutdown value. The safety analysis shows that these settings provide protection in the event of a large steam break (Reference 3).
6. Steam generator low-low water level and 4.16 kV Bus 11 and 12 (21 and 22 in Unit 2) low bus voltage provide initiation signals for the Auxiliary Feedwater System. Selection of these setpoints is discussed in the Bases of Section 2.3 of the Technical Specification.
7. High radiation signals providing input to the Containment Ventilation Isolation circuitry are set in accordance with the Radioactive Effluent Technical Specifications. The setpoints are established to prevent exceeding the limits of 10 CFR Part 20 at the SITE BOUNDARY.
8. The degraded voltage protection setpoint is  $90 \pm 2\%$  of nominal 4160 V bus voltage. Testing and analysis have shown that all safeguards loads will operate properly at or above the degraded voltage setpoint. The degraded voltage protection time delay of  $6 \pm 2$  seconds has been shown by testing and analysis to be long enough to allow for voltage dips resulting from the starting of large loads. This time delay is also consistent with the maximum time delay assumed in the ECCS analysis for starting of a safety injection pump. A maximum limit on the degraded voltage setpoint has been established to prevent unnecessary actuation of the voltage restoring scheme.

The loss of voltage protection setpoint is approximately 55% of nominal 4160 V bus voltage. Relays initiate a rapid (less than two seconds) transfer to an alternate source on loss of voltage.

### 3.5 INSTRUMENTATION SYSTEM

#### Bases continued

#### Instrument Operating Conditions

During plant operations, the complete instrumentation systems will normally be in service. Reactor safety is provided by the Reactor Protection System, which automatically initiates appropriate action to prevent exceeding established limits. Safety is not compromised, however, by continuing operation with certain instrumentation channels out of service since provisions were made for this in the plant design. This specification outlines limiting conditions for operation necessary to preserve the effectiveness of the Reactor Control and Protection System when any one or more of the channels is out of service.

Almost all reactor protection channels are supplied with sufficient redundancy to provide the capability for CHANNEL CALIBRATION and test at power. Exceptions are backup channels such as reactor coolant pump breakers. The removal of one trip channel on process control equipment is accomplished by placing that channel bistable in a tripped mode; e.g., a two-out-of-three circuit becomes a one-out-of-two circuit. The source and intermediate range nuclear instrumentation system channels are not intentionally placed in a tripped mode since these are one-out-of-two trips, and the trips are therefore bypassed during testing. Testing does not trip the system unless a trip condition exists in a concurrent channel.

#### References

1. USAR, Section 7.4.2
2. USAR, Section 14.6.1
3. USAR, Section 14.5.5
4. FSAR, Appendix I



### 3.6 CONTAINMENT SYSTEM

#### Bases

Proper functioning of the Shield Building vent system is essential to the performance of the containment system. Therefore, except for reasonable periods of maintenance outage for one redundant chain of equipment, the system should be wholly in readiness whenever above 200°F. Proper functioning of the auxiliary building special vent system and isolation of the auxiliary building normal vent system are similarly necessary to preclude possible unfiltered leakage through penetrations that enter the special ventilation zone.

For a train of the Shield Building Ventilation System to be considered OPERABLE, the safety injection actuation input and the pressure difference input for recirculation damper control must be OPERABLE. For a train of the Auxiliary Building Special Ventilation System to be considered OPERABLE, the safety injection actuation input to start fans and to isolate the normal ventilation system must be OPERABLE.

The auxiliary building special ventilation zone and its associated ventilation system have been designed to serve as secondary containment following a loss of coolant accident (Reference 2). Special care was taken to design the access doors in the boundary and isolation valves in normal ventilation systems so that AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY can be intact during reactor operation. The zone can perform its accident function with openings if they can be closed within 6 minutes, since the accident analysis assumed direct leakage of primary containment atmosphere to the environs when the shield building is at positive pressure (6 minutes). As noted in Reference 2, part of the Shield Building is part of the Auxiliary Building Special Ventilation Zone. The part of the Shield Building which is part of the Auxiliary Building Special Ventilation Zone is subject to the Technical Specifications of the SHIELD BUILDING INTEGRITY and not those associated with AUXILIARY BUILDING SPECIAL VENTILATION ZONE INTEGRITY.

The action statement which allows SHIELD BUILDING INTEGRITY to be lost for 24 hours will allow for minor modifications to be made to the Shield Building during power operations.

The COLD SHUTDOWN condition precludes any energy release or buildup of containment pressure from flashing of reactor coolant in the event of a system break.

The shutdown margin for the COLD SHUTDOWN condition assures sub-criticality with the vessel closed, even if the most reactive rod control cluster assembly were inadvertently withdrawn.

The 2 psig limit on internal pressure provides adequate margin between the maximum internal pressure of 46 psig and the peak accident pressure resulting from the postulated Design Basis Accident (Reference 1).

The containment vessel is designed for 0.8 psi internal vacuum, the occurrence of which will be prevented by redundant vacuum breaker systems.

### 3.6 CONTAINMENT SYSTEM

#### Bases continued

The containment has a nil ductility transition temperature of 0°F. Specifying a minimum temperature of 30°F will provide adequate margin above NDTT during power operation when containment is required.

The conservative calculation of off-site doses for the loss of coolant accident (References 2, 4) is based on an initial shield building annulus air temperature of 60°F and an initial containment vessel air temperature of 104°F. The calculated period following LOCA for which the shield building annulus pressure is positive, and the calculated off-site doses are sensitive to this initial air temperature difference. The specified 44°F temperature difference is consistent with the LOCA accident analysis (Reference 4).

The initial testing on leakage into the shield building and the auxiliary building special ventilation zone (ABSVZ) has resulted in greater specified inleakage (Figure TS.4.4-1, change No. 1) and the necessity to deenergize the turbine building exhaust fans in order to achieve a negative pressure in the ABSVZ (TS.3.6.E.2). The staff's conservative calculation of doses for these conditions indicated that changing allowable containment leak rate from 0.5% to 0.25%/day would offset the increased leakage (Reference 3).

High efficiency particulate absolute (HEPA) filters are installed before the charcoal adsorbers to prevent clogging of the iodine adsorbers for all emergency air treatment systems. The Charcoal adsorbers are installed to reduce the potential release of radioiodine to the environment.

The operability of the equipment and systems required for the control of hydrogen gas ensures that this equipment will be available to maintain the hydrogen concentration within containment below its flammable limit during post-LOCA conditions. Either recombiner unit is capable of controlling the expected hydrogen generation associated with (1) zirconium-water reactions, (2) radiolytic decomposition of water, and (3) corrosion of metals within containment. These hydrogen control systems are consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA", March 1971.

Air locks are provided with two doors, each of which is designed to seal against the maximum containment pressure resulting from the limiting DBA. Should an air lock become inoperable as a result of an inoperable air lock door or an inoperable door interlock, power operation may continue provided that at least one OPERABLE air lock door is closed. With an air lock door inoperable, access through the closed or locked OPERABLE door is only permitted for repair of inoperable air lock equipment.

### 3.6 CONTAINMENT SYSTEM

#### Bases continued

OPERABILITY of air locks is required to ensure that CONTAINMENT INTEGRITY maintained. Should an air lock become inoperable for reasons other than an inoperable air lock door, the air lock leak tight integrity must be restored within 24 hours or actions must be taken to place the unit in a condition for which CONTAINMENT INTEGRITY is not required.

#### References

1. USAR, Section 5
2. USAR, Section 10.3.4 and FSAR Appendix G
3. Letter to NSP dated November 29, 1973
4. Letter to NSP dated September 16, 1974



### 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

#### Bases

Throughout the 3.10 Technical Specifications, the terms "rod(s)" and "RCCA(s)" are synonymous.

#### A. Shutdown Margin

A sufficient shutdown margin ensures that: (1) the reactor can be made subcritical from all operating conditions, (2) the reactivity transients associated with postulated accident conditions are controllable within acceptable limits, and (3) the reactor will be maintained sufficiently subcritical to preclude inadvertent criticality in the shutdown condition.

Shutdown Margin requirements vary throughout core life as a function of fuel depletion, reactor coolant system boron concentration and reactor coolant average temperature. The most restrictive condition occurs at end of life and is associated with a postulated steam line break accident and resulting uncontrolled reactor coolant system cooldown. In the analysis of this accident, a minimum Shutdown Margin as defined by Figure TS.3.10-1 is required to control the reactivity transient. Accordingly, the Shutdown Margin requirement is based upon this limiting condition and is consistent with plant safety analysis assumptions. With reactor coolant system average temperature less than 200°F, the reactivity transients resulting from a postulated steam line break cooldown are minimal and a 1%  $\Delta k/k$  Shutdown Margin provides adequate protection.

#### B. Power Distribution Control

The specifications of this section provide assurance of fuel integrity during Condition I (Normal Operations) and II (Incidents of Moderate frequency) events by: (a) maintaining the minimum DNBR in the core of greater than or equal to 1.30 for Exxon fuel and 1.17 for Westinghouse fuel during normal operation and in short term transients, and (b) limiting the fission gas release, fuel pellet temperature and cladding mechanical properties to within assumed design criteria. The ECCS analysis was performed in accordance with SECY 83-472. One calculation at the 95% probability level was performed as well as one calculation with all the required features of 10 CFR Part 50, Appendix K. The 95% probability level calculation used the peak linear heat generation rate specified in the CORE OPERATING LIMITS REPORT. The Appendix K calculation used the peak linear heat generation rate specified in the CORE OPERATING LIMITS REPORT for the  $F_0$  limit specified in the CORE OPERATING LIMITS REPORT. Maintaining 1) peaking factors below the  $F_0$  limit specified in the CORE OPERATING LIMITS REPORT during all Condition I events and 2) the peak linear heat generation rate below the value specified in the CORE OPERATING LIMITS REPORT at the 95% probability level assures compliance with the ECCS analysis.

### 3.10 CONTROL ROD AND POWER DISTRIBUTION LIMITS

Bases continued

#### B. Power Distribution Control (continued)

During operation, the plant staff compares the measured hot channel factors,  $F_{Q}^N$  and  $F_{\Delta H}^N$ , (described later) to the limits determined in the transient and LOCA analyses. The terms on the right side of the equations in Section 3.10.B.1 represent the analytical limits. Those terms on the left side represent the measured hot channel factors corrected for engineering, calculational, and measurement uncertainties.

$F_{Q}^N$  is the measured Nuclear Hot Channel Factor, defined as the maximum local heat flux on the surface of a fuel rod divided by the average heat flux in the core. Heat fluxes are derived from measured neutron fluxes and fuel enrichment.

The  $K(Z)$  function specified in the CORE OPERATING LIMITS REPORT is a normalized function that limits  $F_Q$  axially. The  $K(Z)$  value is based on large and small break LOCA analyses.

$V(Z)$  is an axially dependent function applied to the equilibrium measured  $F_{Q}^N$  to bound  $F_{Q}^N$ 's that could be measured at non-equilibrium conditions. This function is based on power distribution control analyses that evaluated the effect of burnable poisons, rod position, axial effects, and xenon worth.

$F_{Q}^E$ , Engineering Heat Flux Hot Channel Factor, is defined as the allowance on heat flux required for manufacturing tolerances. The engineering factor allows for local variations in enrichment, pellet density and diameter, surface area of the fuel rod and eccentricity of the gap between pellet and clad. Combined statistically the net effect is a factor of 1.03 to be applied to fuel rod surface heat flux.

The 1.05 multiplier accounts for uncertainties associated with measurement of the power distribution with the movable incore detectors and the use of those measurements to establish the assembly local power distribution.

$F_{Q}^N$  (equil) is the measured limiting  $F_{Q}^N$  obtained at equilibrium conditions during target flux determination.

$F_{\Delta H}^N$ , Nuclear Enthalpy Rise Hot Channel Factor, is defined as the ratio of the integral of linear power along the rod with the highest integrated power to the average rod power.

#### 4.1 OPERATIONAL SAFETY REVIEW

##### Bases

##### CHANNEL CHECK

Failures such as blown instrument fuses, defective indicators, faulted amplifiers which result in "upscale" or "downscale" indication can be easily recognized by simple observation of the functioning of an instrument or system. Furthermore, such failures are, in many cases, revealed by alarm or annunciator action, and a check supplements this type of built-in surveillance.

Based on experience in operation of both conventional and nuclear plant systems, when the plant is in operation, the minimum checking frequencies set forth are deemed adequate for reactor and steam system instrumentation.

##### CHANNEL CALIBRATION

Calibration is performed to ensure the presentation and acquisition of accurate information.

The nuclear flux (linear level) channels daily calibration against a thermal power calculation will account for errors induced by changing rod patterns and core physics parameters.

Other channels are subject only to the "drift" errors induced within the instrumentation itself and, consequently, can tolerate longer intervals between calibration. Process system instrumentation errors induced by drift can be expected to remain within acceptable tolerances if recalibration is performed at intervals of each refueling shutdown.

Substantial calibration shifts within a channel (essentially a channel failure) will be revealed during routine checking and testing procedures.

##### CHANNEL FUNCTIONAL TESTS

The specified surveillance intervals for the Reactor Protection and Engineered Safety Features instrumentation have been determined in accordance with WCAP-10771, "Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation System", and supplements to that report. Surveillance intervals were determined based on maintaining an appropriate level of reliability of the Reactor Protection System and Engineered Safety Features instrumentation.

##### CHANNEL RESPONSE TESTS

Measurement of response times for protection channels are performed to assure response times within those assumed for accident analysis (USAR, Section 14).