



P.O. Box 300  
Seabrook, NH 03874  
Telephone (603) 474-5521  
Facsimile (603) 474-2987

Ted C. Feigenbaum  
Senior Vice President and  
Chief Nuclear Officer

NYN- 92127

September 30, 1992

United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Document Control Desk

Reference: Facility Operating License No. NPF-86, Docket No. 50-443

Subject: License Amendment Request 92-13; Manual Operation of Cooling Tower Fans  
and Sprays

Gentlemen:

North Atlantic Energy Service Corporation (North Atlantic) has enclosed License Amendment Request 92-13. This License Amendment Request is submitted pursuant to 10CFR50.90 and is distributed pursuant to 10CFR50.4.

The purpose of License Amendment Request 92-13 is to propose changes to the Seabrook Station Technical Specifications. The proposed change will increase the Technical Specification temperature limit for the cooling tower basin water from the current 67.3°F to 70.0°F and permit the cooling tower sprays and fans to be manually operated following a cooling tower actuation.

License Amendment Request 92-13 has been reviewed and approved by the North Atlantic Station Operation Review Committee and the Nuclear Safety Audit Review Committee.

As discussed in the enclosed License Amendment Request 92-13, Section V, the proposed changes have been determined not to involve a significant hazards consideration pursuant to the standards of 10CFR50.92. A copy of this letter and the enclosed License Amendment Request 92-13 have been forwarded to the State of New Hampshire State Liaison Officer pursuant to 10CFR50.91(b).

North Atlantic requests NRC review of License Amendment Request 92-13 and issuance of a license amendment by March 1, 1993 or as soon as possible (see enclosed License Amendment Request 92-05, Section VI).

020044

9210080140 920930  
PDR ADOCK 05000443  
P PDR

member of the Northeast Utilities system


ACD

United States Nuclear Regulatory Commission  
Attention: Document Control Desk

September 30, 1992  
Page two

Should you have any questions regarding this letter, please contact Mr. Terry L. Harpster, Director of Licensing at (603) 474-9521 extension 2765.

Very truly yours,

  
Ted C. Feigenbaum

Enclosures

TCF:MDO

cc: Mr. Thomas T. Martin  
Regional Administrator  
United States Nuclear Regulatory Commission  
Region 1  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Gordon E. Edison, Sr. Project Manager  
Project Directorate I-3  
Division of Reactor Projects  
United States Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Noel Dudley  
NRC Senior Resident Inspector  
P.O. Box 1149  
Seabrook NH 03874

Mr. George Iverson, Director  
New Hampshire Director of Emergency Management  
State Office Park South  
107 Pleasant Street  
Concord NH 03301