



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4040

10CFR50.36
John L. Skolds
Vice President
Nuclear Operations

October 6, 1992

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Director, Office of Resource Management

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SEPTEMBER MONTHLY OPERATING REPORT

Enclosed is the September 1992 Monthly Operating Report for the Virgil C. Summer Nuclear Station Unit No. 1. This submittal is made in accordance with the requirements of Technical Specifications, Section 6.9.1.10.

If there are any questions, please call me at your convenience.

Very truly yours,

John L. Skolds

JWH:RJB:lcd
Attachments

cc: O. W. Dixon
R. R. Mahan
R. J. White
S. D. Ebner
G. F. Wunder
General Managers
G. J. Taylor
NRC Resident Inspector
J. B. Knotts Jr.

J. W. Flitter
F. Yost
INPO Records Center
Marsh & McLennan
Pat Haught (Westinghouse)
NSRC
RTS (MON 2000)
File (818.03-1)

9210090377 920930
PDR ADDCK 05000395
R PDR

NUCLEAR EXCELLENCE - A SUMMER TRADITION!

IE24

111

ATTACHMENT I
AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50/395
UNIT V. C. SUMMER I
DATE 10/1/92
COMPLETED BY J. W. HALTIWANGER
TELEPHONE (803) 345-4297

SEPTEMBER 1992

DAY AVERAGE DAILY POWER LEVEL

DAY AVERAGE DAILY POWER LEVEL

	(MWe-Net)
1.	878
2.	882
3.	884
4.	884
5.	878
6.	877
7.	883
8.	884
9.	884
10.	885
11.	883
12.	883
13.	883
14.	883
15.	884
16.	885

	(MWe-Net)
17.	884
18.	885
19.	886
20.	885
21.	884
22.	885
23.	884
24.	885
25.	887
26.	886
27.	887
28.	886
29.	886
30.	886

ATTACHMENT II
OPERATING DATA REPORT

DOCKET NO. 50/395
UNIT V. C. SUMMER I
DATE 10/ 1/92
COMPLETED BY J. J. HALTIWANGER
TELEPHONE 803) 345-4127

OPERATING STATUS

1. Reporting Period: September 1992
Gross Hours in Reporting Period: 720
2. Currently Authorized Power Level (MW): 2775
Max. Depend. Capacity (MWe-Net): 885
Design Electrical Rating (MWe-Net): 900
3. Power Level to Which Restricted (If Any)(MWe-Net): N/A
4. Reasons for Restrictions: N/A

	THIS MONTH -----	YR TO DATE -----	CUMULATIVE -----
5. Number of Hours Reactor Critical	720.0	6344.1	60968.7
6. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
7. Hours Generator on Line	720.0	6323.6	59811.3
8. Unit Reserve Shutdown Hours	0.0	0.0	0.0
9. Gross Thermal Energy Generated (MWH) 1995350		17354302	155923069
10. Gross Electrical Energy(MWH) 663210		5789730	51575129
11. Net Electrical Energy Generated (MWH) 636383		5546969	49094251
12. Reactor Service Factor	100.0	96.5	79.5
13. Reactor Availability Factor	100.0	96.5	79.5
14. Unit Service Factor	100.0	96.2	78.0
15. Unit Availability Factor	100.0	96.2	78.0
16. Unit Capacity Factor (Using MDC)	99.9	95.3	72.3
17. Unit Capacity Factor (Design MWe)	98.2	93.7	71.1
18. Unit Forced Outage Rate	0.0	0.0	6.1
19. Shutdowns Scheduled Over Next 6 Months(Type, Date & Duration of Each): Refueling, March 5, 1993, 65 days.			
20. If Shut Down at End of Report Period, Estimated Date of Startup: N/A			
21. Units in Test Status (Prior to Commercial Operation): N/A			

ATTACHMENT III
UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50/395
UNIT V. C. SUMMER I
DATE 10/ 1/92
COMPLETED BY J. W. HALTIWANGER
TELEPHONE (803) 345-4297

SEPTEMBER 1992

NO.	DATE	TYPE	DURATION	REASON	METHOD	CORRECTIVE ACTION/COMMENTS
-----	------	------	----------	--------	--------	----------------------------

NONE

1.0 REASON

- A: Equipment Failure
- B: Maintenance or Test
- C: Refueling
- D: Regulatory Restriction
- E: Operator Training and License Examination
- F: Administrative
- G: Operational Error
- H: Other (Explain)

2.0 METHOD

- 1: Manual
- 2: Manual Scram
- 3: Automatic Scram
- 4: Continuation (Use initial Date)
- 5: Power Reduction (Duration 0.0)
- 9: Other (Explain)

Director, Office of Resource Management
September Monthly Operating Report
Page 4

ATTACHMENT IV
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50/395
UNIT V. C. SUMMER I
DATE 10/ 1/92
COMPLETED BY J. W. HALTIWANGER
TELEPHONE (803) 345-4297

SEPTEMBER 1992

V. C. Summer Station, Unit 1, operated at approximately 100 percent power for the entire month of September.