



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

February 8, 1971

Roger S. Boyd, Assistant Director, BWR, Division of Reactor Licensing
THRU: Donald F. Knuth, Chief, BWR-1, Division of Reactor Licensing

Donald F. Knuth
MEETING SUMMARY FOR NORTHERN STATES POWER COMPANY, MONTICELLO NUCLEAR
GENERATING UNIT NO. 1, POL NO. DPR-22, DOCKET NO. 50-263

A meeting was held with NSP on February 4, 1971, to discuss the full-power license for the Monticello plant. Those in attendance at the meeting are listed in the enclosure.

The Monticello Nuclear Generating Plant Unit No. 1 is authorized to operate at no higher than 5 MWt until the feedwater pumps are operational. In the meantime, cracks have been found on both feedwater bypass lines. According to the licensee, these cracks were not formed as a result of the feedwater pump vibrations, but due to forces generated from the closing of the bypass valve (a 4-inch angle valve in the 6-inch line).

The licensee has agreed to do the following:

1. Install restraints in the pipes.
2. Review the stresses in other feedwater piping.
3. With restraints in place, check piping for vibration.
4. Replace the eroded orifice downstream of the valve.
5. Test the valve in the "B" loop and show proper operation (valve in "A" loop works properly). Sign-off preoperational testing program.
6. Test feedwater pump in "A" loop and show proper operation.

The licensee expects that it will take seven to ten days to finish the proposed program.

We informed the licensee that:

1. We understand the need for power operation to continue testing for checking out the systems;
2. The proposed program seems satisfactory to us and it will be up to Compliance to see that it has been carried out satisfactory; and
3. Provided that no additional safety related items arise, upon written notification from Compliance, the restrictions imposed in the license to go to full power could be removed.

Victor Benaroya

Victor Benaroya, Project Leader
Boiling Water Reactor Br. No. 1
Division of Reactor Licensing

Enclosure:
Attendance List

9212080403 710208
PDR ADOCK 05000263
P PDR

NSP - MONTICELLO

Meeting Attendance

February 4, 1971

AEC/DRL

D. F. Knuth
V. Benaroya
D. B. Vassallo

AEC/CO

J. G. Keppler
J. P. O'Reilly
C. D. Feierabend

Shaw, Pittman, etc.

G. Charnoff

NSP

E. C. Ward
M. F. Dinville
R. O. Duncanson
W. V. Jokela

General Electric

J. B. Violette
J. W. Eberle
I. F. Stuart
R. V. Poe

Bechtel

R. Anderson
R. W. Straiton
F. E. Vinson

Roger S. Boyd

- 3 -

Distribution:

Docket ✓
DRL Reading
BWR-1 File
PAMorris
F Schroeder
Asst. Directors, DRL
EGCase, DRS
RRMaccary, DRS
PWHowe, DRL
BR. Chiefs, DRL/DRS
Compliance (2)
BGrimer, DRL
SMKari, DRL
VBensaroya, DRL
Attendees, DRL/CO

OFFICE ▶						
SURNAME ▶						
DATE ▶						