

Duke Power Company  
McGuire Nuclear Generation Department  
12700 Hagers Ferry Road (MG01A)  
Huntersville, NC 28078-8985

T. C. McMeekin  
Vice President  
(704) 875-4800  
(704) 875-4809 Fax



**DUKE POWER**

November 30, 1992

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: McGuire Nuclear Station, Unit 1  
Docket Nos. 50-369  
Inservice Inspection, Section XI  
Second Interval, Unit 1  
Relief Request 92-05


Dear Sir;

Pursuant to 10 CFR 50.55a(g)(5)(iii), I am submitting the attached relief request for NRC review and approval. This request for relief from ASME Code requirements involves the Unit 1 safety-related snubber selection plan required by Section XI during the second interval. A copy of the Inservice Inspection plan that will be used during the second interval for McGuire Nuclear Station, Unit 1 was provided by my letter dated October 12, 1992.

For your information, a similar relief request was approved by the NRC for both units during the first interval. This approval is documented within a March 26, 1985 NRC letter.

Should there be any questions regarding this matter, please contact Paul Guill at (704) 875-4002.

Very truly yours,

  
Ted C. McMeekin

9212090082 921130  
PDR ADCKK 05000369  
G PDR

A047

U. S. Nuclear Regulatory Commission  
November 30, 1992  
page 2

xc: Mr. S. D. Ebnetter  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. P. K. Van Doorn  
Senior NRC Resident Inspector, McGuire  
McGuire Nuclear Station

Mr. T. A. Reed, Project Manager  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop 943  
Washington, D.C. 20555

John C. Brooks, Commissioner of Labor  
Attention: Director, Boiler & Pressure Vessel Division  
Department of Labor State of North Carolina  
4 West Edenton Street  
Raleigh, North Carolina 27601

U. S. Nuclear Regulatory Commission  
November 30, 1992  
page 3

xc: with attachment  
R. O. Sharpe  
L. J. Kunka  
P. T. Vu  
P. F. Guill  
T. D. Curtis  
R. B. Travis  
R. E. Hall  
W. H. Taylor  
B. H. Hamilton  
J. W. Boyle  
R. D. Klein (MG01MM)  
J. O. Barbour (NS)  
J. M. Boughman (NS)  
J. E. Cherry (NS)  
A. J. Hogge (NS)  
G. J. Underwood (NS)  
R. L. Cill, jr (N<sup>c</sup>)  
H. A. Froebe (NS [File:MC-801.01]  
File: 801.01  
\pfg062.nrc

# ATTACHMENT

DUKE POWER COMPANY  
MCGUIRE NUCLEAR STATION

## Request for Relief From ASME Code Section XI Requirements

### I. Component for Which Relief is Requested

- A. Name and Identification Number  
All safety-related snubbers for Unit 1
- B. Function  
Snubbers are designed to prevent pipe motion under dynamic loads.
- C. ASME Section XI Code Class  
Provides support for Class 1, 2 and 3 systems
- D. Valve Category  
Not Applicable

### II. ASME Code Section XI Requirement That Has Been Determined To Be Impractical

ASME Boiler and Pressure Vessel Code Section XI, 1986  
Edition, Article IWF-5000

### III. Basis for Requesting Relief

The McGuire Nuclear Station Technical Specification (TS) Surveillance Requirement 4.7.8 states that each snubber required by Technical Specification (TS) 3.7.8 be operable by performing an augmented inservice inspection program (as specified in TS 4.7.8a-1). Part of this augmented inspection program (TS 4.7.8e), requires that during the first refueling shutdown and at least once per refueling thereafter, a representative sample of snubbers be tested using one of three stated sample plans.

In addition to the above TS requirement, TS 4.0.5 requires that the rules of ASME Boiler and Pressure vessel Code Section XI be followed. Whereas TS 4.7.8e permits for the selection of one of the three sampling plans for snubber functional tests, the ASME Code Section XI has only one sampling plan to follow.

Prior to 1980, the ASME Code Section XI and Generic Standard TS sampling plan requirements were identical. That is, the Generic Standards TS specified only one plan and it was identical to what was specified by section XI. In the 1980 revision of the Generic Standard TS, up to date operating experience and design practices were used as a basis for the three sampling plans, one of which is identical to the Section XI plan. By a letter dated February 14, 1984, Duke notified the NRC that sample plan number 2 for the functional testing of snubbers would be performed during the first McGuire Unit 1 refueling shutdown. This plan involves functionally testing a representative sample of snubbers in accordance with TS Figure 4.7.1. Since this plan for snubber selection differs from that specified in Section XI of the 1986 Edition of the ASME Code, relief from the requirements of this portion of the ASME Code is requested.

The code requirement to perform functional testing on 10% of the total number of snubbers, with subsequent samples of an additional 10% if any snubber fails the test, is impractical for stations with large number of snubbers. The consequences of using the 10% sample plan would lead to excessive radiation exposures, an increase in reinstallation errors, additional manpower requirements, and possibly extended outages due to the probability of being required to test 100% of the snubber population. Alternate sampling plans, as outlined in the McGuire TS, will provide a 95% confidence level that 90% of the snubbers are operable. The NRC has reviewed these alternate plans and has found them acceptable. Due to the problems of dealing with such a large population of snubbers as required under the 10% plan, we would anticipate an actual decrease in the level of safety provided. McGuire Units 1 and 2 have a total population of approximately 2500 safety related snubbers.

IV. Alternate Testing

Safety-related snubbers will be functionally tested per plan number 2 of the alternative plans in the McGuire TS 3/4.7.8.e.

V. Implementation Schedule

McGuire safety-related snubbers will continue to be functionally tested per the requirements of the TS.