

REGULATORY DOCKET FILE COPY

September 7, 1979

Docket No.: 50-320

Mr. John G. Harbein, Vice President
Nuclear Operation
c/o Three Mile Island Nuclear Station
Middletown, Pa. 17057

Dear Mr. Harbein:

SUBJECT: POWER SUPPLY FOR MDHR PUMP MOTORS

It is our understanding that the current design criteria for MDHR pump motor power requires a Class IE source and that the motors are not Class IE qualified. It is noted that there are other non-IE loads on the IE buses (see attached). This is part of the original plant design which was approved for an operating license. On this basis, we concur with the proposed criteria for MDHR pump motor power.

J. T. Collins
Deputy Director
TMI-Support

cc: R. Fitzpatrick
S. Newberry
A. Ignatonia
M. Greenberg
J. Waxmail
B. Elam, GPU
R. Harding, Mat-Ed
R. Vollmer

DISTRIBUTION:
Docket Files
NRR Rdg. File
SEP/TMI R/F
PSS/TMI R/F
PDR

OFFICE	TMI-Support				
SURNAME	JTC:llins:jb				
DATE	9/7/79			7910190327	