



Duquesne Light

Nuclear Group
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

May 28, 1985

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
ASME Section XI Code Case N-288

Gentlemen:

Code Case N-288 waived the 100°F minimum test temperature requirement for both Class 1 and Class 2 components constructed entirely of austenitic materials.

We request NRC staff authorization to use Code Case N-288 during the remainder of our first 10-year ISI interval presently scheduled to end September 20, 1984. Various inservice inspections including Hydrostatic Testing, will be performed during the next two refueling outages, the first of which is scheduled to begin in May of 1986. Your timely review of this request would be appreciated in order to plan outage activities in preparation for our May 1986 (fifth refueling) outage.

If you have any questions concerning this subject, please contact my office.

Very truly yours,

J. J. Carey
Vice President, Nuclear

8506110315 850528
PDR ADOCK 05000334
G PDR

cc: Mr. W. M. Trostoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission (2)
c/o Document Management Branch
Washington, DC 20555

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P.O. Box 26666
One James River Plaza
Richmond, VA 23261

A047
1/0