

Appendix

NOTICE OF VIOLATION

Commonwealth Edison Company

Docket No. 50-373

Docket No. 50-374

As a result of the inspection conducted on May 9-28, 1985, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

1. Technical Specification 6.2.B requires that radiation control procedures be maintained, made available to all personnel, and adhered to.
 - a. LaSalle Radiation Protection Procedure (LRP-1250-3) requires that individuals wear personnel dosimeters (film badge and self-reading dosimeter) near each other on the front part of the body at or above waist level.

Contrary to the above, during this inspection, many workers were observed wearing their personal film badges on their trouser pockets or at the hip section of their trousers.
 - b. LaSalle Radiation Protection Procedure (LRP-1480-4) requires that individuals using friskers survey their hands and shoes by moving the probe slowly over the area of interest.

Contrary to the above, two workers were observed at frisker stations who did not survey their hands, and who did not survey their shoes in accordance with the posted frisking instructions.
 - c. LaSalle Radiation Protection Procedure (LRP 1410-1) states that after removing protective clothing, a whole body frisk is required in accordance with LRP 1480-4.

Contrary to the above, two persons were observed to remove their protective clothing at a controlled step-off pad area without frisking prior to changing into their personal clothing.

This is a Severity Level IV violation (Supplement IV).


Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be

8506110378 850607
PDR ADDCK 05000373
G PDR

taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

6/5/85

Dated _____



C. J. Paperiello, Chief
Emergency Preparedness and
Radiological Protection Branch