



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-082
(412) 787-5141
(412) 923-1960
Telecopy (412) 787-2629

June 4, 1985

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief
Licensing Branch 3
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
Revision to the Response to DSER Outstanding Issue 76


REFERENCE: 2NRC-4-049, dated April 30, 1984

Gentlemen:

Duquesne Light Company letter 2NRC-4-049 of April 30, 1984, transmitted the response to Outstanding Issue 76 as Attachment 1. Paragraph 2.b(3) of that response referred to the pressurizer PORVs as air operated valves. These valves have been upgraded to Garrett solenoid operated valves. This information will be incorporated into the response to FSAR Question 420.4.

DUQUESNE LIGHT COMPANY

By


J. J. Carey
Vice President

KAT/wjs

cc: Mr. B. K. Singh, Project Manager
Mr. G. Walton, NRC Resident Inspector

8506110398 850604
PDR ADOCK 05000412
E PDR

Boo!
1/0