

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T	
0	1

REPORT
SOURCE

SOURCE 60 61 POCKET NUMBER

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 3 The plant was in Operational Mode 3 with the RCS temperature less than the 10-10
0 4 average temperature value of 543 degrees. At 1108 hours, the No. 4 Vital Bus
0 5 Inverter was transferred from its auxiliary power source to the Inverter. However,
0 6 the Inverter was not operable and, when the vital bus was transferred to the
0 7 deenergized inverter, it resulted in a high steam flow signal coincident with the
0 8 10-10 temperature and a safety injection occurred. Safety injections to date:
0 9 113 operational, 2 preoperational.

09		SYSTEM CODE E D 11		CAUSE CODE A 12		CAUSE SUBCODE A 13		COMPONENT CODE G E N E R A 14				COMP SUBCODE F 15		VALVE SUBCODE Z 16			
7 8		9 10		11 12		13 14		15 16				17 18		19 20			
17		EVENT YEAR 7 9 21		SEQUENTIAL REPORT NO. 0 4 0 24		OCCURRENCE CODE 9 9 25		REPORT TYPE X 30		REVISION NO. 0 32							
ACTION TAKEN H 18		FUTURE ACTION Z 19		EFFECT ON PLANT C 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM 508 N 24		PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER S 3 7 9 26	
13 14		15 16		17 18		19 20		21 22		23 24		25 26		27 28		29 30	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 3 The incident resulted from operator error in transferring the No. 4 Vital Bus to
1 4 the deenergized inverter. The involved personnel were reprimanded and reminded of
1 5 the necessity to adhere to written procedures.
1 6
1 7
1 8

FACILITY STATUS										N POWER										OTHER STATUS (30)										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION (32)									
1 5 G 29										0 0 0 29										N/A										A 31										Operational event									
ACTIVITY CONTENT										RELEASED OF RELEASE										AMOUNT OF ACTIVITY (35)										LOCATION OF RELEASE (36)																			
1 6 G 33										Z 34										N/A										N/A																			

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	2	3	4	5	6	7	8	9	10
0	0	0	3	2	38	N/A			

PERSONNEL NUMBER		DESCRIPTION	
10	101010	10	N/A

POOR ORIGINAL

LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION		N/A		90002349	
1	2	3	4	5	6	7	8

PUBLICITY
 ISSUED ☐ DESCRIPTION ☒ N/A 7912270520 NRC USE ONLY

NAME OF PREPARER J. A. Werling

PHONE 412-643-1258