

POOR ORIGINAL

90003002  
7912280

# UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November, 1979

DOCKET NO. 50-318  
UNIT NAME Calvert Cliffs #2  
DATE 12/19/79  
COMPILED BY S. D. Merson  
TELEPHONE 234-5240

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
79-17	791012	S	608.0	C	4	N/A	RC	FUELXY	Reactor refueling and unit general inspection. Plant was already shut down due to a unit trip.
79-18	791126	F	112.0	B	9	N/A	CB	HUMPX	Replace seals on reactor coolant pump 21B and 22B. Plant was already shut down due to refueling.

<sup>1</sup> F: Forced  
S: Scheduled

<sup>2</sup> Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

<sup>3</sup> Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Continuation  
5-Reduction  
9-Other

<sup>4</sup> Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup> Exhibit I - Same Source

(9/77)

527